

LED Commercial Down Light

Features:

- Replaces legacy CFL, HID or incandescent down lights.
- ETL & ES certified.
- AC Input:100-277V.
- 1-10V Dimmable.
- CCT and Power Adjustable
- High efficiency LM80 SMD LEDs, CRI90.
- Designed for 50,000 hours lifetime.






Application:

- ◆ Residential.
- ◆ Property management.
- ◆ Office, Multi-family.
- ♦ Hospitality, Healthcare etc..



Product Dimension:



| D1 | D3 | A | В | H1 | Н2 | Cut HOLE |
|--------|--------|--------|--------|--------|--------|----------|
| 8. 66" | 4. 69" | 9. 09" | 7. 09" | 4. 92" | 4. 72" | 7. 28" |

LED Commercial Down Light

Specifications

LED Commercial Down Light

| Model: | SZ-DL32W8-CD-ACP |
|----------------|--|
| Wattage: | Adjustable 18W/25W/32W |
| Size: | 8 inch |
| CCT: | Adjustable:2700K/3000K/3500K/4000K/5000K |
| CRI: | 90 |
| Beam Angle: | 105° |
| Lumens: | 125LM/W |
| PF: | >0.9 |
| Input: | 100-277V 50/60Hz |
| Certification: | ETL & ES |
| Warranty: | 5 years |

Package

| Size | Qty/Carton | Gross Weight |
|----------------------|------------|--------------|
| 19. 37*19. 33*17. 6" | 12 | 10.7Kg |

Installation instructions


RETROFIT INSTALLATION


- Shut off power at the sourceof the flxture housing into which you are installing fixture. Remove existing trim and CFL or incandescent bulb Note: Follow all federal and local regulations when disposing of lamps and removed components.
- 2.Measure celling opening to ensure that the edge of the luminaire will cover the entire opening and still sit firmly in the ceiling.
- Select desired Wattage and CCT using adjustment switches on fixture.
- 4. Attach carabiner safety clip to the existing fixture housing.




- 5. Insert lamp condult Into J-box and wire to power source(Black to Live, white to Neutra, Violet to 0-10V dlmmlng positive, Gray to 0-10V dlmmlng negative).

 Reattach J-box cover when done.
- Squeeze the two housing clips so they are in an upright position and then insert lamp into housing.
- 7. Once lamp is inside housing, release housing clips and continue to push lamp into housing until securely fixed and flush with celling. Restore power.










LED Commercial Down Light

INSTALLATION INSTRUCTIONS(continued)

RETROFIT INSTALLATION

- 1. Shut off power at the source of the flxture housing into which you are installing flxture.
- Create celling opening to ensure that the edge of the luminaire will cover the entire opening and still sit firmly in the celling.
- Select desired Wattage and CCT using adjustment switches on fixture.
- 4. Attach carabiner safety clip to secure location in ceiling.



Squeeze the two housing clips so they are in an upright position and then insert lamp into opening.

