

Product Summary

Part 1 : Dimensions

Width	Aus Timber Designs: 182 Oak Designs: 228	mm
Length	1524	mm
Total Thickness	5	mm
Wear Layer	0.7	mm
Boards Per Box	6	planks
Box Size	Aus Timber Designs: 1.664 Oak Designs: 2.084	sqm

Part 2 : General Data

Core Type	PVC Vinyl with Fibre-Glass Mesh
Wear Layer	0.7mm
Finish	Matte Light Embossed
Installation Method & Adhesives	Full trowel installation (refer to installation guidelines) F. BALL F44 Styccobond Adhesive F. BALL F58 Styccobond Adhesive F. BALL F48 PLUS - High Temperature (for areas of high temperature variation and areas with exposure to sunlight) FLOOR+ F2000 Vinyl & Resilient Adhesive
Surface Coat	UV-cured Lacquer (with anti-stain coat)
Box Weight	182mm Wide Planks: 16.1KG 228mm Wide Planks: 20.1KG
Profile	Micro Bevel

Pattern Repeat	12 - 15 Pure Unique 72 - 90 Unique Prints (with pattern shifts down the plank) Note: This is approximately triple the standard unique prints available on a vinyl floor, showcasing greater print and colour variations.
-----------------------	---

Part 3 : Warranty

General Residential	25	Years
Commercial	By Application	Years



Part 4: Wet Pendulum Slip Test (AS 4586-2013)

TEST REPORT

Client : Everfloor
2A 87 Allingham Street
Condell Park NSW 2200

Test Number : 25-000866
Issue Date : 2/04/2025
Print Date : 2/04/2025

**AS 4586-2013
Appendix A**

**Slip Resistance Classification of new Pedestrian Surface Materials
Wet Pendulum Test Method**

Date of Testing 01-04-2025
Operator AWTATest Operator 14
Test Temperature (20±5degC) 25 °C
Specimens Washed with pH Neutral Detergent then dried
Test Direction Length
Fixed/Unfixed Unfixed

Slider No 96 Batch No 33
Length 1 2 3 4 5 SRV
British Pendulum 34 35 38 37 38 36
number

Classification P3

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 11/10/2023
Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions , including maintenance and wear on their slip resistance be checked.