

Product declaration **K86656/11**

Issued 2026-03-05

Replaces K86656/10

Page 1 of 11

DSPA - Non-Pressurized Condensed Aerosol Generators and Components

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

DSPA B.V.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa Product Certification Scheme BRL-K23001/06 "for non-pressurized condensed aerosol generators and components used in fixed fire extinguishing systems" of September 2th, 2020 or K21045/02 scope E version 2021-03-30.

Ron Scheepers
Kiwa

Publication of this declaration is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchillaan 273

Postbus 70

2288 AB Rijswijk

Tel. +31 88 998 51 00

www.kiwa.nl

Executed by:

Kiwa Certification

NL.infocertification.fss@kiwa.com

www.kiwafss.nl

Company

DSPA B.V.

Hulzenseweg 30

6534 AC NIJMEGEN

P.O. Box 6572

6503 GB NIJMEGEN

The Netherlands

Tel. +31 24 352 25 73

www.dspa.nl

Product Declaration

ANSI/CAN/UL/ULC 2775: 2019

Additional listing according to

ANSI/CAN/UL/ULC 2775: 2019

based on product certificate

K86591. Validity of this

declaration is one year.

**Certification process
consists of initial and
regular assessment of:**

- quality system
- product

Technical specification & Approval

The Kiwa Product Certification Scheme K23001/06 "for non-pressurized condensed aerosol generators and components used in fixed fire extinguishing systems" of September 2th, 2020 is based on the following standards:

- EN15276-1 Fixed fire fighting systems – Condensed aerosol extinguishing systems - Part 1: Requirements and test methods for components;
- ISO 15779 Condensed aerosol fire extinguishing systems - Requirements and test methods for components and system design, installation and maintenance - General requirements.

The following Aerosol non-pressurized generators belong to this product declaration.

Type	Housing Red coated steel	Activation
DSPA 8-1	Cylindrical, axial	Electrical
DSPA 8-1-60	Cylindrical, axial	Electrical
DSPA 2-4-1	Cylindrical, axial	Electrical
DSPA 11-1	Disk, radial, double shaped plate	Electrical
DSPA 11-2	Disk, radial, double shaped plate	Electrical
DSPA 11-3	Disk, radial, double shaped plate	Electrical
DSPA 11-4	Disk, radial, double shaped plate	Electrical
DSPA 11-5	Disk, radial, double shaped plate	Electrical
DSPA 11-6	Disk, radial, double shaped plate	Electrical
DSPA 11-7	Disk, axial, double shaped plate	Electrical
DSPA 12-1	Disk, radial, single shaped plate	Electrical or Thermal cord
DSPA 12-2	Disk, radial, single shaped plate	Electrical or Thermal cord
DSPA 12-3	Disk, radial, single shaped plate	Electrical or Thermal cord
DSPA 12-4	Disk, radial, single shaped plate	Electrical or Thermal cord
DSPA 12-5	Disk, radial, single shaped plate	Thermal cord

Type	Housing Aluminum	Activation
DSPA 0.90-2	Cylindrical, axial	Electrical
DSPA 0.45-2	Cylindrical, axial	Electrical

Application and use

It is important that the fire protection of a building or plant be considered as a whole. Condensed aerosol extinguishing systems form only a part, though an important part, of the available facilities, but it should not be assumed that their adoption necessarily removes the need to consider supplementary measures, such as the provision of portable fire extinguishers or other mobile appliances for first aid or emergency use, or to deal with special hazards.

Condensed aerosol extinguishants are an effective medium for the extinction of flammable liquid fires (Class B according to EN2), and ordinary Class A to EN2 hazards (solid surface burning fires), but it should not be forgotten, in the planning of comprehensive schemes, that there may be hazards for which these mediums are not suitable, or that in certain circumstances or situations there may be dangers in their use requiring special precautions. For Class C to EN2 (fires involving gases) is the extinguishing density also determined.

Advice on these matters can be obtained from the approved supplier of this manufacturer of the extinguishant and / or the extinguishing system according to scheme K23003. Information may also be sought from the appropriate fire authority, the health and safety authorities and insurers. In addition, reference should be made as necessary to other national standards and statutory regulations of the particular country.

It is essential that firefighting equipment be carefully maintained to ensure instant readiness when required. Routine maintenance is liable to be overlooked or given insufficient attention by the owner of the system. It is, however, neglected at peril to the lives of occupants of the premises and at the risk of crippling financial loss. The importance of maintenance cannot be too highly emphasized. Installation and maintenance should only be carried out by qualified personnel according to scheme K23003.

Inspection should include an evaluation that the extinguishing system continues to provide adequate protection for the risk (protected zones as well as state of the art can change over time).

Where aerosol generators are used in a potentially explosive application, the suitability of the generator to the atmosphere for the determined life shall be assessed.

Conditions for application

- The detail engineering and installation of the extinguishing system shall to be determined in conformity with the guidelines and calculation methods of the manufacturer.
- The user of the extinguishing system is instructed by an instructor for this system authorized by the supplier on behalf of the manufacturer.
- The detail engineering, installation and maintenance of the fire extinguishing components have to take place according to the specifications of the manufacturer, ISO15779, EN15276-2 and certification scheme K23003. The minimal density for the extinguishing systems shall be based on a Class A according to EN2 for the compatible wood crib according to ISO15779. For risk associated with deep seated fires shall be based on a Class A wood crib test according to EN15276-1.

Point of interest during use

The condensed aerosol extinguishing components should not be used on fires involving the following unless relevant testing by accredited testing laboratories has been carried out to the satisfaction of the Authority:

- Temperatures for use of aerosol extinguishing agents shall be within the supplier's listed limits.
- Local applications of condensed aerosol extinguishing systems are not covered by this product declaration. Local applications require a pre-engineered and pre-designed system which has been tested and approved for a specific application by an authority such as Kiwa or by an accredited testing laboratory.

Design Installation,& Operating Manual (DIOM)


At delivery the product should be accompanied by an operation manual in the English language, known and authorized by Kiwa. Following minimum items shall be described:

- Type of aerosol generators;
- Design application density in relation to Fire Class according to EN2 with a minimum based on Fire Class A (compatible wood crib);
- Description of occupancies and hazards to be protected against;
- Specification of aerosol generators;
- Equipment schedule or list of materials for each piece of equipment or device, showing device name; supplier, model or part number and description;
- System calculation;
- Enclosure pressurization and venting calculations;
- Description of fire detection, actuation and control systems.
- Requirements for inspection, maintenance and testing of an aerosol fire-extinguishing system and for the training of inspection and maintenance personnel.

For specific details regarding the (DIOM) Design Installation,& Operating Manual, see EN15276-1&2, ISO15779 & NFPA 2010.

Marking

The products should be marked with the Kiwa®-mark.



Place of the mark:

- On the generator

Required specifications:

- Name of the product and supplier
- Supplier's type designation
- Production date and serial number
- Mass of aerosol-forming compound
- Temperature range
- Storage humidity range
- Service life
- Distances as specified in table 5 of this certificate
- Reference to the application instructions
- Certification mark
- Class A according EN2
- Class B according EN2

Method of marking

- Non-erasable and non-detachable;
- Non-flammable;
- Permanent and legible

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- DSPA B.V.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.

Product specifications - Approval

Table 1 – pre burn time – soak time – density of the aerosol

Fire Class	Listing	According	Pre burn time	Soak period	Test room	Density
EN2	Material / fuel	EN 15276-1	in seconds	in seconds	in m ³	in grams / m ³
A	Wood crib	A.6.1	120	600	101.3	116
A	Class A compatible wood crib test	A.6.4	120	600	101.3	79
A	Polymethylmethacrylate	A.6.3	210	600	112.12	97
A	Polypropylene	A.6.3	210	600	112.12	58
A	ABS	A.6.3	210	600	112.12	87
A	Reformed wood (chops)	A.6.4	360	600	112.12	29
A	MDF	A.6.4	360	600	112.12	59
A	Multilayers plywood	A.6.4	360	600	112.12	87
B	Heptane	A.6.2	30	600	112.12	34
C	Propane (30 Kilowatt)	A.6.5	30	600	106.16	31

Table 2 – Efficiency of the generator types

Type	Efficiency in %	Type	Efficiency in %	Type	Efficiency in %
DSPA 11-1	100	DSPA 8-1	100	DSPA 2-4-1	100
DSPA 11-2	88 - 100	DSPA 8-1-60	100	DSPA 0.90-2	100
DSPA 11-3	90 - 100	DSPA 12-1	100	DSPA 0.45-2	98 - 100
DSPA 11-4	100	DSPA 12-2	100		
DSPA 11-5	94 - 100	DSPA 12-3	96 - 100		
DSPA 11-6	100	DSPA 12-4	100		
DSPA 11-7	100	DSPA 12-5	90 - 100		

Table 3 – Agent distribution of the generators

Type	Housing, type and discharge method	Agent distribution according EN 15276-1			
		Minimum height in m	Maximum area coverage in m	Maximum height in m	Maximum area coverage in m
DSPA 0.90-2	Cylinder, axial	0.50	2.00 x 2.00	2.00	0.50 x 2.00
DSPA 0.45-2	Cylinder, axial	0.50	2.00 x 1.00	1.00	0.50 x 1.00
DSPA 8-1	Cylinder, axial	2.44	9.76 x 3.66	4.88	4.88 x 3.66
DSPA 8-1 60	Cylinder, axial	2.44	9.76 x 3.66	4.88	4.88 x 3.66
DSPA 2-4-1	Cylinder, axial	2.44	4.00 x 3.66	6.10	2.44 x 2.44
DSPA 11-1	Disk, radial	0.50	3.66 x 1.22	1.83	1.22 x 1.22
DSPA 11-2	Disk, radial	0.50	3.66 x 2.44	2.44	1.22 x 1.22
DSPA 11-3	Disk, radial	0.50	3.66 x 2.44	2.44	1.22 x 1.22
DSPA 11-4	Disk, radial	1.22	3.66 x 3.66	3.05	1.83 x 1.83
DSPA 11-5	Disk, radial	1.22	4.88 x 3.66	3.66	2.44 x 2.44
DSPA 11-6	Disk, radial	1.22	7.32 x 3.66	3.66	2.44 x 2.44
DSPA 11-7	Disk, axial	1.22	7.32 x 1.22	3.05	1.83 x 1.83
DSPA 12-1	Disk, radial,	0.50	0.81 x 0.73		
DSPA 12-2	Disk, radial,	0.50	0.81 x 1.60	0.80	0.81 x 0.74
DSPA 12-3	Disk, radial,	0.80	0.81 x 1.49	1.99	0.81 x 0.86
DSPA 12-4	Disk, radial,	1.60	0.81 x 1.99	1.99	0.81 x 1.60
DSPA 12-5	Disk, radial,			0.53	0.25 x 0.59

Table 4 – Discharge time of the generators

Type	Discharge time In seconds	Type	Discharge time In seconds	Type	Discharge time In seconds
DSPA 11-1	6 - 10	DSPA 8-1	67 - 89	DSPA 2-4-1	48 - 53
DSPA 11-2	9 - 15	DSPA 8-1-60	48 - 58	DSPA 0.90-2	53 – 57
DSPA 11-3	14 - 26	DSPA 12-1	9 - 11	DSPA 0.45-2	27 – 28
DSPA 11-4	19 - 31	DSPA 12-2	13 - 15		
DSPA 11-5	40 - 60	DSPA 12-3	9 - 11		
DSPA 11-6	30 - 50	DSPA 12-4	11 - 14		
DSPA 11-7	30 - 50	DSPA 12-5	5 - 7		

Table 5 – radiated heat of the generators

Type	Distance in m		
	75°C	200°C	400°C
DSPA 0.90-2	0.15	n/a	n/a
DSPA 0.45-2	0.15	n/a	n/a
DSPA 8-1	1.5	0.75	0.15
DSPA 8-1-60	3.0	1.0	0.10
DSPA 2-4-1	3.15	0.60	n/a
DSPA 11-1	0.5	0.15	0.05
DSPA 11-2	0.5	0.15	0.05
DSPA 11-3	0.5	0.15	0.05
DSPA 11-4	1.0	0.25	0.15
DSPA 11-5	1.0	0.25	0.15
DSPA 11-6	1.5	0.35	0.15
DSPA 11-7	1.5	0.50	0.10
DSPA 12-1	0.08	0.03	0.01
DSPA 12-2	0.15	0.08	0.02
DSPA 12-3	0.25	0.10	0.03
DSPA 12-4	0.30	0.15	0.05
DSPA 12-5	0.08	0.03	0.01

Table 6

Listing		According EN 15276-1	Leakage to volume ratio	Hold Time	Test room	Density
EN2	Test		in %	in minutes	in m ³	in grams / m ³
B	Hold Time	A.7	0.10	10	101.3	78
B	Hold Time (optional)	A.7.1.5	0.10	30	101.3	78

Cross reference EN 15276-1, Fixed fire fighting systems - Condensed aerosol extinguishing systems - Part 1: Requirements and test methods for components - 2019

Chapter	Description	Demand ¹⁾	Result	Remarks and reference to relevant chapter, table(s) and tests (if available)
1.	Scope			
2.	Normative references			
3	Terms and definitions			
4	Component requirements			
4.1	Condensed aerosol generator	A	Pass	Drawings and product material specifications
4.2	Solid aerosol forming compound	A	Pass	Product material specifications – formula
4.3	Cooling mechanism	A	Pass	Drawings and product material specifications and function testing. See 5.11.
4.4.1	Ignition device	A	Pass	Drawings and product material specifications and function testing. See 5.12.
4.4.2	Electrical ignition device	A	Pass	
4.4.3	Thermal ignition device	A	Pass	Types 12: Thermal cord only tested for function
4.4.4	Other methods of ignition device	N/A		
4.5	End plate and housing	A	Pass	Drawings and product material specifications
4.6	Extinguishants	A	Pass	Product material specifications – formula
5.	Condensed aerosol generator requirements			
5.1	General Drawings; part lists; descriptions of function and operated instructions.	A	Pass	See 5.16 and 7.3 See table 2 See table 5
5.2	Extinguishing density Annex A	A	Pass	See 7.4 See table 1
5.3	Agent distribution	A	Pass	See 7.5 See table 3
5.4	Discharge time	A	Pass	See 7.14 See table 4
5.5	Ambient temperature and humidity operation ranges	A	Pass	See 7.6
5.6	Service life and service conditions	A	Pass	See 7.6 and 7.7
5.7	Shelf life and storage conditions	A	Pass	Manual
5.8	Corrosion	A	Pass	See 7.8 and 7.9
5.9	Vibration	A	Pass	See 7.10
5.10	Mechanical shock	A	Pass	See 7.11 and 7.14
5.11	Discharge temperature			
5.11.2	Casing temperature	A	Pass	See 7.14
5.11.3	Aerosol flow temperature	A	Pass	See 7.14

Chapter	Description	Demand ¹⁾	Result	Remarks and reference to relevant chapter, table(s) and tests (if available)
				See table 5
5.12	Activation device			
5.12.2	Electrical ignition device	A	Pass	See 7.13
5.12.3	Thermal ignition device	A	Pass	See 7.14; Implemented Types 12: Thermal cord only tested for function; see 7.14 Rated temperature 182°C
5.13	Function reliability	A	Pass	See 7.14
5.14	Open fire conditions	A	Pass	See 7.15
5.15	Accessories – mounting brackets	A	Pass	See 7.8, 7.10 and 7.13.
5.16	Documentation; General description; Technical specification; Installation instructions; Operation instructions; Maintenance instructions; Safety Data Sheet	A	Pass	
6	Marking	A	Pass	K23001
7.	Test methods			
7.1	Conditions	A	Pass	
7.2	Samples	A	Pass	
7.3	Compliance	A	Pass	
7.4	Extinguishing density determination Annex A	A	Pass	See A6
7.5	Coverage determination Annex A	A	Pass	See A5 See table 3
7.6	Temperature and humidity operation range tests EN60068-2-30: 2005; 25 <> 55 °C at 95% with 10 cycles. Low temperature at -20 °C at 16 hours	A	Pass	Temperature limitations from -40 °C to +75°C and ambient humidity up to 95 %.
7.7	Accelerated ageing test 15 years; -10 <> 50°C one cycle at 8 hours; 50 cycles. Start and end at -10 °C	A	Pass	116 test days at 90 °C = 15 years based on UL 2775
7.8	Corrosion test	A	Pass	
7.9	Stress corrosion test	A	Pass	Materials used in the construction are not susceptible to ammonia stress corrosion
7.10	Vibration test EN-IEC 60068-2-6: 2008	A	Pass	Acceleration amplitude for components which are designed to be attached to machinery according NEN-EN-IEC 60068-2-6 Type 8-1 and 8-1-60 only at 0,5G Acceleration amplitude for components which are designed to be attached to walls
7.11	Drop test	A	Pass	2 meter
7.12	Aerosol flow test	A	Pass	

Chapter	Description	Demand ¹⁾	Result	Remarks and reference to relevant chapter, table(s) and tests (if available)
7.13	Activation performance test	A	Pass	500 activation devices are tested of the electrical activation device. >20 activation devices are tested of thermal activation device
7.14	Function test			
7.14.1	Discharge time	A	Pass	See table 4
7.14.2	Aerosol flow temperature	A	Pass	See table 5
7.14.4	Casing temperature test	A	Pass	
7.14.5	Efficiency	A	Pass	See table 2
7.15	Fire exposure test	A	Pass	Tested with normal electrical ignition device only
Annex A	(normative) Extinguishing factor/coverage test procedure			
A5	Aerosol generator distribution verification tests			
A5.1	Minimum height/maximum coverage test	A	Pass	The following types were tested: <ul style="list-style-type: none"> All See table 3
A5.2	Maximum height test	A	Pass	The following types were tested: <ul style="list-style-type: none"> All See table 3
A6	Extinguishing factor tests			
A6.1	Wood crib test	A	Pass	See table 1
A6.2	n-Heptane pan test	A	Pass	See table 1
A6.3	Polymeric sheet fire test A6.3.2.2 Polymethyl methacrylate (PMMA); A6.3.2.2 Polypropylene, A6.3.2.2 Acrylonitrile-butadiene-styrene polymer (ABS)	A	Pass	See table 1
A6.4	Class A compatible wood crib test	A	Pass	See table 1
	Composite wood fire test according to K23001 Reformed wood (chops) both sides plastic lined MDF (Medium Density Fibreboards) according to EN 622 and EN 316 not lined Multilayers plywood (kiln spruce or fir) not lined	A	Pass	See table 1
A7	Hold time	A	Pass	See table 6

¹⁾ A = Applicable

N/A = Not Applicable

Not tested

Cross reference

ANSI/CAN/UL/ULC 2775: 2019, Standard for Fixed Condensed Aerosol Extinguishing System units

Chapter	Description	Demand ¹⁾	Result	Remarks
General				
15	Condensed aerosol extinguishing agents	A	Pass	See SNAP listing by US Environmental Protection Agency (EPA)
Performance				
21	Discharge test	A	Pass	See table 4.
22	Temperature measurement test	A	Pass	See table 5.
23	Mounting device test	A	Pass	
24	Rough Usage test	A	Pass	
25	Vibration test EN-IEC 60068-2-6	A	Pass	Type 8-1 and 8-1-60 only at 0,5G Acceleration amplitude for components which are designed to be attached to walls
26	Pyrotechnic reaction containment test	Not Tested		
27	Fire exposure test	A	Pass	
28	High humidity test	A	Pass	
29	Moist hydrogen sulfide air mixture corrosion test	A	Pass	
30	Moist carbon dioxide sulfur dioxide air mixture corrosion test	A	Pass	
31	Salt spray corrosion test	A	Pass	
32	Thirty day elevated temperature test	A	Pass	
33	Temperature cycling test	A	Pass	
48	500 cycle operation test			
48.1	Electrical initiators	A	Pass	Aging test 116 days at 90 °C = 15 years and Temperature range -40°C and +75°C
48.2	Other devices	N/A		
49	Class A and B fire extinguishment tests			
49.2	Class A fire extinguishment tests	A	Pass	Table 1; ANSI/CAN/UL/ULC 2775
49.3	Class B fire extinguishment tests	A	Pass	Table 1; ANSI/CAN/UL/ULC 2775
50	Distribution verification extinguishment tests with extinguishing system units			
50.3	Maximum area coverage and minimum height test arrangement procedure	A	Pass	See table 3.
50.4	Maximum height test procedure	A	Pass	See table 3.
54	Stress corrosion cracking test for brass parts	A	Pass	Materials used in the construction are not susceptible to ammonia stress corrosion.
55	Aging test condensed aerosol generator	A	Pass	116 days at 90 °C = 15 years
Manufacturing and production tests				
61.1	Manufacturing and production tests	A	Pass	
61.2	Aerosol-forming compound	A	Pass	
61.3	Electrical initiators	A	Pass	
Markings				
62	General	A	Pass	K23001
Instructions				
64	Owner's manual	A	Pass	See DSPA Manual
65	Design, installation, operating and maintenance instruction manual	A	Pass	See DSPA DIOM

¹⁾ A = Applicable N/A = Not Applicable Not tested

Table 1 - ANSI/CAN/UL/ULC 2775

Fire Class NFPA	Listing	According ANSI/CAN/UL/ULC 2775	Pre burn time	Soak period	Test room	Density
	Material / fuel		in seconds	in seconds	in m ³	in grams per m ³
A	Class A compatible wood crib test	49.2.2	120	600	101.3	79
A & C	Polymethylmethacrylate	49.2.3	210	600	112.12	97
A & C	Polypropylene	49.2.3	210	600	112.12	58
A & C	ABS	49.2.3	210	600	112.12	87
B	Heptane	49.3	30	600	112.12	34