

ANNUAL TESTS AS PER THE URA

Parameter	Reference Range	Parameter	Reference Range	Parameter	Reference Range
Anionic Detergents	0.002 - 0.275 ppm	Cyanide	<0.07 ppm	Potassium	0 - 50 ppm
Arsenic	<0.01 ppm	Enterococci	0/100ml CFU	Salmonella typhi	0/100ml CFU
Boron	<2.4 ppm	Fluoride	<1.5 ppm	Shigella spp.	0/100ml CFU
Bromine	0.05 - 4.5 ppm	Lead	< 0.01 ppm	Sodium	<200 ppm
Cadmium	<0.003 ppm	Manganese	0.1 ppm	Sulphate	<250 ppm
Calcium Hardness	<60 ppm	Mercury	<0.001 ppm	Total Petroleum Hydrocarbon	0 mg/l
Chromium	<0.05 ppm	Phenolic Compounds	0.002 - 0.2 ppm	Vibrio Cholerae	0/100ml CFU
Copper	<2 ppm	Phosphate	<5 ppm		