


MONTHLY TEST AS PER THE URA

DAILY TEST

Parameter	Reference range
Physical Appearance	Clear & Colorless
pH	6.5 - 8.5
Free Chlorine	0.04 - 0.2 mg/l
Electrical Conductivity	300 - 700 µs/cm
Total Coliform	0/100ml CFU
Fecal Coliform	0/100ml CFU
Turbidity	<1 NTU
Total Dissolved Solids	150 - 350 mg/L



MONTHLY TEST

Parameter	Reference range
Chlorides	<200 mg/l
Nitrates	<50 mg/l
Ammonia	<0.5 mg/l
Iron	<0.3 mg/l
Hydrogen Sulphide	0.05 mg/l
Total Hardness	<75 mg/l
Total Suspended Solids	5-750 mg/L
E.Coli	0/100ml CFU