RFP 26-03 Addendum 1

Additional Information

	Question	Answer
1	Is a bid bond needed?	No
2	Is electronic key management (RFID key control cabinets) within the scope of this project?	No
3	Are smart lockers for weapons, radios, or officer equipment within scope?	No
4	Does the County have the PLC programs, the HMI configuration files and the passwords for that system, and will they be provided to the awarded contractor? If the original installer holds any of them, how does the County expect other respondents to plan the integration?	Yes. The County has the files and passwords, which will be made available to the awarded contractor.
5	The cost proposal lists bonds and insurance but the RFP does not state the bond amount. What percentage will the performance and payment bonds need to be, and would the County like the bond cost shown as a separate line in the cost proposal?	The performance and payment bonds need to each be 10% and should be shown as a separate line item.
6	What is the funding source for this project, and is there a date by which the funds must be committed or spent? If any portion is federal funding, do federal procurement requirements, federal bonding requirements or Build America, Buy America apply to this award?	The project is funded through County Capital Carryover funds. There is no deadline to obligate or expend the funds, and no federal funding is involved.
7	Will the County's contract form be available for review before the proposal deadline, and will it include a non-appropriation clause for any obligation that extends beyond one fiscal year?	The contract will not be available before the proposal deadline. It will be provided to the selected contractor for review before execution. Contract terms will be determined during negotiations. The inclusion of a non-appropriation clause will be determined during contract negotiations.
8	In addition to proposals responsive to the scope as written, would the County accept and consider a proposal structured as a multi-year service agreement, under which the existing control systems are placed under contract and replaced in phases, with the contractor responsible for system performance throughout the term? If so, would such a proposal be evaluated under the published scoring criteria or considered separately?	No, the County will not accept or consider a multi-year service agreement.
9	Is there a required or target completion date for the project?	The County's target completion date is September 2027.
10	The RFP bundles the electrical and physical installation together with the control system, cameras, software, programming and commissioning as one turnkey project. Would the County consider awarding the work as two contracts — a public works contract for the electrical and installation work, and a separate systems agreement for the equipment, software, programming, integration, commissioning and ongoing support? We ask because it may work in the County's favor in a few ways. The performance and payment bonds would cover the construction work only, so the County isn't paying bond cost on equipment and software that don't need it. The equipment and software could be purchased and paid for on the County's funding schedule rather than waiting on the construction schedule. Support, software maintenance and licensing could be extended down the road without re-bidding the construction. And the company that designs and programs the system would be the one responsible for it after acceptance — which, in our experience, is where these projects succeed or struggle. It would be the County's option either way. If the County is open to it, may respondents present the cost proposal both ways, with a combined total so the proposals still compare directly?	No. The County intends to award the project as a single contract.
11	What is the existing camera system's storage capacity, number of cameras, and recording retention period?	The SHU and Work Release systems have a combined 103 cameras. Each has its own NVR, with the SHU NVR serving as the primary and the Work Release NVR as the secondary. Both systems are configured for 30 days of video retention but are currently retaining approximately 41 days of footage.
12	What is the minimum required video retention period for the 60 cameras included in the project?	The minimum required video retention period for the 60 replacement cameras is 30 days.
13	How many cameras are currently connected to the SHU and Work Release systems?	There are 103 cameras between the SHU and Work Release systems.
14	Where should hard-copy proposals be delivered, and how should they be addressed?	Proposals should be delivered to the Bonneville County Commissioners' Office at 605 N. Capital Avenue, Idaho Falls, ID 83402, referencing RFP No. 26-03. Proposals may be addressed to Austin Black.
15	Can the County provide drawings identifying the locations of intercoms, push buttons, and cameras?	Additional drawings and photographs, including the upper level, are available in the County's shared project folder. The County considers these materials sufficient for proposal preparation.

16	Does the County have administrative access and credentials for the existing CML control system, Valerus/Vicon camera systems, Harding system, and Schneider PLCs?	Yes. The County confirmed that it has access to all existing systems.
17	Is registration as an interested party required to submit a responsive proposal, or is registration only required to receive addenda and project communications?	No, registration as an interested party is not required to submit a proposal.
18	What specific approval process, background screening, NDA requirements, or credentialing is required to obtain access to facility photos, plans, and security drawings?	The County has an access request form and PREA form that would need to be filled out and approved prior to anyone gaining access. The access request will be approved based on the result of a criminal history background run through NCIC and the PREA question responses.
19	Does the county participate in NASPO cooperative procurement vehicle?	No.
20	I see (3) control stations listed however, are any of these limited/ restricted on what they should control?	The three control stations (Booking, Master, and Housing) will be replaced. Each must be capable of assuming control of the other stations, as well as the SHU and Work Release panels.
21	Are respondents permitted to propose additional functionality, including utility integration, automated camera call-up, system automation, and other detention control enhancements beyond the minimum scope?	Automated camera call-up is required as part of the proposed system. Respondents may propose additional enhancements beyond the RFP requirements. Any optional enhancements should be clearly identified in the Technical Proposal, with associated costs listed separately in the Cost Proposal.
22	What types cameras are there currently? Would you like the 60 new Cameras to be the same brand for licensing/VMS/SMA purposes?	The existing cameras in the original jail are analog. The 60 replacement cameras must be digital and compatible with the County's existing Valerus video management system. The existing SHU and Work Release cameras are Vicon.
23	If respondents utilize a local Idaho contractor for installation labor while maintaining responsibility for design, fabrication, programming, commissioning, and integration, are there any additional County licensing or authorization requirements?	No, there are not additional licensing or authorization requirements.
24	Could you please clarify whether the existing system currently controls or monitors any of the following: Automated camera call-up and video pop-up functions Cell or housing unit lighting controls Television controls Plumbing controls (flush valves, water controls, etc.) Other utility or building management functions	The existing panel controls water, lighting, and power. The SHU and Work Release panels also provide these functions. No other functions are currently controlled or monitored.
25	If these functions are currently part of the facility's operational environment, should respondents include integration or migration of those systems as part of the proposed solution?	Yes, include integration or migration of those systems as part of the proposed solution.
26	The control panels in Main Jail Master Control and the panel termination documents provided on 11/2 include controls for an upper level — Housing Unit A upper (cells 1–8), Housing Unit B upper (cells 1–8), Women upper (cells 1–5), and the upper interconnecting doors — with door status, door release and intercom call points for each. The door control, camera and speaker layouts provided mark first-floor devices only. Can you please provide the upper-level device locations (controlled doors, intercoms, cameras and speakers)? Or confirm whether the upper level is within the scope of this project.	Yes. The upper level is included in the project scope. Device locations are identified in the drawings and photographs available in the County's shared project folder.