



UN APPROVED IBC INSPECTION CERTIFICATE

Test carried out at: United Power Access, Attain, Queensway, Croydon CR0 4RR

Product Details: 900 FC

Approval No:	31AZ0117GBFP5952-2441/1224
Manufacturer:	Fuel Proof
Serial No:	22151/8
Year of Manufacture:	01/17
Nominal Capacity:	900 Litre
Date of Initial Test:	January 2027
Date of Latest Periodic Test:	July 2025
Certificate expiry date:	January 2028

Comments

Pressure test on inner cylinder ok:	YES
Visually examine the bowser internally and externally, in good condition:	YES
Visually examine interconnecting pipework and fittings, in good condition:	YES
Visually examine pumping gear, in good condition:	YES
Visually examine mounting bolts, in good condition:	YES

Inspector:

Signature:

Neil Wilson.

A handwritten signature in black ink, appearing to read "Neil Wilson", written over a horizontal line.

Fuel Proof Limited

Date: August 5 2025

Fuel Proof Ltd

Registered office: Middleton Business Park, Middleton Road, Heysham, Lancashire, LA3 3FH
Company registration number 3991145

BT/0900-02