

UN APPROVED IBC INSPECTION CERTIFICATE

Test carried out at: United Power Access, CA Group, Winvic Construction, Hudhurst Lane Crawley RH10 9HU

Product Details: 2000 Fuelstore

Approval No:	31AZ0117GBFP/4907/02560	
Manufacturer:	Fuel Proof	
Serial No:	22151/1	
Year of Manufacture:	01/17	
Nominal Capacity:	2000 Litre	
Date of Initial Test:	January 2017	
Date of Latest Periodic Test:	July 2025	
Certificate expiry date:	January 2028	

Comments

Pressure test on inner cylinder ok:	
Visually examine the bowser internally and externally, in good condition:	
Visually examine interconnecting pipework and fittings, in good condition:	
Visually examine pumping gear, in good condition:	
Visually examine mounting bolts, in good condition:	

Inspector:

Signature:

Neil Wilson.

Fuel Proof Limited

Date: August 5. 2025