

## UN APPROVED IBC INSPECTION CERTIFICATE

Test carried out at: United Power Access, TJ Morris Distribution Centre, Doncaster

**DN8 5GS Product Details: 2000ltr Bowser** 

Approval No:	31AZ0117GBFP5952-2441/1224	
Manufacturer:	Fuel Proof	
Serial No:	BT/2000/01A	
Year of Manufacture:	2018	
Nominal Capacity:	2000 Litre	
Date of Initial Test:	2018	
Date of Latest Periodic Test:	October 2025	
Certificate expiry date:	April 2028	

## **Comments**

Pressure test on inner cylinder ok:	
Visually examine the bowser internally and externally, in good condition:	
Visually examine interconnecting pipework and fittings, in good condition:	
Visually examine pumping gear, in good condition:	
Visually examine mounting bolts, in good condition:	

Inspector:

Signature:

Neil Wilson

**Fuel Proof Limited** 

Date: October 10 2025