



## **UN APPROVED IBC INSPECTION** **CERTIFICATE**

Test carried out at: DA2 6QB

### **Product Details: 2000L Fuel Store**

|                               |                                |
|-------------------------------|--------------------------------|
| Approval No:                  | 31A/Z/GB/FUELPROOF-4912/0/3037 |
| Manufacturer:                 | Fuel Proof                     |
| Serial No:                    | 22151/4                        |
| Year of Manufacture:          | 2017                           |
| Nominal Capacity:             | 2000L Fuel Store               |
| Date of Initial Test:         | 2017                           |
| Date of Latest Periodic Test: | October 2026                   |
| Certificate expiry date:      | April 2029                     |

### **Comments**

|                                                                            |     |
|----------------------------------------------------------------------------|-----|
| Pressure test on inner cylinder ok:                                        | YES |
| Visually examine the bowser internally and externally, in good condition:  | YES |
| Visually examine interconnecting pipework and fittings, in good condition: | YES |
| Visually examine pumping gear, in good condition:                          | YES |
| Visually examine mounting bolts, in good condition:                        | YES |

**Inspector:**

Kieran Stewart

**Signature:**

A handwritten signature in black ink, appearing to be "K Stewart", written over a horizontal line.

**Fuel Proof Limited**

**Date:** 07.10.2026

**Fuel Proof Ltd**

Registered office: Middleton Business Park, Middleton Road, Heysham, Lancashire, LA3 3FH  
Company registration number 3991145



## SERVICE CERTIFICATE

Middleton Business Park, Middleton Road  
Heysham, Lancashire LA3 3FH  
Tel: 01524 850685 Fax: 01524 859681  
e-mail: info@fuelproof.co.uk Web: www.fuelproof.co.uk

### Certificate details:

Certificate number: 11646

Issue number: 1

Date issued: October, 2026

Issued to: United Power Access

### Product details:

Serial number: 22151/4

Model: 2000L Fuel Store

Capacity: 2000L

Year of Manufacture: 2017

### Service details:

#### Summary of work carried out:

- Examined all interconnecting pipe work and fittings for leaks, kinks and general damage.
- Checked all hoses.
- Checked operation of fuel delivery pump.
- Checked accuracy of flow meter.
- Replaced fuel filter element.
- Checked filtration on nozzle.
- Examined Inner Tank where possible (Optimum level is 25% or less).
- Cleaned pump and dispensing cabinet.

Next service due on: October 2027

We hereby certify that the above-mentioned equipment has been given a thorough inspection and has met all the necessary servicing criteria.

Name: Kieran Stewart (Service Engineer) Signed:

A handwritten signature in black ink, appearing to be "K Stewart", written over a horizontal line.