

ELECTRICAL CERTIFICATE OF COMPLIANCE & ELECTRICAL SAFETY CERTIFICATE

REFERENCE/CERTIFICATE ID NO.: 1212

This form has been designed to be used by licensed electrical workers to certify that installations or Part installations under **Part 1** or **Part 2** of AS/NZS 3000 are safe to be connected to the **specified** system of electrical supply.

Location Details:

169 North Road Dunedin

Contact Details:
(Name and address)

Sortehaug Residential No 2 Limited PO Box 7111 Mornington Dunedin 9040

Name of Electrical worker:

Doug Pryor

Registration/Practising licence number:

E250871

Phone & email:

doug@dmpe.co.nz 0210317536

Name and registration number of person(s) supervised:

Certificate of Compliance

Type of work:

☒ Addition

☒ Alteration

☐ New work

The prescribed electrical work is:

☐ Low risk

☒ General

☐ High-risk (Specify):

Means of compliance:

☐ Part 1 of AS/NZS 3000

☒ Part 2 of AS/NZS 3000

Additional Standards or electrical code of practice were required:

☐ No

☒ Yes (specify): AS/NZS3017

Date or range of dates that prescribed electrical work undertaken:

11/5/20 to 20/5/20

Contains fittings that are safe to connect to a power supply?

☒

Yes

☐

No

Specify type of supply system:

230V 1P MEN

The installation has an earthing system that is correctly rated (where applicable)

☒

Yes

☐

No

Parts of the installation to which this certificate relates that are safe to connect to a power supply?

☐ All ☒ Parts (specify)

All FSCs, Heatpumps, power and light. Kitchen appliances, bathroom appliances.

The work relies on manufacturers instructions:

☐

Yes

☒

No

If yes – identify the instruction manual including name, date and version. Also attach a copy of manufacturer's instructions to this certificate.
(Or provide reference to readily accessible electronic format, eg Internet link.)

Identify:

Link:

The work has been done in accordance with a certified design:

☐

Yes

☒

No

If yes – identify the certified design including name, date and version. Also attach a copy of the certified design to this certificate.
(Or provide reference to readily accessible electronic format, eg Internet link.)

Identify:

Link:

The work relies on a Supplier Declaration of Conformity (SDoC):

☐

Yes

☒

No

If yes - identify the SDoC including name, date and version OR EESS registration. Also attach a copy of the SDoC to this certificate.
(Or provide reference to readily accessible electronic format, eg Internet link.)

Identify:

Link:

The installation has been satisfactorily tested in accordance with the Electricity (Safety) Regulations 2010

☐ No

☒ Yes

Description of Work:

Fit off all power and light, kitchen appliances, bathroom appliances, 6 heatpumps. Carry out all testing as required.

Test Results (provide values)

Polarity (Independent earth):	OK
Insulation resistance:	>50M Ohms
Earth Continuity:	ok Ohms
Bonding:	Ohms
Fault Loop impedance	Ohms
Other (specify):	

By signing this document I certify that the completed prescribed electrical work to which this Certificate of Compliance applies has been done lawfully and safely, and the information in the certificate is correct.

Certifier's signature: Doug Pryor

Digitally signed by Doug Pryor
Date: 2020.05.26 22:27:32 +12'00'

Date: 26/5/20

Electrical Safety Certificate

By signing this document I certify that the installation, or part of the installation, to which this Electrical Safety Certificate applies is connected to a power supply and is safe to use.

Certifier's name:

Doug Pryor

Registration/Practising licence number:

E250871

Certifier's signature:

Doug Pryor
Digitally signed by Doug Pryor
Date: 2020.05.26 22:27:47 +12'00'

Certificate Issue Date:


26/5/20

Connection Date:

20/5/20

CUSTOMER COPY – THIS IS AN IMPORTANT DOCUMENT AND SHOULD BE RETAINED FOR A MINIMUM OF 7 YEARS

This Electrical Safety Certificate also confirms that the electrical work complies with the building code for the purposes of Section 19(1)(e) of the Building Act 2004.



ELECTRICAL CERTIFICATE OF COMPLIANCE & ELECTRICAL SAFETY CERTIFICATE

REFERENCE/CERTIFICATE ID No.: 1209

This form has been designed to be used by licensed electrical workers to certify that installations or Part installations under **Part 1** or **Part 2** of AS/NZS 3000 are safe to be connected to the **specified** system of electrical supply.

Location Details:

169 North Road Dunedin

Contact Details:
(Name and address)

Sortehaug Residential No 2 Limited PO Box 7111 Mornington Dunedin 9040

Name of Electrical worker:

Doug Pryor

Registration/Practising licence number:

E250871

Phone & email:

doug@dmpe.co.nz 0210317536

Name and registration number of person(s) supervised:

Certificate of Compliance

Type of work:

☐

Addition

☒

Alteration

☐

New work

The prescribed electrical work is:

☐

Low risk

☒

General

☒

High-risk (Specify):

New main switchboard to existing mains and existing main earth.

Means of compliance:

☐

Part 1 of AS/NZS 3000

☒

Part 2 of AS/NZS 3000

Additional Standards or electrical code of practice were required:

☐

No

☒

Yes (specify): AS/NZS3017

Date or range of dates that prescribed electrical work undertaken:

18/2/2020

Contains fittings that are safe to connect to a power supply?

☒

Yes

☐

No

Specify type of supply system:

230V 1P MEN

The installation has an earthing system that is correctly rated (where applicable)

☒

Yes

☐

No

Parts of the installation to which this certificate relates that are safe to connect to a power supply?

☐ All ☒ Parts (specify) Main switchboard. 1 Power point in main house. Light and power in sleepout.

The work relies on manufacturers instructions:

☐

Yes

☒

No

If yes – identify the instruction manual including name, date and version. Also attach a copy of manufacturer's instructions to this certificate.
(Or provide reference to readily accessible electronic format, eg Internet link.)

Identify:

Link:

The work has been done in accordance with a certified design:

☐

Yes

☒

No

If yes – identify the certified design including name, date and version. Also attach a copy of the certified design to this certificate.
(Or provide reference to readily accessible electronic format, eg Internet link.)

Identify:

Link:

The work relies on a Supplier Declaration of Conformity (SDoC):

☐

Yes

☒

No

If yes - identify the SDoC including name, date and version OR EESS registration. Also attach a copy of the SDoC to this certificate.
(Or provide reference to readily accessible electronic format, eg Internet link.)

Identify:

Link:

The installation has been satisfactorily tested in accordance with the Electricity (Safety) Regulations 2010

☐

No

☒

Yes

Description of Work:

Replacement of main switchboard, connection to existing mains and main earth. New RCDs and MCBs for final subcircuits. Wiring of sleepout building light and power. One power point in main house. Carry out all testing as required.

Test Results (provide values)

Polarity (Independent earth):	ok
Insulation resistance:	152M Ohms
Earth Continuity:	MEC0.04 Ohms
Bonding:	n/a Ohms
Fault Loop impedance	0.06 Ohms
Other (specify):	PFC 4.0kA 237V

By signing this document I certify that the completed prescribed electrical work to which this Certificate of Compliance applies has been done lawfully and safely, and the information in the certificate is correct.

Certifier's signature: Doug Pryor

Digitally signed by Doug Pryor
DN: cn=Doug Pryor, o=DMPC Consulting Ltd, ou, email=doug@dmpe.co.nz, c=NZ
Date: 2018.06.01 11:28:33 +1200

Date: 18/2/2020

Electrical Safety Certificate

By signing this document I certify that the installation, or part of the installation, to which this Electrical Safety Certificate applies is connected to a power supply and is safe to use.

Certifier's name:

Doug Pryor

Registration/Practising licence number:

E250871

Certifier's signature:

Doug Pryor

Digitally signed by Doug Pryor
DN: cn=Doug Pryor, o=DMPC Consulting Ltd, ou, email=doug@dmpe.co.nz, c=NZ
Date: 2018.06.01 11:28:33 +1200

Certificate Issue Date:

19/2/2020

Connection Date:

18/2/2020

CUSTOMER COPY – THIS IS AN IMPORTANT DOCUMENT AND SHOULD BE RETAINED FOR A MINIMUM OF 7 YEARS

This Electrical Safety Certificate also confirms that the electrical work complies with the building code for the purposes of Section 19(1)(e) of the Building Act 2004.



ELECTRICAL SAFETY CERTIFICATE

REFERENCE/CERTIFICATE ID NO.: 1349

This Electrical Safety Certificate provides a legally recognisable statement that the connected installation or part installation, or any fitting that supplies an installation or a part of an installation, is safe to use following prescribed electrical work.

Location Details:

169 North Rd, Dunedin

Contact Details:

(Name and address)

Sortehaug Residential Ltd, PO Box 7111, Mornington, Dunedin

Details of work:

☐

The whole installation

☒

Part of the installation

Description of work:

Replacement of two Serene 2068 bathroom wall heaters.
Carry out testing as required.

Date of connection:

19/6/2024

By signing this document I certify that the installation, or part of the installation, to which the Electrical Safety Certificate applies is connected to a power supply and is safe to use.

Certifier's name:

Doug Pryor

Registration/Practising
licence number:

E250871

Certifier's
signature:

Doug
Pryor

Digitally
signed by
Doug Pryor

Certificate Issue Date:

22/06/2024

Email:

doug@dmpe.co.nz

Organisation/
Company:

DMP Consulting Ltd

**CUSTOMER COPY – THIS IS AN IMPORTANT DOCUMENT AND
SHOULD BE RETAINED FOR A MINIMUM OF 7 YEARS**

This electrical safety certificate also confirms that the electrical work complies with the building code for the purposes of Section 19(1)(e) of the Building Act 2004.