



ELECTRICAL CERTIFICATE OF COMPLIANCE & ELECTRICAL SAFETY CERTIFICATE

REFERENCE/CERTIFICATE ID No.: 1235

This form has been designed to be used by licensed electrical workers to certify that installations or Part installations under **Part 1** or **Part 2** of AS/NZS 3000 are safe to be connected to the **specified** system of electrical supply.

Location Details:

31 Royston Street Dunedin

Contact Details:
(Name and address)

Sortehaug Residential Limited P O Box 7111 Mornington 9040

Name of Electrical worker:

Doug Pryor

Registration/Practising licence number:

E250871

Phone & email:

doug@dmpe.co.nz 0210317536

Name and registration number of person(s) supervised:

Certificate of Compliance

Type of work:

☐

Addition

☒

Alteration

☐

New work

The prescribed electrical work is:

☒

Low risk

☒

General

☐

High-risk (Specify):

Mains work. Relocate mains, new MSB and MEN link.

Means of compliance:

☐

Part 1 of AS/NZS 3000

☒

Part 2 of AS/NZS 3000

Additional Standards or electrical code of practice were required:

☐

No

☒

Yes (specify): AS/NZS3017

Date or range of dates that prescribed electrical work undertaken:

Contains fittings that are safe to connect to a power supply?

☒

Yes

☐

No

Specify type of supply system: 230V 1P MEN

The installation has an earthing system that is correctly rated (where applicable)

☒

Yes

☐

No

Parts of the installation to which this certificate relates that are safe to connect to a power supply?

☐☒

All Parts (specify)

Main switchboard, one FSC to hallway power points.

The work relies on manufacturers instructions:

☐

Yes

☒

No

If yes – identify the instruction manual including name, date and version. Also attach a copy of manufacturer's instructions to this certificate.
(Or provide reference to readily accessible electronic format, eg Internet link.)

Identify:

Link:

The work has been done in accordance with a certified design:

☐

Yes

☒

No

If yes – identify the certified design including name, date and version. Also attach a copy of the certified design to this certificate.
(Or provide reference to readily accessible electronic format, eg Internet link.)

Identify:

Link:

The work relies on a Supplier Declaration of Conformity (SDoC):

☐

Yes

☒

No

If yes - identify the SDoC including name, date and version OR EESS registration. Also attach a copy of the SDoC to this certificate.
(Or provide reference to readily accessible electronic format, eg Internet link.)

Identify:

Link:

The installation has been satisfactorily tested in accordance with the Electricity (Safety) Regulations 2010

☐

No

☒

Yes

Description of Work:

Relocate consumer mains from old exterior meter box, to new combined MSB with metering. Install new main switch, neutral connection and MEN link. Connection of existing main earth conductor. Install one RCD and one FSC to 4 power points in hallway. Carry out testing as required.

Test Results (provide values)

Polarity (Independent earth):	ok
Insulation resistance:	71M Ohms
Earth Continuity:	Ohms
Bonding:	n/a Ohms
Fault Loop impedance	LN 0.5 Ohms
Other (specify):	PFC 478A 239V

By signing this document I certify that the completed prescribed electrical work to which this Certificate of Compliance applies has been done lawfully and safely, and the information in the certificate is correct.

Certifier's signature: Doug Pryor

Digitally signed by Doug Pryor
Date: 2020.05.26 22:27:32 +12'00'

Date: 30/10/20

Electrical Safety Certificate

By signing this document I certify that the installation, or part of the installation, to which this Electrical Safety Certificate applies is connected to a power supply and is safe to use.

Certifier's name:

Doug Pryor

Registration/Practising licence number:

E250871

Certifier's signature:

Doug Pryor

Digitally signed by Doug Pryor
Date: 2020.05.26 22:27:47 +12'00'

Certificate Issue Date:

5/11/20

Connection Date:

30/10/20

CUSTOMER COPY – THIS IS AN IMPORTANT DOCUMENT AND SHOULD BE RETAINED FOR A MINIMUM OF 7 YEARS

This Electrical Safety Certificate also confirms that the electrical work complies with the building code for the purposes of Section 19(1)(e) of the Building Act 2004.



RECORD OF INSPECTION (ROI) OF HIGH-RISK PRESCRIBED ELECTRICAL WORK PURSUANT TO THE ELECTRICITY (SAFETY) REGULATIONS 2010

Reference/Record ID Number:

301020/5

Issuer (Inspector) details:

Name of Inspector: Allan Perry

Registration #: I 1919

Email address: allan@iei.co.nz

Telephone: 0204 771 262

Address description:

Business Description:

Energy Type: Grid / Indpt

Worktype: New / Addition / Alteration / Extension / Replacement / Repair following Accident

Location of installation:

Location details:

31 Royston St Dunedin

Location type:

☒ Domestic

☐ Non-Domestic Accommodation

☐ Industrial

☐ Commercial

☐ Educational

☐ Healthcare

☐ Miscellaneous (other)

Certifying Electrical Work and Certificate of Compliance (CoC) details:

Name of Electrical worker(s):

Doug Rogers

Registration #:

EW 048569

E250871

CoC details:

1235

☐ CoC(s) attached
☒ CoC(s) Electronic

Certifying Electrical Work and ROI details:

What was inspected:

Test - inspect relocated mains - new switchboard to main switch neutral & Earth Bars

Specify the regulation(s) and companion standard(s) or identify the certified design, followed when carrying out the inspection:

AS/NZS 3000-2007 ☒ AS/NZS 3017-2007 ☒ PV-AS/NZS 5033-2014 ☐ Inver AS/NZS 4777.1-2016 ☐

AS/NZS 60079.14-2017 ☐ Other

☐ AS/NZS3003-2011

What are the results of the inspection:

Insulation Res 71mΩ. Polarity ~~OK~~ OK. Voltage 239V

Ln 0.5Ω Pfc 478A. LE. 63.8m

High Risk Category:

☐ Not to AS/NZS 3000 Part 2 - 6A(2)(a)(i)

☐ Photovoltaic system - 6A(2)(a)(iv)

☐ Electrical medical area - 6A(2)(a)(vi)

☐ High voltage installation - 6A(2)(a)(ii)

☐ Hazardous area - 6A(2)(a)(v)

☒ Mains work - 6A(2)(b)

☐ Mains parallel generation - 6A(2)(a)(iii)

☐ Animal stunning or meat conditioning - 6A(2)(c)

☐ Other - please describe:

Declaration

I hereby confirm that the work described above has been done in / ~~not in~~ accordance with the regulations; and the ~~installation~~ / part installation on on which the work has been done is, and will be / ~~not be~~, when energised, electrically safe.


(Note: Strike out or delete the inapplicable words highlighted in red above.)

Signature:

[Signature]

Date:

30/10/20



ELECTRICAL CERTIFICATE OF COMPLIANCE & ELECTRICAL SAFETY CERTIFICATE

REFERENCE/CERTIFICATE ID No.: 1263

This form has been designed to be used by licensed electrical workers to certify that installations or Part installations under **Part 1 or Part 2 of AS/NZS 3000** are safe to be connected to the **specified** system of electrical supply.

Location Details:

31 Royston Street Dunedin

Contact Details:
(Name and address)

Sortehaug Residential .PO Box 7111 Mornington Dunedin 9040

Name of Electrical worker:

Doug Pryor

Registration/Practising licence number:

E250871

Phone & email:

doug@dmpe.co.nz 0210317536

Name and registration number of person(s) supervised:

Certificate of Compliance

Type of work:



Addition



Alteration



New work

The prescribed electrical work is:



Low risk



General



High-risk (Specify):

Means of compliance:



Part 1 of AS/NZS 3000



Part 2 of AS/NZS 3000

Additional Standards or electrical code of practice were required:



No



Yes (specify): AS/NZS3017

Date or range of dates that prescribed electrical work undertaken:

1-11-2020 to 9-6-2021

Contains fittings that are safe to connect to a power supply?



Yes



No

Specify type of supply system:

230V 1P MEN

The installation has an earthing system that is correctly rated (where applicable)



Yes



No

Parts of the installation to which this certificate relates that are safe to connect to a power supply?



All



Parts (specify)

The work relies on manufacturers instructions:



Yes



No

If yes – identify the instruction manual including name, date and version. Also attach a copy of manufacturer's instructions to this certificate.
(Or provide reference to readily accessible electronic format, eg Internet link.)

Identify:

Link:

The work has been done in accordance with a certified design:



Yes



No

If yes – identify the certified design including name, date and version. Also attach a copy of the certified design to this certificate.
(Or provide reference to readily accessible electronic format, eg Internet link.)

Identify:

Link:

The work relies on a Supplier Declaration of Conformity (SDoC):



Yes



No

If yes - identify the SDoC including name, date and version OR EESS registration. Also attach a copy of the SDoC to this certificate.
(Or provide reference to readily accessible electronic format, eg Internet link.)

Identify:

Link:

The installation has been satisfactorily tested in accordance with the Electricity (Safety) Regulations 2010



No



Yes

Description of Work:

Relocation of wiring as necessary for new building layout. Installation of new power outlets and lighting circuits for new layout in bedrooms, hallway and bathrooms. Installation of heaters & towel rails in bathrooms. Reconnection of oven to existing wiring. New wiring of power and interconnect for 7 heatpumps in bedrooms. Additional RCDs and MCBs in main switchboard for new circuits. Installation of IC-F LED downlights in bedrooms, hallways, bathroom and kitchen. Rewiring of living room lighting circuit and installation of new light fitting. Carry out testing as required.

Test Results (provide values)

Polarity (Independent earth):	OK
Insulation resistance:	>121M Ohms
Earth Continuity:	OK Ohms
Bonding:	Slab OK Ohms
Fault Loop impedance	0.35 Ohms
Other (specify):	237V

By signing this document I certify that the completed prescribed electrical work to which this Certificate of Compliance applies has been done lawfully and safely, and the information in the certificate is correct.

Certifier's signature:

Doug Pryor

Digitally signed by Doug Pryor
Date: 2020.05.26 22:27:32 +12'00'

Date:

15/6/21

Electrical Safety Certificate

By signing this document I certify that the installation, or part of the installation, to which this Electrical Safety Certificate applies is connected to a power supply and is safe to use.

Certifier's name:

Doug Pryor

Registration/Practising licence number:

E250871

Certifier's signature:

Doug Pryor

Digitally signed by Doug Pryor
Date: 2020.05.26 22:27:47 +12'00'

Certificate Issue Date:

15/6/21

Connection Date:

9/6/21

CUSTOMER COPY – THIS IS AN IMPORTANT DOCUMENT AND SHOULD BE RETAINED FOR A MINIMUM OF 7 YEARS

This Electrical Safety Certificate also confirms that the electrical work complies with the building code for the purposes of Section 19(1)(e) of the Building Act 2004.



ELECTRICAL SAFETY CERTIFICATE

REFERENCE/CERTIFICATE ID NO.: 1357

This Electrical Safety Certificate provides a legally recognisable statement that the connected installation or part installation, or any fitting that supplies an installation or a part of an installation, is safe to use following prescribed electrical work.

Location Details:

31 Royston St Dunedin

Contact Details:

(Name and address)

Sortehaug Residential Ltd, PO Box 7111, Mornington, Dunedin

Details of work:

☐

The whole installation

☒

Part of the installation

Description of work:

Replacement of two Serene 2068 bathroom wall heaters.
Carry out testing as required.

Date of connection:

2/7/2024

By signing this document I certify that the installation, or part of the installation, to which the Electrical Safety Certificate applies is connected to a power supply and is safe to use.

Certifier's name:

Doug Pryor

Registration/Practising
licence number:

E250871

Certifier's
signature:

Doug
Pryor

Digitally
signed by
Doug Pryor

Certificate Issue Date:

12/07/2024

Email:

doug@dmpe.co.nz

Organisation/
Company:

DMP Consulting Ltd

**CUSTOMER COPY – THIS IS AN IMPORTANT DOCUMENT AND
SHOULD BE RETAINED FOR A MINIMUM OF 7 YEARS**

This electrical safety certificate also confirms that the electrical work complies with the building code for the purposes of Section 19(1)(e) of the Building Act 2004.