

DISCLAIMER

Statement of Passing Over: This information has been supplied by the vendor or the vendor's agents and TRG Dunedin (powered by ownly Ltd licensed REAA 208) is merely passing over this information as supplied to us. We cannot guarantee its accuracy as we have not checked, audited, or reviewed the information and all intending purchasers are advised to conduct their own due diligence investigation into this information. Where you have been supplied with a Council Property File or a LIM Report, please note there may be matters relating to pre-1992 consents or permits in this file which may need further investigation in order to determine their relevance. To the maximum extent permitted by law we do not accept any responsibility to any party for the accuracy or use of the information herein.



ELECTRICAL CERTIFICATE OF COMPLIANCE & ELECTRICAL SAFETY CERTIFICATE

REFERENCE/CERTIFICATE ID No.: 0373

This form has been designed to be used by licensed electrical workers to certify that installations or Part installations under Part 1 or Part 2 of AS/NZS 3000 are safe to be connected to the specified system of electrical supply.

Location Details:

18 Barnett St, Dunedin

Contact Details:
(Name and address)

Jacinda White

Name of Electrical worker:

Joshua Oranje

Registration/Practising licence number:

E260285

Phone & email:

027 2424520 jdc.electricalnz@gmail.com

Name and registration number of person(s) supervised:

Certificate of Compliance

Type of work: Addition Alteration New work
The prescribed electrical work is: Low risk General High-risk (Specify): Mains

Means of compliance: Part 1 of AS/NZS 3000 Part 2 of AS/NZS 3000

Additional Standards or electrical code of practice were required: No Yes (specify):

Date or range of dates that prescribed electrical work undertaken: 27.8.20

Contains fittings that are safe to connect to a power supply? Yes No

Specify type of supply system: 230V Mains

The installation has an earthing system that is correctly rated (where applicable) Yes No

Parts of the installation to which this certificate relates that are safe to connect to a power supply?

All Parts (specify)

The work relies on manufacturers instructions: Yes No

If yes - identify the instruction manual including name, date and version. Also attach a copy of manufacturer's instructions to this certificate.
(Or provide reference to readily accessible electronic format, eg Internet link.)

Identify:
Link:

The work has been done in accordance with a certified design: Yes No

If yes - identify the certified design including name, date and version. Also attach a copy of the certified design to this certificate.
(Or provide reference to readily accessible electronic format, eg Internet link.)

Identify:
Link:

The work relies on a Supplier Declaration of Conformity (SDoC): Yes No

If yes - identify the SDoC including name, date and version OR EESS registration. Also attach a copy of the SDoC to this certificate.
(Or provide reference to readily accessible electronic format, eg Internet link.)

Identify:
Link:

The installation has been satisfactorily tested in accordance with the Electricity (Safety) Regulations 2010 No Yes

Description of Work:

Installed new 16m² 2c Mains from MSB to New Mains entry Box. Connected new mains in links behind MSB to Existing mains.

Test Results (provide values)

Polarity (Independent earth):	<u>Pass</u>
Insulation resistance:	<u>Existing</u> Ohms
Earth Continuity:	<u>N/A</u> Ohms
Bonding:	<u>N/A</u> Ohms
Fault Loop Impedance	<u>L-N: 32</u> Ohms
Other (specify):	<u>241V E-loop 10, 27A</u>

By signing this document I certify that the completed prescribed electrical work to which this Certificate of Compliance Psx-757A applies has been done lawfully and safely, and the information in the certificate is correct.

Certifier's signature: [Signature]

Date: 27.8.20

Electrical Safety Certificate

By signing this document I certify that the installation, or part of the installation, to which this Electrical Safety Certificate applies is connected to a power supply and is safe to use.

Certifier's name: Joshua Oranje

Registration/Practising licence number: E260285

Certifier's signature: [Signature]

Certificate Issue Date: 27.8.20

Connection Date: 27.8.20

CUSTOMER COPY - THIS IS AN IMPORTANT DOCUMENT AND SHOULD BE RETAINED FOR A MINIMUM OF 7 YEARS



3105

DELTA
THINK. INFRASTRUCTURE

COMPLIANCE & ELECTRICAL SAFETY CERTIFICATE

1 LOCATION OF INSTALLATION

ADDRESS: 18 Burnett St

2 CUSTOMER INFORMATION

NAME:

POSTAL ADDRESS:

EMAIL:

PHONE:

3 ELECTRICAL WORKER INFORMATION

NAME: Benn McDonald

REGISTRATION: LMD272355

ORGANISATION: Delta

PHONE: 021431328

EMAIL:

PERSON BEING SUPERVISED:

4 WORK DETAILS

THE WORK IS: (CIRCLE) ADDITIONS ALTERATIONS **NEW WORK**

THE PRESCRIBED ELECTRICAL WORK IS: (TICK) HIGH RISK GENERAL LOW RISK

THE HOMEOWNER HAS UNDERTAKEN PART OF THE ELECTRICAL INSTALLATION WORK

TICK IF WORK INCLUDES Mains MEN switchboard closest to point of supply Main Earthing System Electrical Lines

MEANS OF COMPLIANCE: Part 1 of AS/NZS 3000 Part 2 of AS/NZS 3000

ADDITIONAL STANDARDS OR ELECTRICAL CODE OF PRACTICE WERE REQUIRED: No Yes (specify)

SPECIFY TYPE OF SUPPLY SYSTEM:

BRIEF DESCRIPTION: NS

5 CERTIFICATION OF WORK

I certify that the completed prescribed electrical work to which this certificate applies, has been done lawfully and safely and the information in the certificate is correct in that the installation, or part of the installation:

- has been installed in accordance with a certified design
- has an earthing system that is correctly rated
- contains fittings which are safe to connect to a power supply
- relies on supplier's Declaration of Conformity (attach or reference¹)
- relies on manufacturers instructions (attach or reference¹)
- has been satisfactorily tested in accordance with Electricity (Safety) Regulations 2010
- is safe to connect

TEST RESULTS

	Electrical Worker	Inspector
Polarity (independent earth):		
Insulation resistance:	7550	
Earth continuity:		
Bonding:		
Other (specify):		

ELECTRONIC REFERENCE:

ELECTRICAL WORKER'S SIGNATURE:

DATE: 27-8-20

1 If it is impractical to attach a copy of a particular manufacturers instructions, or of any certified design or supplier declarations of conformity, provide a reference to where the documents can be found, in a readily accessible format, through electronic means.

6 ELECTRICAL SAFETY CERTIFICATE

I certify and that the installation, or part of the installation to which the Electrical Safety Certificate applies is connected to a power supply and is safe to use

NAME: Benn

REGISTRATION: LMP272355

SIGNATURE:

DATE: 27-8-20

(if certifier is different from electrical worker)



RECORD OF INSPECTION (ROI) OF HIGH-RISK PRESCRIBED ELECTRICAL WORK
PURSUANT TO THE ELECTRICITY (SAFETY) REGULATIONS 2010

Reference/Record ID Number: JOC - 16 BURNETT ST.

Issuer (Inspector) details:

Name of Inspector: Johno Jamison Registration #: I-280466
Email address: inspectorjohnonz@gmail.com Telephone: 027 328 5080

Location of installation:

Location details: 18 BURNETT ST, CAVERSHAM, DUNEDIN.
Location type: Domestic Non-Domestic Accommodation Industrial Commercial
 Educational Healthcare Miscellaneous (other)

Certifying Electrical Work and Certificate of Compliance (CoC) details:

Name of Electrical worker(s): JOSH ARNISE Registration #: 9-260285
CoC details: 0373 CoC(s) Physically attached CoC(s) Electronically attached

Certifying Electrical Work and ROI details:

What was inspected:

NEW AERIAL & INTERNAL WIRING, MAINS ENTRY BOX,
LIGNED & TESTED TO MAIN SWITCH ONLY.
MEN LINK INSTALLED.

Specify the regulation(s) and companion standard(s), or identify the certified design, followed when carrying out the inspection:

AS/NZS3000:2007 and E(S)R:2010

What are the results of the inspection:

Insulation Resistance = / Mohm, Polarity Correct, Voltage = 241 Vac,
Line Loop = 0.32 ohms, PSCC = 0.757 kA, Earth Loop = 10.27 ohms,
M.E.C = / ohms

High Risk Category:

- Not to AS/NZS 3000 Part 2 - 6A(2)(a)(i) Photovoltaic system - 6A(2)(a)(iv) Electrical medical area - 6A(2)(a)(vi)
 High voltage installation - 6A(2)(a)(ii) Hazardous area - 6A(2)(a)(v) Mains work - 6A(2)(b)
 Mains parallel generation - 6A(2)(a)(iii) Animal stunning or meat conditioning - 6A(2)(c)
 Other - please describe:

Declaration

I hereby confirm that the work described above has been done in accordance with the regulations; and the
installation on which the work has been done is, and will be, when energized, electrically safe.

Signature: [Signature] Date: 17-8-20