

DISCLAIMER

Statement of Passing Over: This information has been supplied by the vendor or the vendor's agents and TRG Dunedin (powered by ownly Ltd licensed REAA 208) is merely passing over this information as supplied to us. We cannot guarantee its accuracy as we have not checked, audited, or reviewed the information and all intending purchasers are advised to conduct their own due diligence investigation into this information. Where you have been supplied with a Council Property File or a LIM Report, please note there may be matters relating to pre-1992 consents or permits in this file which may need further investigation in order to determine their relevance. To the maximum extent permitted by law we do not accept any responsibility to any party for the accuracy or use of the information herein.



ELECTRICAL CERTIFICATE OF COMPLIANCE AND ELECTRICAL SAFETY CERTIFICATE



Reference/Certificate ID No:

755

This form has been designed to be used by licensed electrical workers to certify that installations or Part installations under Part 1 or Part 2 of AS/NZS 3000 are safe to be connected to the specified system of electrical supply.

Location Details:

33 FORFAR ST DUNEDIN.

Contact Details:
(Name and address)

CLAIRE LATTA.

Name of
Electrical worker:

John Wilson

Registration/Practising
licence number:

E250079

Organisation/company:

Reid Wilson Electrical Ltd

Phone and email:

0211600756 / ajfn@xtra.co.nz

Name of person(s)
supervised:

Rhys Turner / Calum Booth

CoC

Type of work:

☐

Additions

☒

Alterations

☐

New work

The prescribed electrical work is:

☐

Low risk

☐

General

☒

High risk (Specify):

Reference Standards:

☐

Part 1 of AS/NZS 3000

☒

Part 2 of AS/NZS 3000

☐

Additional Standards:

Description of Work: (including date/s of work and type of supply system)

INSTALL NEW EARTHING SYSTEM + EARTH ROD.
REPLACE REMAINING VUL + TRS WITH TRS
CABLE.

I certify that the completed prescribed electrical work to which this Certificate of Compliance applies has been done lawfully and safely, and the information in the certificate is correct in that the installation, or part of the installation:

Select those that apply:

☐Has been installed in accordance with the specified certified design¹☒

Has an earthing system that is correctly rated (where applicable)

☒

Contains fittings that are safe to connect to a power supply

☐Relies on a supplier Declaration of Conformity¹☐Relies on a manufacturer's instructions¹☒

Has been satisfactorily tested in accordance with the Electricity (Safety) Regulations 2010

☒

Is safe to connect

Electronic/Other reference:

Certifier's signature:

E return 31.3 Ω **Test Results**

Polarity (Independent earth):	Pass
Insulation resistance:	
Earth Continuity:	
Bonding:	
Fault Loop impedance	0.39 Ω
Other (specify):	PFC 611A

Date:

4/12/18

¹ Attach or reference. If it is impractical to attach a copy of a particular manufacturer's instructions, or of any certified design or supplier declaration of conformity, provide a reference to where the documents can be found, in a readily accessible format, by electronic means.

ESC

I certify that the installation, or part of the installation, to which this Electrical Safety Certificate applies is connected to a power supply and is safe to use.

Certifier's
name:

John Wilson

Registration/Practising
licence number:

E250079

Certifier's
signature:Certificate
Issue Date:

4/12/18

Connection
Date:

4/12/18



DN009306

DELTA
THINK.INFRASTRUCTURE

RECORD OF INSPECTION

1 CUSTOMER INFORMATION

NAME:

C LATTER

PHONE:

LOCATION ADDRESS:

33 FOREAR ST CAULON HILL

2 ELECTRICAL WORKER INFORMATION

REFERENCE:

755

NAME:

J WILSON

REGISTRATION:

E 250079

DATE:

4/12/18

3 HIGH RISK CATEGORY

- ☐ NOT TO AS/NZS 3000 PART 2 (6A(2)A(I)) ☐ HIGH VOLTAGE INSTALLATION (6A(2)A(III)) ☐ MAINS PARALLEL GENERATION (6A(2)A(III))
☐ PHOTOVOLTAIC SYSTEM (6A(2)A(IV)) ☐ HAZARDOUS AREA (6A(2)A(V)) ☐ INSTALLATION LOCATED IN A MINE (6A(2)A(VI))
☐ ELECTRICAL MEDICAL AREA (6A(2)A(VII)) ☒ MAINS WORK (6A(2)B) ☐ ANIMAL STUNNING OR MEAT CONDITIONING (6A(2)A(V))
☐ OTHER Please describe.....

4 WORK DETAILS

THE WORK IS: (CIRCLE)

ADDITIONS

ALTERATIONS

NEW WORK

THE PRESCRIBED ELECTRICAL WORK IS: (TICK)

☒ HIGH RISK☐ GENERAL☐ LOW RISK☐ MAINS☐ SWITCH BOARD☒ MAIN EARTH☐ METERING☐ ELECTRICAL LINES☐ OTHERNEW 6mm² EARTH TO DRIVEN ELECTRODE

NEW NEUTRAL + EARTH BARS

VISUAL CHECK, TEST. CONFIRM POLARITY AND NETWORK (L-N) LOOP.

5 COMPLIANCE AND TEST RESULTS

Specify what the inspection was carried out in accordance with (regulation/s and/or companion standard/s):

☒ AS/NZS 3000☐ AS/NZS 3003☐ AS/NZS 5033☐ AS/NZS 60079☐ OTHER

WHAT ARE THE RESULTS OF THE INSPECTION:

☒ TEST EQUIPMENT CALIBRATED☐ OTHER RESULTS ATTACHEDP/N LOOP 0.39 Ω PSSC 811 AMPS VOLTAGE 238 V P/E LOOP 31.3 Ω RESISTANCE OF M.O.E 0.10 Ω

INSULATION OF NETWORK POLE FUSE TO METERBOX/SWITCHBOARD

M Ω

METERBOX TO SWITCHBOARD

M Ω

ANY NON-COMPLIANCE

☐ FIXED BEFORE LIVENING☐ POLARITY CHECKED WITH LINK OUT☒ CHECKED WITH TRAILING LEAD☐ PHASE ROTATION CHECKED

6 INSPECTION DETAILS

I confirm that the part of the installation, to which this Record of Inspection applies is connected to the network, is safe to use and complies to electrical safety regulations:

☒ HAS BEEN ENLIVENED

NAME:

GARY LOE

REGISTRATION:

I 1222

SIGNATURE:

DATE:

4/12/18

PHONE:

021 194 1021

COMPANY:

DELTA