

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

CALL FOR BIDS

THE UTILITY BOARD OF THE CITY OF KEY WEST, FLORIDA, operator of Keys Energy Services (KEYS), hereby gives notice to prospective bidders that sealed proposals will be received by **KEYS** electronically until **10:00 a.m.** on **Monday, August 25, 2025** for:

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

KEYS has instituted VendorLink and DemandStar systems to provide current information to potential bidders. These systems will allow you to receive bid information quickly and at your convenience 24 hours a day, 7 days a week. Specifications may be obtained from their websites at www.myvendorlink.com or www.DemandStar.com. Registered vendors will be notified automatically of all Requests for Proposals. You may also visit www.KeysEnergy.com for links and download information for all KEYS bid specifications.

It shall be the sole responsibility of each bidder to have their bid electronically delivered on or before the time for opening proposals last announced to bidders. Emailed proposals will not be accepted. Should a vendor not be able to submit via VendorLink or DemandStar, paper submittals will be accepted. Paper submittals must be received prior to the opening date and time in order to be considered. Paper submittals, if applicable, are to be delivered via FedEx, UPS, or in-person to:

Keys Energy Services
Bid Opening Committee – KEYS Bid 19-25
6900 Front Street Extended
Key West, FL 33040

Note: This address does not receive US Postal Service.

Any proposal received after the time last announced for opening proposals may be retained by KEYS or returned to the bidder, but such proposal may be rejected as not responsive.

Vendors with questions pertaining to this bid specification must submit them in writing via email to purchasing@keysenergy.com no later than **Friday, August 8, 2025 at noon**. Any questions received after noon on August 8, 2025 will not be addressed.

Each proposal should be accompanied by a Certified Check or Bid Bond payable to the **UTILITY BOARD OF THE CITY OF KEY WEST** in an amount not less than five (5%) percent of the amount of the proposal as security.

Each proposal should constitute an offer to **KEYS**, as outlined therein, and should be irrevocable after the time announced for the opening thereof.

At a meeting of the **BID OPENING COMMITTEE** to be held virtually on **Monday, August 25, 2025 at 10:00 a.m.** Proposals will be opened and vendor names will be publicly read aloud.

KEYS reserves the right to reject any or all proposals, to waive irregularities and informalities in any or all proposals, and to separately accept or reject any item, items, bid schedule or bid schedules of the proposal which KEYS deems to be in the best interest of the Utility Board.



Tyler Randolph, Purchasing Supervisor

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

GENERAL

Keys Energy Services (KEYS) is a municipal electric utility supplying power to residents of the lower Florida Keys. KEYS is located in the extreme southern tip of peninsular Florida, situated in Monroe County, Florida, primarily what is considered the "Lower Keys", which extends eastwardly from Key West to the west end of the Seven-Mile Bridge. Corporate Offices are located at 1001 James Street, Key West, Florida and the Transmission and Distribution (T&D) Facility is located on Stock Island at 6900 Front Street Extended, Key West, Florida 33040.

KEYS and its representatives have exercised due care in preparing this Request for Proposals (RFP). All information contained herein is believed to be substantially correct. However, bidders should verify information independently if desired. KEYS and its representatives do not warrant the accuracy of information contained herein.

SPECIFICATIONS

BACKGROUND

KEYS electrical system is currently supplied by a single, 138kV transmission line that interconnects with Florida Keys Electric Cooperative's transmission system at Knights Key, Florida. KEYS' existing transmission line system has been in service since the 1960s with some newer lines built in the late 1990s. These lines are critical to the supply of reliable electricity to KEYS customers.

PROJECT SUMMARY

This project encompasses mobilization/demobilization, measuring, surface cleaning, surface preparation, coating application, and final wrap of steel transmission poles over water and land. The Poles are both steel and galvanized steel construction and are located from Marathon, Florida, to Key West, Florida. Each steel pole on Transmission Lines 6, 7, 8, 9 and 11 will be cleaned and coated from 4' above the base plate down to include the baseplate, nuts/bolts, and under baseplate. Each steel pole on Transmission Lines 3 and 5 will be cleaned and coated from top to bottom. In addition, this project requires the repair of damaged pole areas identified by a recent inspection.

All structures are located in a subtropical environment with high humidity, high UV radiation, and salt spray and are located within one (1) mile or less from salt water. Because of the harsh salt environment, immediate repair is necessary to extend the life of the existing steel pole and prevent further corrosion. Contractor will be responsible for providing all necessary materials, labor, tools, and equipment to complete the scope of work. This project will start with Line 7 at Marathon, FL and continue towards Key West, FL on Line 6, Line 9, Line 3, Line 5, Line 8, and Line 11.

SCOPE OF WORK

Contractor is to provide services for corrosion maintenance of transmission line steel poles recommended by recent inspection (see attached "Steel Pole Recommendations" at "REFERENCE MATERIAL" Link). Contractor will be tasked for surface cleaning, surface preparation, and coating of the steel poles from 4' above the base plate to the baseplate on lines 6, 7, 8, 9, 11 and the full pole on lines 3 & 5, including baseplate, nuts and bolts. The Contractor shall also perform "Steel Pole Recommendations" from the Praxel Inspection on 4/15/2025. Contractor shall provide all necessary materials, labor, tools, and equipment for the project. Contractor is responsible for providing their own boat and means of accessing, launching, and storage of boat. The contractor shall be responsible for any damage which results from dripping and/or blowing of paint or other material during cleaning and/or surface preparation.

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

4' surface cleanse, application, and coating:

Line 7: 90 steel poles, 37 on land and 53 on water, (location Big Pine Key to Marathon)

Line 6: 25 steel poles on land, (location Big Pine Key to Big Coppitt Key)

Line 9: 11 steel poles on land, (location Big Coppitt Key to US1 Stock Island)

Line 8: 15 steel poles on land, (Kennedy Drive Substation Key West to US1 Stock Island)

Line 11: 1 steel poles on land, (Kennedy Drive, Key West)

Full pole cleanse, application, and coating:

Line 3: 7 steel poles on land, (US1 Stock Island to Second Street Substation Stock Island)

Line 5: 6 steel poles on land, (US1 Stock Island to Second Street Substation Stock Island)

Praxel Pole Recommendations: 54 Structures:

See Appendix A Table 1: List of Structures & Recommendations and attached Praxel Summary found at "REFERENCE MATERIAL" Link.

WORK PLAN

The contractor shall follow the work plan below for surface cleaning, surface preparation, and coating applications. The Contractor shall prevent paint chips and/or paint from dripping, spattering, or blowing onto equipment. Specifically, **THE CONTRACTOR SHALL PROVIDE CATCH BASIN TO PREVENT ANY DEBRIS FROM FALLING INTO SURROUNDING WATERS DUE TO THE SENSITIVITY OF THE MARINE SANTUARY.** The contractor shall be responsible for any damage to buildings, cars or other facilities which result from dripping and/or blowing of paint or other material during cleaning and/or surface preparation.

Area Preparation: Any area closure or FMOT set up must be done prior to work commencing. All shielding/hoods and ground tarps to prevent airborne particles during cleaning or painting should take place prior to work commencement.

Surface Cleaning: At minimum, the steel pole area shall be cleaned using the following methods described below from grade to bottom plate. If repair work has been completed on the pole, remove all weld spatter and round all sharp edges. Cleaning shall start at 4 foot above the top of baseplate and move towards the baseplate. Under baseplate, nuts and bolts shall all be included.

SSPC-SP1 Solvent Cleaning: A method of removing all visible oil, grease, soil, drawing and cutting compounds and other soluble contaminants. Change rags and cleaning solution frequently so that deposits of oil and grease are not spread over additional areas in the cleaning process. Be sure to allow adequate ventilation.

SSPC-SP6/NACE 3 Commercial Blast Cleaning: A near-white metal blast cleaned surface, when viewed without magnification, shall be free of all visible oil, grease, dust, dirt, mill scale, rust, coating, oxides, corrosion products and other foreign matter of at least 66-2/3% of each unit area. Light shadows, slight streaks, or minor discolorations caused by stains of rust, stains of mill scale, or stains of previously applied coatings in less than 33-1/3% of the unit area are acceptable.

SSPC-SP10/NACE 2 Near-White Blast Cleaning: A near-white metal blast cleaned surface, when viewed without magnification, shall be free of all visible oil, grease, dust, dirt, mill scale, rust, coating, oxides, corrosion products and other foreign matter of at least 95% of each unit area. Staining shall be limited to no more than 5 percent of each unit area, and may consist of

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

light shadows, slight streaks, or minor discolorations caused by stains of rust, stains of mill scale, or stains of previously applied coatings.

Surface Preparation: After surface cleaning of the corrosive area is completed, the exposed steel area shall be prepared for coating. This is done by a rinse of CHLOR*RID® per manufacturer instructions. Do not dilute solution.

Surface Preparation Testing: After CHLOR*RID® rinse, test surface area with CHLOR*RID® test kit for chlorides, repeat rinse and test if necessary.

POR-15: The contractor shall apply the POR-15 Metal Prep compound in accordance with manufactures instructions.

Coating: Coat steel surfaces with Induron InduraGuard 9200 coating (Dark Grey) per manufacturer's instructions.

Praxel Steel Pole Recommendations: Perform all required recommendations found within the attached study and in Appendix A Table-1 and the Summary found within "REFERENCE MATERIAL" link.

GENERAL SITE CONDITIONS

The Contractor shall be aware that structures to be inspected are within the National Marine Sanctuary located in Monroe Country, Florida. Many structures are located in extreme environmentally sensitive areas, including but not limited to sea grass beds, live coral, estuaries, mangroves and other sensitive locations. See additional information in Environmental Compliance section.

Many structures are in areas of extremely shallow water and are exposed or above water at low tides. Shallow draft vessels with propeller protection shall be utilized as required to protect sensitive areas. In addition, it will be necessary to utilize non-powered vessels such as small Jon boats or canoes to access some shallow water structures, particularly in the Lower Keys segment of the inspection. Some structures must be accessed by walking from existing bridges, as required. Water depths range from 0.0' to approximately 25' at MLW. The Contractor shall be responsible for any and all damages caused by personnel and equipment during the course of this project.

The Contractor shall be aware of extreme weather conditions that occur in the Florida Keys, such as hurricanes and unexpected storms. Contractor is responsible for monitoring and adhering to weather advisories on pending storms. Any damage to property or safety to personnel due to Contractor negligence is the responsibility of the Contractor.

Contractor is responsible for coordinating with necessary agencies for pending inspection. These may include U.S. Coast Guard, Department of Homeland Security, local, county and state authorities. KEYS must be kept informed of all activities.

DISCLAIMER

KEYS reserves the right to change the quantity and type of inspection based upon bid unit costs and budget. All water depths are approximate and should be verified by Contractor using sources such as topographical maps and flow data from the Corps of Engineers, tidal charts from National Oceanic and Atmospheric Administration (NOAA), and internet mapping and satellite services.

ENVIRONMENTAL COMPLIANCE

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

Governing Authorities

U.S. Department of Army Corps of Engineers (USACE).
Florida Department of Environmental Protection (FDEP).
Department of Natural Resources (DNR).
United States Coast Guard (USCG).
Florida Marine Patrol (FMP).
Florida Fish and Wildlife Conservation Commission (FWC).
Florida Department of Transportation (DOT).

Contractor's Responsibility

Violations or environmental damage caused by the Contractor due to negligence or lack of care or concern on the part of the Contractor shall be mitigated and/or repaired by the Contractor, at the Contractor's expense, to the satisfaction of the governing authority citing such damage.

Items discussed in this Section are not intended to be all inclusive of Federal, State and Local Laws and Regulations. Information is provided at anticipated minimum requirements. Contractor shall be familiar and comply with all requirements of applicable Laws and Regulations.

Equipment Limitations

Utilize shallow-draft pontoon boats or barges in shallow areas (where the mean low water level is less than 18"). Draft of such equipment shall not exceed 12" when fully loaded.

When working in or traversing shallow areas, move vessels only during periods of high tide.

Equip propellers and other propulsion systems as required to prevent damage to bay bottom in all areas.

Items discussed in this Section are not intended to be all inclusive of Federal, State and Local Laws and Regulations. Information is provided at anticipated minimum requirements. Contractor shall be familiar and comply with all requirements of applicable Laws and Regulations.

INSPECTION REQUIREMENTS

The following inspections are required by KEYS Project Manager:

1. Prior to start of work to view containment area.
2. After cleaning transmission poles bases, nuts/bolts, base plates.
3. Testing results after CHLOR*RID application.
4. After Induraguard 9200 application.
5. At completion of project to review site cleaning.

PERSONEL/EQUIPMENT REQUIREMENTS

Contractor must adhere to KEYS Safety Manual or provide Company Safety Manual for KEYS approval. Contractor must provide dedicated supervisor, fluent in the English language. Supervisor shall conduct a job briefing with the workers involved in job before the start of each day. At minimum the briefing shall cover hazards associated with the job, work procedures involved, special precautions, and safety procedures on water. Supervisor will be in radio contact with KEYS Control Room Coordinators at all times during working hours. Hand-held radio will be provided by KEYS during the duration of project. Workers must be able to speak fluent English. Contractor will adhere to all Federal and State boating requirements and recommendations.

PRODUCTS:

The following products are to be used (manufactures information sheets attached):

CHLOR*RID® rinse and test kit.

POR-15 Metal Prep.

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

Induron InduraGuard 9200 coating.

Any and all associated required materials to complete all recommended work in accordance with the Praxel Study.

SCHEDULE

Work Schedule:

The following work schedule is to be adhered to:

Work hours 8am – 7pm, Monday – Saturday. Any alterations from the work schedule shall be approved prior to work start by KEYS Energy Services Project Manager.

Phone KEYS dispatch when work commences and completes daily and for any emergencies.

Project completion: May 1st, 2026.

Line Schedules:

The following work schedule is to be adhered to:

Work hours 8am – 7pm, Monday – Saturday. Any alterations to the work schedule shall be approved prior to work start by KEYS Energy Services Project Manager.

Phone KEYS dispatch when work commences and completes daily and for any emergencies.

Line Outage Schedules:

No transmission line outages are anticipated for Lines 6, 7, 8, 9 and 11.

Lines 3 & 5 are typically on mutual poles, as parallel circuits. These transmission lines are the only two lines that connect to KEYS on-island generation facilities. Outages on these lines will need to be coordinated by KEYS with Florida Municipal Power Agency. Work is required in the power zone. The 13.8 kV distribution shall remain energized at all times. The 69 kV transmission on the poles may be required to be de-energized for work. The goal will be to minimize the outage duration for the transmission line by separating work that can be done de-energized and work that will require an outage. Multiple structures should be worked in parallel to minimize the outage times. .

BLACK OUT DATES

New Year's Day	January 1st
Martin Luther King, Jr. Birthday	January, 3rd Monday
President's Day	February, 3rd Monday
Memorial Day	May, Last Monday
Independence Day	July 4th
Labor Day	September, 1st Monday
Columbus Day	October, 2nd Monday
Veteran's Day	November 11th
Thanksgiving Day	November 4th Thursday
Day After Thanksgiving	November
Christmas Eve	December 24th
Christmas	December 25th
New Year's Eve Day	December 31st – Half day

When a holiday falls on a Sunday, the Monday following shall be considered the holiday. When a holiday falls on a Saturday, the Friday prior thereto shall be considered the holiday.

REFERENCE MATERIAL

Please use the following link to access Google Earth KMZ files and all reference material.

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

https://keysenergy0.sharepoint.com/:f:/s/Purchasing/El6RWwkCajhOue9ih_uDx-kB6LD4K-58L-ZA0uBVpvr5VA?e=OdrLvF

NOTE: KMZ Disclaimer – The Google Earth KMZ file is just for reference only. It shall provide the bidder an idea of the site conditions. Google Earth photos can be up to three (3) years old. It is the bidders responsibility to field inspect pole for actual field conditions.

DOCUMENTATION

The following must be submitted with proposal for consideration:

- Three (3) References of similar projects, 138kV and above, where work was done on energized line, including full contact information. (name/phone number/email address.)
- Demonstrate successful completion of similar projects
- Provide experience with similar projects in Florida Keys
- Description of containment over water
- Preliminary project schedule

PROPOSAL CONTENTS & EVALUATION

The proposal should include a description of the firm's capabilities and experience with providing the requested services, including a description of any special qualifications which are indicative of working familiarity with similar projects.

The proposals will be evaluated. The evaluation criteria will include a variety of considerations, including, but not limited to:

- a. Experience with products and pole painting;
- b. Experience with similar projects in Florida Keys
- c. Pricing;
- d. References.

BID SUBMITTAL

Proposals shall be submitted electronically via VendorLink or DemandStar prior to the opening date and time. Emailed proposals will not be accepted. Should a vendor not be able to submit via VendorLink or DemandStar, paper submittals will be accepted. Paper submittals must be received before the opening date and time to be considered.

Paper submittals can be sent via **FedEx, UPS, or In-Person** to:

Keys Energy Services
Bid Opening Committee – Bid 19-25
6900 Front Street Extended
Key West, Florida 33040

Note: This address does not receive US Postal Service.

Bidders must submit the following to be found responsive:

1. Bid Bond or Cashier's Check for 5% of Total
2. Proposal Page
3. Insurance Agent's Statement
4. Bidder's Statement
5. Safety Compliance Affidavit

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

6. Drug-Free Workplace Statement
7. Public Entity Crimes Sworn Statement
8. Hourly Rates for Labor and Equipment – to be used should additional work/material outside of the scope of work is required
9. Three References
10. Preliminary Project Schedule

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

Appendix A

Table 2: List of Structures & Recommendations

Line Number	Structure Number	Pole Element Number	Area	Tower in Water	Recommendation #1	Recommendation #2	
T3	58	T3-58	Stock Island	No	External Rust Removal & Treatment		
T3	62	SK55-6	Stock Island	No	External Rust Removal & Treatment		
T5	5	SK55-7	Stock Island	No	External Rust Removal & Treatment		
T5	9	T5-9	Stock Island	No	External Rust Removal & Treatment		
T6	106	SL31	Park Key	No	Install/Repair Ground		
T6	127	SL53	Upper Sugarloaf Key	No	Nut for anchor bolt is missing from the base on the SW corner. Clean off protection and install new nut.		
T6	94	SL17	Park Key	No	Install/Repair Ground		
T6	97	SL21	Park Key	No	Install/Repair Ground		
T7	10	PK31	Big Pine	No	Install/Repair Ground		
T7	112	BH41	Ohio Bahia Honda Channel Bridge	Yes	External Rust Removal & Treatment		
T7	130	LDK4 (T7-130)	Little Duck Key	No	Install/Repair Ground		
T7	152	T7-152	Seven Mile Bridge	Yes	External Rust Removal & Treatment		
T7	153	T7-153	Seven Mile Bridge	Yes	External Rust Removal & Treatment		
T7	166	T7-166	Seven Mile Bridge	Yes	External Rust Removal & Treatment		
T7	178	T7-178	Seven Mile Bridge	Yes	External Rust Removal & Treatment		
T7	179	T7-179	Seven Mile Bridge	Yes	External Rust Removal & Treatment	Remove Anchor Bolt Rust, Apply Protection	
T7	180	T7-180	Seven Mile Bridge	Yes	External Rust Removal & Treatment		

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

T7	181	T7-181	Seven Mile Bridge	Yes	External Rust Removal & Treatment		
T7	182	T7-182	Seven Mile Bridge	Yes	External Rust Removal & Treatment		
T7	183	T7-183	Seven Mile Bridge	Yes	External Rust Removal & Treatment		
T7	184	T7-184	Seven Mile Bridge	Yes	External Rust Removal & Treatment		
T7	185	T7-185	Seven Mile Bridge	Yes	External Rust Removal & Treatment		
T7	186	T7-186	Seven Mile Bridge	Yes	External Rust Removal & Treatment		
T7	197	T7-197	Seven Mile Bridge	Yes	External Rust Removal & Treatment		
T7	209	T7-209	Seven Mile Bridge	Yes	External Rust Removal & Treatment		
T7	210	T7-210	Seven Mile Bridge	Yes	External Rust Removal & Treatment		
T7	24	PK51	Big Pine	No	Other (See Notes)		
T7	38	PK70	Big Pine	No	Install/Repair Ground	Missing a nut on Anchor Bolt. Clean off threads and Install new nut. Reapply protectant to new nut.	
T7	40	PK72	Spanish Harbor Channel	Yes	External Rust Removal & Treatment	Install/Repair Ground	
T7	41	PK73	Spanish Harbor Channel	Yes	Secure Anode Box to Pole		
T7	44	PK75.5	Spanish Harbor Channel	Yes	External Rust Removal & Treatment		
T7	45	PK76	Spanish Harbor Channel	Yes	External Rust Removal & Treatment		
T7	46	PK77	Spanish Harbor Channel	Yes	External Rust Removal & Treatment		
T7	48	WS1	West Summerland Key	Yes	External Rust Removal & Treatment		
T7	66	WS21	New Bahia Honda Bridge	Yes	External Rust Removal & Treatment		
T7	67	WS22	New Bahia Honda Bridge	Yes	External Rust Removal & Treatment	Move ground tap to next side over due to corrosion and plug old hole.	
T7	68	WS23	New Bahia Honda Bridge	Yes	External Rust Removal & Treatment		

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

T7	69	WS24	New Bahia Honda Bridge	Yes	Secure Anode Box to Pole	External Rust Removal & Treatment	
T7	70	WS25	New Bahia Honda Bridge	Yes	External Rust Removal & Treatment		
T7	71	WS26	New Bahia Honda Bridge	Yes	External Rust Removal & Treatment		
T7	72	BH1	New Bahia Honda Bridge	Yes	External Rust Removal & Treatment		
T7	74	BH3	New Bahia Honda Bridge	Yes	External Rust Removal & Treatment		
T7	75	BH4	New Bahia Honda Bridge	Yes	External Rust Removal & Treatment	Remove Anchor Bolt Rust, Apply Protection	
T7	76	BH5	New Bahia Honda Bridge	Yes	External Rust Removal & Treatment	Remove Anchor Bolt Rust, Apply Protection	
T7	77	BH6	New Bahia Honda Bridge	Yes	Install Structural Steel Plate(s)	External Rust Removal & Treatment	
T7	78	BH7	New Bahia Honda Bridge	Yes	Install Structural Steel Plate(s)	External Rust Removal & Treatment	
T7	79	BH8	New Bahia Honda Bridge	Yes	External Rust Removal & Treatment		
T7	80	BH9	New Bahia Honda Bridge	Yes	External Rust Removal & Treatment	Remove Anchor Bolt Rust, Apply Protection	
T7	81	BH10	New Bahia Honda Bridge	Yes	External Rust Removal & Treatment		
T7	82	BH11	New Bahia Honda Bridge	Yes	External Rust Removal & Treatment		
T7	83	BH12	New Bahia Honda Bridge	Yes	Secure Anode Box to Pole		
T7	93	BH22	Bahia Honda Key	Yes	Monitor Annually for Corrosion Progression		The foundation reveal is lower than it should be, creating a situation where higher tide brings water to the structure base. There is corrosion on anchor bolts and on the inside that is not structurally significant. Structure exterior is in decent shape. Bolts and inside should be monitored annually for corrosion progression
T8	50	US1-S1	Key Haven	No	External Rust Removal & Treatment		Minor surface rust near base.
T9	79	BC12-3	Big Coppitt Key	No	Install/Repair Ground		Ground pole lug appears to be intact, but no rod is visible.

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

KEYS ENERGY SERVICES **GENERAL TERMS & CONDITIONS**

ADDITIONS/DELETIONS

KEYS reserves the right to add or delete any item from this bid or resulting contract when deemed to be in the best interest of KEYS.

ALTERATIONS IN PROPOSAL

Except as otherwise provided herein, Proposals which are conditional in any way, or which contain erasures or interlineations not authenticated as provided herein, or which contain items not called for, items not in conformity with applicable laws, changes, additions, recapitulations, alternative Proposals, or any other modifications of the Proposal forms which are not specifically called for in the Contract Documents, will be rejected as not responsive unless specifically agreed to in writing by KEYS. Erasures, interlineations or other corrections shall be authenticated by affixing in the margin immediately opposite the correction, the handwritten initials of each person executing the Proposal.

APPLICABLE LAW

This Contract shall be interpreted in accordance with the law of the State of Florida.

ASSIGNMENT

No contract awarded under these terms, conditions, and specifications, may be sold, transferred or assigned in full or part without the written permission of KEYS. Such written permission shall not relieve contractor from its obligations and liabilities.

ATTORNEY FEES

The prevailing party in any litigation or mediation relating to the contract shall be entitled to recover its reasonable attorney fees and costs from the other party for all matters, including, but not limited to, appeals.

BASIS OF AWARD

- A. The award will be made by KEYS on the basis of the Proposal from the lowest responsive* responsible**, Bidder which, in KEYS' sole and absolute judgment, will best serve the interest of KEYS.
- B. KEYS reserves the right to accept or reject any or all Proposals, and to waive any informalities and irregularities in said Proposal.
 - *Responsive Bidder: Any person, firm, or corporation submitting a bid for the work contemplated whose bid form is complete and regular, free of excisions or special conditions and has no alternative bids for any item unless requested in the technical specifications.
 - **Responsible Bidder: Any person, firm, or corporation submitting a bid for the work contemplated who maintains a permanent place of business, has adequate manpower and equipment to do the work properly and within the time limit that is established, has adequate financial status to meet his obligations contingent to the work and has a history of performance of like contracts (acceptable to KEYS).
- C. Evaluation: The lowest evaluated price shall be determined from an analysis which assesses the impact of the contract price, operational and maintenance costs.

BID BOND/CERTIFIED CHECK

Each proposal should be accompanied by a Bid Bond or Certified Check payable to the UTILITY BOARD OF THE CITY OF KEY WEST, FLORIDA in an amount not less than five (5%) percent of the amount of the proposal as security.

BID PROPOSAL PRICING

All bid proposals must remain firm for 120 days minimum.

BIDDER QUALIFICATIONS

Please provide this information in your bid response.

CITY/COUNTY LICENSING

For the term of the contract, Contractor shall maintain City of Key West and Monroe County licenses and/or other requirements to work within the City or County limits. Contractor should provide KEYS with a copy of all licenses.

COMPLETENESS OF PROPOSAL

- A. Each Bidder shall respond to all items on Proposal Page. When quoting on all items including optional items, bidders shall insert the words "No Bid" in the space provided for any item for which no offer is made. Failure to do so may result in the Proposal being rejected as not responsive.
- B. KEYS will consider alternative, additive, or deductive options with no initial pricing.
- C. Each Proposal shall include specific acknowledgment of receipt of all Addenda issued during the bidding period. Failure to do so may result in the Proposal being rejected as not responsive.
- D. Each Bidder shall furnish information relating to its experience, facilities, material, equipment and business as is required by the Proposal form. Failure to do so may result in the Proposal being rejected as not responsive.
- E. Additional technical data furnished by a Bidder, but not required by the Request for Proposal (RFP), may at KEYS' option be considered part of the Proposal to the extent that it is supplementary to, is consistent with and not contrary to the RFP.

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

CONTACT REFERENCES

KEYS contact for bidding requirements and technical specifications: Tyler Randolph, Supervisor of Purchasing, Tyler.Randolph@keysenergy.com or purchasing@keysenergy.com.

CONTRACT DURATION

The duration of the base contract shall be from the date of execution by the Utility Board through August 1, 2026. If this contract is for a unit price and estimated quantities and if KEYS desires, KEYS and Contractor can extend the contract at the same unit price. KEYS reserve the right to cancel this contract without cause with 30 days written notice and with cause within 10 days.

CONTRACT CHANGES

No changes, over the contract period, shall be permitted unless prior written approval is given by the Utility Board of the City of Key West, Florida. No Contractor shall assign the contract or any rights or obligations there under without the written consent of KEYS. In the event of such approved subcontracting, contractor agrees to provide KEYS with written documentation relative to the Subcontractor(s) employed in this contract.

CONTRACT COMPLIANCE

All contracts are subject to the terms and conditions of the Fair and Accurate Credit Transactions Act of 2003. The said provisions and compliance therewith are expressly made part of the contract and are binding covenants on the party contracting with KEYS.

CONTRACTOR LIABILITY

In the event of default by Contractor, KEYS reserves the right to utilize the next lowest Bidder as the new Contractor. In the event of this occurrence, the next lowest Bidder, if it wishes the award, shall be required to provide the bid items at the prices as contained on its proposal or bid for this specification.

CONTRACTOR'S RESPONSIBILITIES

- A. Contractor shall be responsible for all loss, damage, vandalism, theft, etc. for all equipment, tools, materials, etc. left on the job site.
- B. Contractor shall be responsible for maintaining the site in a clean condition during installation. Contractor and KEYS at which time the site should be cleaned up will make a final walk down of the sites.
- C. Prior to completion of demobilization, Contractor shall remove all construction materials, waste, demolition debris, excess materials, temporary installation, etc. that have not been specifically turned over and accepted by KEYS.
- D. Contractor shall be responsible for any and all costs for cleanup of oil or gasoline spills which result from his equipment or from any work performed as part of this contract.
- E. Permit violations or environmental damage caused by contractor shall be mitigated or repaired by contractor, at contractor's expense, to the satisfaction of the governing authority citing such damage.
- F. Items discussed in this section are not intended to be all-inclusive of Federal, State, and Local Laws and Regulations. Information is provided as anticipated minimum requirements. Contractor shall be familiar and comply with all requirements of applicable laws and regulations.
- G. Contractor will assume total responsibility for materials, delivery to/from job site, installation, and testing of system.

DELIVERY

- A. Delivery, inspection and acceptance - delivery, inspections and acceptance will be at destination, F.O.B. Key West as specified in the RFP, KEYS Warehouse, unless otherwise provided. Until delivery and acceptance and after any rejections, risk of loss will be on the Vendor, unless loss results from negligence of KEYS.
- B. Notwithstanding the requirements for any KEYS inspection and test contained in the specifications applicable to this proposal, except where specialized inspections or tests are specified for performance solely by KEYS, contractor shall perform or have performed the inspections and tests required to substantiate that the supplies and services provided under this proposal conform to the drawings, specifications and proposal requirements listed herein, including if applicable, the technical requirements for the manufacturer's part numbers specified herein.
- C. Delivery of Excess Quantities – Contractor is responsible for the delivery of each item quantity within allowable variations, if any. If contractor delivers and KEYS receives quantities of any item in excess of the quantity called for (after considering any allowable variations of quantity) such excess quantities will be treated as being delivered for the convenience of contractor. KEYS may retain such excess quantities without compensating the interests herein. Quantities in excess, will at the option of KEYS, either be returned at contractor's expense, or retained and paid for by KEYS at the contract unit price.
- D. Deliveries – In the event of failure to deliver material of the quality or within the time specified, KEYS may cancel the order and buy elsewhere. Contractor will be responsible for any cost differences encountered in the procurement of materials. Failure of KEYS to exercise this option with respect to any installment shall not be deemed a waiver with respect of future installments, if any.
- E. Delivery tickets – All shipments under this agreement shall be accompanied with delivery tickets, or packing slips, in triplicate, which shall contain the following minimum information: name of supplier, purchase order number, date of order, date of delivery or shipment, itemized list of supplies or services furnished, quantity, unit price, and extension of each line item. Upon delivery, the Warehouse will retain a copy of the related delivery ticket.
- F. Inspection, Acceptance and Title – Inspection and acceptance will be at destination, unless otherwise provided. Title and risk of loss or damage to all items shall be the responsibility of the contract supplier until accepted by KEYS in writing.

ENTIRE AGREEMENT

The terms, specifications and/or drawings included in a duly executed contract will constitute the entire agreement between the parties. No modification or waiver of terms of this agreement shall be binding, unless in writing, signed by a duly authorized representative of KEYS.

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

ERROR IN BID CALCULATION

In the event there is a mathematical error in the bid, KEYS will recalculate using the line items and correct the total.

EXECUTION OF PROPOSAL

If a Proposal is made by a partnership, it shall contain the name and address of each partner and shall be executed in the partnership name, followed by the handwritten signature of a partner authorized to execute the Proposal for the partnership. If a Proposal is made by a corporation, it shall be executed in the name of the corporation, followed by the handwritten signature of an officer authorized to execute the Proposal for the corporation, and the printed or typewritten designation of the office he holds in corporation. Another partner of the partnership or official of the corporation shall attest to the authority of the person executing the Proposal. KEYS may require any Bidder to furnish certified copies of extracts of the minutes of meetings of the governing body of the Bidder authorizing execution of the Proposal and Contract Documents.

FORCE MAJEURE

KEYS shall not be liable in any way to contractor as a result of an event, circumstance or act of a third party that is beyond a party's reasonable control (e.g. an act of God, and act of the public enemy, an act of a government entity, strikes or other labor disturbances, hurricanes, earthquakes, fires, floods, epidemics, embargoes, war and riots).

LITIGATION SEARCH

KEYS reserve the right to conduct a litigation search on contractor's history of past litigation.

LIQUIDATED DAMAGES

In the event the Scope of Work is not substantially complete on or before May 1, 2026, liquidated damages shall be payable by Contractor to KEYS in the amount of \$500.00 per day for each day the Scope of Work is not substantially complete.

The parties recognize that the damages to be incurred by KEYS as a result of delay in completion of the Scope of Work are difficult to estimate at this time and would be difficult for KEYS to prove. The parties intend that the payment of Liquidated Damages set forth above would serve to compensate KEYS for its damages resulting from such delay in completion, and constitutes a reasonable, good faith approximation of such damages. The liquidated damages set forth herein are not intended to, nor shall be construed to, function as a penalty, and shall not preclude other remedies available to KEYS at law or in equity.

MATERIAL

No goods or materials provided pursuant to the proposal shall consist of or contain any equipment which has been manufactured or supplied by persons or entities owned by, controlled by, or subject to the jurisdiction or direction of the government of the People's Republic of China.

MODIFICATION OF PROPOSAL

A modification of a proposal already received will be considered only if the modification is received prior to the time last announced for opening Proposals. All modifications shall be made in writing, executed and submitted in the same form and manner as the original proposal, fax or E-mail. Phone modifications will not be considered.

NOTICE TO PROCEED

KEYS will issue the successful bidder a Notice to Proceed after the following activities have been completed: 1) the Performance Bond and Insurance Certificates have been received and approved by KEYS, 2) a meeting has been held and issues regarding environmental, lien releases, payment procedures, safety, security, and use of sub-contractor notification were discussed. The successful bidder will be asked to complete the signature to acknowledge receipt of this notice.

OPENING PROPOSALS

At the time and place last announced for opening Proposals, each Proposal which has been received prior to the time last announced for opening Proposals, except those which have been properly withdrawn, will be publicly opened and read aloud, irrespective of any irregularities or informalities in such Proposals.

KEYS INSPECTIONS/MEETINGS

KEYS will make inspections and/or meetings as deemed necessary to ensure that all work is being performed in compliance with these specifications and guarantees.

PAYMENT

Payment will be made after acceptance of services and materials and within 30 days after receipt of invoice. KEYS will hold 5% retention until 30 days after project completion and final acceptance. Contractor will complete and submit the provided Contractor's Request for Payment form, prior to any payment of draw request. Contractor's request for payment shall be accompanied by a breakdown of material and labor associated with that particular request. KEYS does not pay service charges on late payments.

PENALTIES

KEYS reserves the right to increase or decrease quantities shown without penalties.

PERFORMANCE BOND

Within ten (10) days after contractor receives the Notice of Utility Board Approval and prior to the execution of the Contract, contractor shall furnish a Performance and Payment Bond in the form acceptable to KEYS, with corporate Surety satisfactory to KEYS such bond shall insure

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

the full and faithful performance of the Contract, including the payment of faithful performance of the Contract, including the payment of all obligations arising there under, and shall be in an amount equal to (one hundred) 100% of the Total Contract Amount unless otherwise provided in these specifications. Such bond shall further comply in all respects with the laws of the State of Florida.

PERSONNEL

- A. The project supervisor must be capable of communicating fluently in English at all times.
- B. On a project, the foreman must be capable of communicating fluently in English.
- C. All employees of company must be United States Citizens or legally authorized to reside and work in the United States.
- D. KEYS may request at any time throughout the contract the following within eight (8) hours:
 - Proof of citizenship for all employees
 - Proof of employee's salary is at or above state and federal minimum requirements
 - Proof of eligibility to legally work in the United States

POSTPONEMENT OF OPENING

KEYS reserves the right to postpone the date and time last announced for opening Proposals and such postponement may be made at any time prior to the time last announced for opening Proposals. KEYS will give written notice in the form of an Addendum by email to each party to whom Contract Documents have been issued in addition to posting the Addendum on DemandStar, Vendorlink, and Keysenergy.com websites, stating the change in date and time of any such postponement.

PRICES

- A. All prices bid shall be firm unless the conditions of the RFP permit price escalation. If an escalation method or indices are specified, the Bidder shall indicate in its bid the specific items subject to escalation, and shall give the method and indices to be used in computing the amount thereof.
- B. The vendor shall provide the proposal price in U.S. dollars only.

PROPOSAL GUARANTEE

- A. The Proposal Guarantee shall be the cashier's check or Bid Bond required in the Notice to Bidders. A bid bond or cashier's check in lieu of a surety bond in the amount of (five) 5% of the proposal shall be submitted with all proposals. This bid bond requirement is to be used as security and will be returned to bidder after KEYS enters into a Contract with the successful bidder. This (five) 5% shall be based on the total bid price. The bid bond or cashier's check shall be valid for a period of no less than 120 days after bid opening date.
- B. KEYS may reject all Proposals, and in such event, all cashier's checks and Bid Bonds will thereupon be returned to the Bidders.
- C. When a Proposal is accepted, all checks and Bid Bonds will thereupon be returned to the bidders, except for the approved proposal. The cashier's check or Bid Bond of the approved Bidder will be returned after completion of the requirements in the following paragraph.
- D. Within (ten) 10 days after delivery of Notice of Utility Board Approval, or such additional time as is allowed by KEYS, the Bidder shall furnish satisfactory Performance and Payment Bond, Insurance Certificate and Insurance Policies.

PROTESTS

Any bidder who believes he has been aggrieved in connection with the staff recommendation or award of a contract may protest in writing to the KEYS Purchasing Department. The deadline for filing a protest is prior to the commencement of the Utility Board meeting wherein the award is to be considered. It is the responsibility of the bidder to ascertain the bid award information from DemandStar or VendorLink. Protests shall specifically describe the subject matter and facts giving rise to the protest.

PUBLIC RECORDS ACT

Pursuant to F.S. 119.0701 of the Public Records Act, any request to inspect or copy public records relating to a public agency's contract for services must be made directly to the public agency. Contractors is required to comply with public records laws and upon request by the public records custodian, shall provide a copy of the requested records or allow the records to be inspected or copied within a reasonable time at a cost not to exceed the cost provided in Ch. 119, F.S. or as otherwise provided by law. A contractor who fails to provide the records to the agency within a reasonable time may be subject to penalties as provided in F.S. 119.10

**IF CONTRACTOR HAS QUESTIONS REGARDING THE APPLICATION OF
CHAPTER 119, FLORIDA STATUTES, TO CONTRACTOR'S DUTY TO
PROVIDE PUBLIC RECORDS RELATING TO THIS CONTRACT, CONTACT
THE CUSTODIAN OF PUBLIC RECORDS AT:**

**KEYS ENERGY SERVICES
P.O. BOX 6100
Key West, FL 33041-6100
(305) 295-1067
Gricel Owen**

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

Email: gricel.owen@keysenergy.com

PUBLIC ENTITY CRIME CLAUSE

Any person submitting a bid or proposal in response to this invitation must execute the enclosed form **FOR 094, SWORN STATEMENT UNDER SECTION 287.133 (3) (a), FLORIDA STATUTES ON PUBLIC ENTITY CRIMES**, including proper check(s), in the space(s) provided, and enclose it with his bid proposal. If you are submitting as bid or proposal on behalf of dealers or suppliers who will ship commodities and receive payment from the resulting contract, it is your responsibility to see that copies of the form are executed by them and are included with your bid or proposal. Corrections to the form will not be allowed after the bid or proposal opening time and date. Failure to complete this form may result in immediate disqualification of your bid or proposal.

QUALITY ASSURANCE PROVISIONS

A system of test and inspection shall be used to insure receipt of the quality and quantity of material(s)/service(s) purchased. Material(s)/service(s) will be promptly inspected and any discrepancies from the purchase order and/or the supplier's invoice shall be reported immediately.

RELEASE OF LIENS

Contractor is to furnish a release of liens for sub-contractual materials and labor prior to each payment. In addition, contractor is to furnish the standard form of "Statement Concerning Claims."

REJECTION

The Utility Board reserves the right to reject any or all proposals, to waive irregularities and informalities in any or all proposals, and to separately accept or reject any item, items, bid schedule or bid schedules of the proposal which the Utility Board deems to be in the best interest of the Utility Board.

RETAINAGE

A 5% retainage fee will be applied to all payment requests.

SAFETY/MAINTENANCE OF TRAFFIC (MOT)

Contractor is to provide all required Safety and Traffic Control equipment as required by FDOT, City of Key West, or Monroe County MOT. Personnel are required to be trained in MOT as required. Contractor is to provide copies of certification of MOT training.

SAFETY AND PROTECTION

Examination of existing facilities: After the Contract is awarded and before commencement of the work, Contractor and KEYS shall make thorough examination of all existing structures and facilities associated with the project.

Safety requirements: Contractor shall do whatever work is necessary for safety and be solely and completely responsible for conditions of the job site, including safety of all persons (including employees) and property during the project period. This requirement shall apply continuously and not be limited to normal working hours.

Safety provisions shall conform to Federal and State Departments of Labor, Occupational Safety and Health Act (OSHA), and other applicable Federal, State, County, and Local Laws, Ordinances, Codes, requirements set forth herein, and regulations that may be specified in other parts of these specifications. Where these are in conflict, the more stringent requirement shall be followed. Contractor shall become thoroughly familiar with governing safety provisions and shall comply with the obligations set forth therein.

Contractor shall develop and maintain for the duration of the project, a safety program that will effectively incorporate and implement required safety provisions of the American Public Power Association (APPA) Safety Manual. Contractor is responsible for obtaining the latest edition of the APPA Safety Manual at their expense from APPA at <http://www.publicpower.org/topics/landing.cfm?ItemNumber=38512>. Contractor shall appoint a qualified employee who is authorized to supervise and enforce compliance with the APPA safety Manual. It is not the responsibility of KEYS to review or police contractor's implementation of the APPA Safety Manual's protocols.

SCOPE OF WORK

While KEYS has tried to anticipate all Work required under and during the term of this contract, the parties understand and agree that the Work required herein may require without notice to contractor, the performance of Extra Work or the omission of Work previously required. KEYS may at any time and without notice to contractor, require changes in the scope of Work under this contract as KEYS may find necessary or desirable. Such changes may include the omission of Work previously required.

- A. KEYS shall notify contractor of the change in scope work via Change Order, which shall become part of the Contract Documents. If a Change Order directs Contractor to omit Work, contractor shall refrain from performing it.
- B. Contractor shall perform Extra Work only pursuant to the issuance by KEYS of Change Order. Records of any Extra Work performed by contractor shall be reviewed daily by contractor and KEYS, duplicate copies of accepted records made and signed by both contractor or his representative and KEYS, and one (1) copy retained by each.

SECURITY/BACKGROUND CHECK

KEYS may require successful bidders to supply a complete listing of all individuals that will perform work at the various sites. KEYS may run DMV and mandatory felony and misdemeanor background checks due to security reasons. The successful bidder must expressly agree to the right for KEYS to run the aforementioned checks.

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

KEYS reserve the right to perform background checks during the entire duration of the contractual agreement. Contractor will advise KEYS immediately of any employee staff changes before they are permitted on-site. Non-compliance of security/background check portion of the bid specifications will result in rejection of the proposal or termination of awarded contractual agreement.

SEVERABILITY

If any of these General Terms & Conditions is determined to be invalid, illegal or enforceable, the remaining provisions of these General Terms & Conditions remain in full force to the extent permitted by law.

SUBCONTRACTORS

Each Bidder shall list on the Proposal form the name of each construction subcontractor who will furnish in excess of 10% of the Project. Failure to do so shall entitle KEYS, at its option, to reject the bid.

SUBMISSION OF PROPOSAL

It is the sole responsibility of each Bidder to deliver its Proposal to KEYS at the place designated for receiving Proposals and prior to the time for opening Proposals last announced to Bidders. Any Proposal received after the time last announced for opening Proposals may be retained by KEYS or returned to the Bidder, but such Proposal shall be rejected as not responsive.

No proposal shall contain Personal Information, as defined in Section 501.171, Florida Statutes, unless specifically requested in the Specifications. In the event Personal Information is received, KEYS shall take appropriate precautions to prevent the release of such Personal Information. Notwithstanding the foregoing, to the extent allowed by applicable law, KEYS shall have no liability for the release to any third party of Personal Information included within any proposal.

SUPPLIER DIVERSITY

KEYS is committed to providing equal opportunities to Minority/Women Business Enterprises (M/WBEs) as well as all other Suppliers, Consultants, Contractors and Subcontractors who seek to do business with KEYS. KEYS attempts to ensure that qualified M/WBEs are made aware of, have an opportunity to bid on, and are considered on an equal basis with all other qualified bidders for the provision of supplies and services.

TAX

The prices of materials set forth herein shall not include state sales tax or local option tax. KEYS is generally exempt from state sales tax, (sales tax number 85-8012621609C-2), and local option tax. However; any purchases of materials for construction of new electrical transmission and distribution facilities are subject to state sales tax and local option tax.

TERMINATION OF CONTRACT FOR CONVENIENCE

When deemed to be in the best interest of KEYS, any awards or contracts resulting from this specification may be terminated by KEYS, in whole or in part, without cause by the delivery of thirty (30) days written notice. Upon receipt of the notice of termination Contractor shall, except as otherwise directed by KEYS: (1) stop work as specified in the notice; (2) place no further subcontracts or orders; (3) terminate all subcontracts to the extent they relate to the work terminated; (4) transfer title and deliver to KEYS all completed work and any completed or partially completed items which, if the contract had been completed, would be required to be transferred to KEYS; and (5) take reasonable actions as directed by KEYS to protect and preserve property in which KEYS has an interest. With regard to the portion of the award or contract so terminated, KEYS shall be liable only for payment under the payment provisions of this contract for services rendered before the effective date of termination, plus the reasonable costs of settlement of the work terminated including with limitation the performance of the above items, and expressly excluding the amount of any settlements made by Contractor with any subcontractors. Without waiver of any rights KEYS may have in law or at equity, KEYS and Contractor shall negotiate in good faith to reach a settlement with regard to damages incurred by KEYS as a result of the breach and any outstanding sums which may be owed to Contractor for work performed for which payment has not been received.

TERMINATION OF CONTRACT FOR CAUSE

In the event Contractor fails to perform any provision of the contract or award as specified herein, KEYS may terminate any award or contract resulting from this specification, in whole or in part, by the delivery of 10 days written notice of default. Upon receipt of the notice of termination Contractor shall, except as otherwise directed by KEYS: (1) stop work as specified in the notice; (2) place no further subcontracts or orders; (3) terminate all subcontracts to the extent they relate to the work terminated; (4) transfer title and deliver to KEYS all completed work and any completed or partially completed items which, if the contract had been completed, would be required to be transferred to KEYS; and (5) take reasonable actions as directed by KEYS to protect and preserve property in which KEYS has an interest. Without waiver of any rights KEYS may have in law or at equity, KEYS and Contractor shall negotiate in good faith to reach a settlement with regard to damages incurred by KEYS as a result of the breach and any outstanding sums which may be owed to Contractor for work performed for which payment has not been received.

WARRANTY

- A. Contractor warrants to KEYS that the Material and/ Equipment to be furnished under the Contract shall be designed and fit for the purpose specified when operated in accordance with contractor's specific operating instructions or, in the absence thereof, in accordance with generally accepted operating practices; free from defects in material, workmanship, and title; shall meet all specifications, including those relating to performance, contained or incorporated by reference in the Contract; and that the technical direction of installation on KEYS' premises when furnished by contractor shall be performed in a competent, diligent manner in accordance with generally accepted professional practices.
- B. The foregoing warranties, except as to title, shall apply to defects or deficiencies occurring within a period of **1** year from Final Acceptance provided the same is not unreasonably delayed by the KEYS or others. If, however, during the above **1** year warranty period the

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

Equipment is not available for operation due to a failure to meet such warranties, such time of unavailability shall not be counted as part of the warranty period. The condition of any field tests shall be mutually agreed upon, and Contractor shall be notified of and may be represented at all tests that may be made.

- C. If the equipment and materials furnished hereunder does not meet the warranties specified above when it has normal and proper use and maintenance, KEYS shall promptly notify contractor and make the Equipment available for correction. Contractor shall thereupon within a reasonable time correct all defects, including nonconformance with the Engineering Specifications, by either repairing or replacing any defective or damaged parts of the Equipment.
The cost of Labor, Materials and Equipment components directly associated with such repair or replacement of the Equipment, including removal, loading and unloading, transportation to and from the repair site and reinstallation, shall be borne by contractor.
- D. Any repaired or replacement part furnished under the foregoing warranty shall carry warranties on the same terms as set forth above for **1** year from the date of its Final Acceptance.
- E. Contractor shall obtain written warranties from its Subcontractors and suppliers of Materials, Labor and Equipment components where such warranties are obtainable and shall deliver the original warranties to KEYS.
- F. Neither the final payment, nor any other provision of the Contract, nor partial or entire use of the Material and Equipment by KEYS shall relieve contractor of liability with respect to the warranties referred to in the Contract or any other warranties, express or implied.

WITHDRAWAL OF PROPOSAL

Each Proposal shall constitute an offer to KEYS as outlined therein and shall be irrevocable after the time last announced for opening Proposals. Any Bidder may withdraw its Proposal by giving written notice to KEYS at the place such Proposals are to be received and at any time prior to the time last announced for opening Proposals. After the time last announced for opening Proposals and until execution of the Contract, no Bidder will be permitted to withdraw its Proposal for a period exceeding 120 days after the time last announced for opening Proposals.

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

INSURANCE SECTION

INDEMNITY AND INSURANCE REQUIREMENTS

By the signing of this contract and these indemnity and insurance requirements, Contractor agrees to abide by the provisions herein below.

INDEMNITY

Contractor shall indemnify, defend and hold harmless KEYS and its officers, partners, agents, employees and servants from and against any and all claims, judgments, liens, loss, damage, cost, charge or expense, including defense costs, court costs and attorneys' fees, whether direct or indirect, by reason of liability imposed by law or by bodily injuries, including death at any time resulting therefrom, sustained by any person or persons or on account of damages to property, including loss of use thereof, arising out of or in consequence of the performance of the Contract, whether such injuries to or death of persons or damages to property are due or are claimed to be due to operations, errors, omissions, or negligent acts of KEYS or any of their officers, partners, agents, employees or servants, excepting only such injuries or damages as shall have been finally determined to have resulted solely from errors, omissions or negligent acts of KEYS or of their officers, partners, agents, employees or servants. Such indemnity shall not be limited by the coverage amounts of any applicable insurance. For this indemnity, the Utility Board of the City of Key West, Florida will pay the sum of ten dollars (\$10.00). The bidder shall add this amount (\$10.00) to their base bid proposal, which will be included in payment to firm.

INSURANCE REQUIREMENTS

The insurance provided by the Contractor pursuant to this Contract shall apply on a primary basis and any other insurance provided by KEYS shall be excess of, and not contributory to, the insurance provided by Contractor. Contractor shall have the responsibility for the payment of all deductibles under all policies required herein.

During the term of this agreement, except as specifically provided herein, Contractor shall provide and maintain, at his sole cost and expense, insurance in the following types and amounts to cover all work under this agreement, including that done by subcontractors. The maintenance of any insurance shall not limit any liability of Contractor under this contract.

The Contractor shall not commence any work on the contract until he has provided KEYS with proof of coverages required, in the form an original certified Certificate of Insurance properly signed by the authorized agent of the insurance company. The insurance company must be an eligible surplus lines company or a company authorized by the Florida State Department of Insurance to sell the specific insurance required or with respect to Workers' Compensation authorized as a group self-insurer by Florida Statue 440.57. The agent of the insurance company must be licensed to sell the insurance coverages required under this contract. Without limiting any of the other obligations or liabilities of Contractor, the following insurance coverages with indicated limits of liability are mandatory under this contract. Those coverages with no limits shown are not required.

CONTRACTOR'S ENVIRONMENTAL IMPAIRMENT RESPONSIBILITY

- A. Contractor acknowledges that the performance of this contract is, or may be, subject to Federal, State, and Local laws and regulations enacted for the purpose of protecting, preserving, or restoring the environment. The Contractor shall, at his sole cost, will be responsible for full compliance with any such laws or regulations.
- B. The Contractor's performance under this contract shall include, but not be limited to:
 - 1. Performance in a manner to minimize disturbance of or damage to the environment.
 - 2. To the extent caused by the performance of this contract by or on behalf of the Contractor, the clean-up, repair or restoration of the environment to the extent required by any Federal, State, or Local laws or regulations.
- C. The Contractor shall be responsible for any fines, penalties, damage, or assessments made against the Contractor or KEYS resulting from the performance of this contract by or on behalf of the Contractor.
- D. The Contractor's obligation under paragraph B and C above shall survive the term of the contract and shall not be limited in any manner by acceptances of final payments.

COMMERCIAL GENERAL LIABILITY INSURANCE

This insurance shall cover those sources of liability which would be covered by the latest edition of the standard Commercial General Liability Coverage Form as published by the Insurance Services Office (ISO) as filed for use in Florida without the attachment of restrictive endorsements other than the elimination of medical payments and fire damage legal liability.

General Aggregate	\$ 2,000,000.00
Limit of Insurance <u>per Project</u>	
Products/Completed Operation	\$ 2,000,000.00
Coverage for 3 yrs. after contract completion	
Personal & Advertising Injury	\$ 1,000,000.00
Each Occurrence	\$ 1,000,000.00

BUSINESS AUTOMOBILE POLICY

This insurance shall cover those sources of liability which would be covered by Part IV of the latest edition of the standard business auto policy form (ISO) as filed for use in Florida without attachments of restrictive endorsements. Coverage's shall include owned, non-owned, and hired autos.

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

The policy shall be endorsed to include coverage as required by Section 29 and 30 of the Motor Carrier Act of 1980 (MCS 90).

Each Occurrence Bodily Injury and Property Damage Liability Combined \$ 1,000,000.00

WORKERS COMPENSATION AND EMPLOYER'S LIABILITY INSURANCE

Contractor shall maintain Workers' Compensation insurance consistent with obligations imposed by federal and state law applicable to and having jurisdiction over Contractor's employees engaged in the performance of work under this Contract. Contractor shall maintain Employer's Liability of not less than the following amounts:

Each Accident	\$ 1,000,000.00
Disease-Policy Limit	\$ 1,000,000.00
Disease-Each Employee	\$ 1,000,000.00

Additionally, if there will be operations undertaken on or about navigable waters, a coverage endorsement must be included for the U.S. Longshoremen & Harbor Workers Act and Jones Act. If exempt for Worker's Compensation, proper documentation shall be provided.

ADDITIONAL INSURED

The Utility Board of the City of Key West, Florida shall be included as an additional insured for Comprehensive General Liability Form (ISO).

WAIVER OF SUBROGATION

Contractor's Commercial General Liability and Workers Compensation insurance shall include a Waiver of Transfer of RIGHTS OF Recovery against others to KEYS (ISO Form). The Utility Board of the City of Key West, Florida must be named in the schedule for the specific project involved.

POLLUTION LIABILITY INSURANCE

Pollution Liability Insurance for bodily injury, property damage, clean-up costs or corrective action and defense coverage with a limit of no less than Five Million Dollars (\$5,000,000.00) each incident and a general aggregate limit of no less than Five Million Dollars (\$5,000,000.00). This insurance shall include coverage for, but not be limited to; sudden and accidental discharges; dispersal; seepage; release or escape of any solid, liquid gaseous or thermal irritant or contaminant, including but not limited to smoke, vapors, soot, fumes, acids, alkalis, toxic chemicals, medical waste and waste material into or upon land or any structure on land, the atmosphere or any watercourse or body of water, including groundwater.

WATERCRAFT LIABILITY INSURANCE

Watercraft Liability Insurance for owned, non-owned, and hired craft is required when any such craft is used by the Contractor in performance of work under this Contract. The limits of liability will be determined by KEYS and will not be less than Five Million Dollars (\$5,000,000.00) each occurrence. In no event will watercraft be used in the performance of work hereunder by the Contractor or any subcontractor without the prior written consent of KEYS.

**KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE
CORROSION PROTECTION**

INSURANCE AGENT'S STATEMENT

I have reviewed the above requirements with the bidder named below. The following limits apply to the corresponding policy for the following company:

DATE: _____ FIRM NAME: _____

POLICY (Type /Number)

LIMITS

Acknowledgement of the additional insured and waiver of subrogation requirements: _____
Initials

Liability policies are _____ Occurrence _____ Claims Made

Name of Insurance Agency

Signature of Insurance Agent

SUBMITTED BY: _____
Print Name & Title

NOTE: EACH BIDDER SHALL PROVIDE A COPY OF COMPLETED CERTIFICATE OF INSURANCE COMPLYING WITH THE AFOREMENTIONED INSURANCE REQUIREMENTS OR SIGN AND DATE THE ABOVE INSURANCE AGENT'S STATEMENT AND AGREE TO PROVIDE A VALID CERTIFICATE OF INSURANCE UPON NOTIFICATION OF CONTRACT AWARD.

**KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE
CORROSION PROTECTION**

BIDDER'S STATEMENT

In consideration of this contract, if awarded, the Contractor agrees without reservation to KEYS' Terms & Conditions, Indemnification Clause, and insurance clause herein. The signing of this statement confirms the Contractor's acceptance, which will become a part of the contract.

DATE: _____

FIRM NAME: _____ EMAIL: _____

SUBMITTED BY: _____
Print Name & Title

SIGNATURE: _____

WITNESS: _____

**NOTICE: THIS SIGNATURE PERTAINS TO THE ACKNOWLEDGEMENT AND
ACCEPTANCE OF THE ENTIRE TERMS & CONDITIONS. ANY EXCEPTIONS TO
THIS AGREEMENT SHOULD BE NOTED SEPARATELY.**

**FAILURE TO COMPLETE ABOVE NOTED DOCUMENT WILL RESULT IN
NON-COMPLIANCE WITH THESE SPECIFICATIONS.**

**KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE
CORROSION PROTECTION**

KEYS ENERGY SERVICES
SAFETY COMPLIANCE AFFIDAVIT

Keys Energy Services (KEYS) requires all Contractors to follow the American Public Power Association (APPA) Safety Manual while working for KEYS on all projects.

It is solely Contractor's Responsibility to:

1. Obtain the latest edition of the APPA Safety Manual at their expense from the American Public Power Association (<http://www.publicpower.org/Topics/Landing.cfm?ItemNumber=38512>)
2. Comply to the required safety protocols described in the APPA Safety Manual – for contractor's employees and sub-contractors;
3. Appoint a qualified employee who is authorized to monitor, supervise and ensure compliance to APPA Safety Manual's protocols on the job site and
4. Do whatever is necessary for safety compliance and be solely and completely responsible for conditions of the job site, including safety of all persons and property during the project's duration.

It is not the responsibility of KEYS to review or police Contractor's implementation of the APPA Safety Manual's protocols.

As the person authorized to sign this affidavit, I certify that this firm understands and will fully comply with the above requirements.

Company Name: _____

Representative's Printed Name: _____

Representative's Signature: _____

Date Signed: _____

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

DRUG-FREE WORKPLACE STATEMENT

Preference shall be given to businesses with drug-free workplace programs. Whenever two or more bids which are equal with respect to price, quality, and service are received by the State or by any political subdivision for the procurement of commodities or contractual services, a bid received from a business that certifies that it has implemented a drug-free workplace program shall be given preference in the award process. Established procedures for processing tie bids will be followed if none of the tied vendors have a drug-free workplace program. In order to have a drug-free workplace program, a business shall:

The undersigned vendor in accordance with Florida Statutes Section 287.087 hereby certifies that

_____ does:

(Name of Business)

1. Publish a statement notifying employees that the unlawful manufacture, distribution, dispensing, possession, or use of a controlled substance is prohibited in the workplace and specifying the actions that will be taken against employees for violations of such prohibition.
2. Inform employees about the dangers of drug abuse in the workplace, the business's policy of maintaining a drug-free workplace, any available drug counseling, rehabilitation, and employee assistance programs, and the penalties that may be imposed upon employees for drug abuse violations.
3. Give each employee engaged in providing the commodities or contractual services that are under bid a copy of the statement specified in Subsection 1.
4. In the statement specified in Subsection 1, notify the employees that, as a condition of working on the commodities or contractual services that are under bid, the employee will abide by the terms of the statement and will notify the employer of any conviction of, or plea of guilty or nolo contendere to, any violation of Chapter 1893 or of any controlled substance law of the United States or any state, for a violation occurring in the workplace no later than five (5) days after such conviction.
5. Impose a sanction on, or require the satisfactory participation in a drug abuse assistance or rehabilitation program if such is available in the employee's community, by any employee who is so convicted.
6. Make a good faith effort to continue to maintain a drug-free workplace through implementation of this section.

As the person authorized to sign the statement, I certify that this firm complies fully with the above requirements.

Print Name _____

Vendor's Signature _____

Date: _____

**KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE
CORROSION PROTECTION**

**SWORN STATEMENT PURSUANT TO SECTION 287.133(3)(a),
FLORIDA STATUTES, ON PUBLIC ENTITY CRIMES**

THIS FORM MUST BE SIGNED AND SWORN TO IN THE PRESENCE OF A NOTARY PUBLIC OR OTHER OFFICIAL AUTHORIZED TO ADMINISTER OATHS:

1. This sworn statement is submitted to _____
(print name of public entity)

by _____
(print individual's name and title)

for _____
(print name of entity submitting sworn statement)

whose business address is _____

and (if applicable) its Federal Employer Identification Number (FEIN) is _____

If the entity has no FEIN, include the Social Security Number of the individual signing sworn statement: _____

2. I understand that a "public entity crime" as defined in Paragraph 287.133(1)(g), Florida Statutes, means a violation of any state or federal law by a person with respect to and directly related to the transaction of business with any public entity or with an agency or political subdivision of any other state or of the United States, including, but not limited to, any bid or contract for goods or services to be provided to any public entity or an agency or political subdivision of any other state or of the United States and involving antitrust, fraud, theft, bribery, collusion, racketeering, conspiracy, or material misrepresentation.
3. I understand that "convicted" or "conviction" as defined in Paragraph 287.133(1)(b), Florida Statutes, means a finding of guilt or a conviction of a public entity crime, with or without an adjudication of guilt in any federal or state trial court of record relating to charges brought by indictment or information after July 1, 1989, as a result of a jury verdict, nonjury trial, or entry of a plea of guilty or nolo contendere.
4. I understand that an "affiliate" as defined in Paragraph 287.133(1)(a), Florida Statutes, means:
 - a. A predecessor or successor of a person convicted of a public entity crime; or
 - b. An entity under the control of any natural person who is active in the management of the entity and who has been convicted of a public entity crime. The term "affiliate" includes those officers, directors, executives, partners, shareholders, employee, members, and agents who are active in the management of an affiliate. The ownership by one person of shares constituting a controlling interest in another person, or a pooling of equipment or income among persons when not for fair market value an arm's length agreement, shall be a prima facie case that one person controls another person. A person who knowingly enters into a joint venture with a person who has been convicted of a public entity crime in Florida during the preceding 36 months shall be considered an affiliate.
5. I understand that a "person" as defined in Paragraph 287.133(1)(e), Florida Statutes, means:

**KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE
CORROSION PROTECTION**

- a. any natural person or entity organized under the laws of any state or of the United States with the legal power to enter into a binding contract and which bids or applies to bid on contracts for the provision of goods or services let by a public entity, or which otherwise transacts or applies to transact business with a public entity.
 - b. The term "person" includes those officers, directors, executives, partners, shareholders, employees, members, and agents who are active in management of an entity.
6. Based on information and belief, the statement, which I have marked below, is true in relation to the entity submitting this sworn statement. (Please indicate which statement applies):

_____ Neither the entity submitting this sworn statement, nor any of its officers, directors, executives, partners, shareholders, employees, members, or agents who are active in the management of the entity, nor any affiliate of the entity has been charged with the convicted of a public entity crime subsequent to July 1, 1989.

_____ The entity submitting this sworn statement, or one or more of its officers, directors, executives, partners, shareholders, employees, members, or agents who are active in the management of the entity, nor any affiliate of the entity has been charged with and convicted of public entity crime subsequent to July 1, 1989.

_____ The entity submitting this sworn statement, or one or more of its officers, executives, partners, shareholders, employees, members, or agents who are active in the management of the entity, or an affiliate of the entity has been charged with and convicted of a public entity crime subsequent to July 1, 1989. However, there has been a subsequent proceeding before a Hearing Officer of the State of Florida, Division of Administrative Hearings and the Final Order entered by the Hearing Officer, determined that it was not in the public interest to place the entity submitting this sworn statement on the convicted vendor list. (Attach a copy of the final order).

I UNDERSTAND THAT THE SUBMISSION OF THIS FORM TO THE CONTRACTING OFFICER FOR THE PUBLIC ENTITY IN PARAGRAPH ONE (1) ABOVE IS FOR THAT PUBLIC ENTITY ONLY AND, THAT THIS FORM IS VALID THROUGH DECEMBER 31 OF THE CALENDAR YEAR IN WHICH IT IS FILED. I ALSO UNDERSTAND THAT I AM REQUIRED TO INFORM THE PUBLIC ENTITY PRIOR TO ENTERING INTO A CONTRACT IN EXCESS OF THE THRESHOLD AMOUNT PROVIDED IN SECTION 287.017, FLORIDA STATUTES FOR CATEGORY TWO OF ANY CHANGE IN THE INFORMATION CONTAINED IN THIS FORM.

(Signature)

(Date)

STATE OF _____

COUNTY OF _____

PERSONALLY APPEARED BEFORE ME, the undersigned authority, _____

who, after first being sworn by me, affixed his/her signature in the space provided above on this _____ day of _____ of 20____.

NOTARY PUBLIC

My Commission Expires: _____

STAMP:

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

PAYMENT PROCEDURES & RELATED FORMS

Payments:

Contractor is required to submit the following documents:

- Breakdown of Material and Labor
- "Contractor's Request For Payment"
- "Sworn Statement Concerning Claims"
- "Release Of Lien"

"Contractor's Affidavit and Request for Payment"

Complete this form for work completed to date. Attach appropriate documentation to support this request. Retainage of not less than 5% will be deducted until final inspection by KEYS has been completed and all items are satisfactory. It must be signed by a corporate official and be notarized and signed by the notary.

"Sworn Statement Concerning Claims"

The prime contractor must complete this form for each sub-contractor. This must be done each time a request for payment is made. It must be signed by a corporate official, contain the raised corporate seal, be notarized and signed by the notary.

"Release Of Lien"

The prime contractor is responsible for obtaining and forwarding a release of lien for every sub-contractor on the job, which is to be submitted with each invoice. This is only required when there is a sub-contractor. The release of lien must be unconditional and must contain a date from the sub-contractor, which coincides with the date of the payment request. It must be signed by a corporate official, contain the raised corporate seal, be notarized and signed by the notary.

Final Payments:

Contractor is required to submit the following documents:

- Breakdown of Material and Labor
- "Contractor's Request For Payment"
- "Sworn Statement Concerning Claims"
- "Final Release Of Lien"
- "Contractor's Affidavit Of Contract Completion"

"Contractor's Affidavit and Request for Payment"

Complete this form. Attach appropriate documentation to support this request.

"Final Release Of Lien"

The prime contractor is responsible for obtaining and forwarding a final release of lien for every sub-contractor on the job, which is to be submitted with each invoice. This is only required when there is a sub-contractor. The release of lien must be unconditional. It must be signed by a corporate official, contain the raised corporate seal, be notarized and signed by the notary.

"Contractor's Affidavit Of Contract Completion"

The prime contractor must complete this form. It must be signed by a corporate official, contain the raised corporate seal, be notarized and signed by the notary.

A sample of each of these forms follows.

Each payment request packet is sent to accounts.payable@keysenergy.com for processing.

APPLICATION AND CERTIFICATE FOR PAYMENT			
TO	Accounts Payable	BID NO.	
	Keys Energy Services	CONTRACT NO.	
	accounts.payable@keysenergy.com	PROJECT TITLE	
FROM	Contractor Name	PURCHASE ORDER NO.	
	Contractor Address	APPLICATION NO.	
	Contractor City, State Zip	WORK PERIOD	
	Contractor Number and Email	INVOICE DATE	
CONTRACTOR'S APPLICATION FOR PAYMENT			
1	Original Contract Total		
2	Total of Change Orders to Date		
3	Contract Total (line 1 +2)		
4	Total Amount Completed to Date		
5	Retainage (5% of line 4)		
6	Total Earned less Retainage (line 4 - line 5)		
7	Less Previous Payment Requests (line 6 from previous payment request)		
8	Current Payment Due		
9	Balance to Finish, Plus Retainage (line 3 - line 6)		
<p>We hereby represent that the above contractor's request is a true estimate of work completed under the above contract to date and hereby release KEYS from any claims for materials or labor furnished or expense incurred to date which is not included in requests and payment to date, except for integrated units of construction partially completed for which no request for payment has been made.</p>		FOR KEYS USE ONLY	
Signature		Notice to Owner received?	
Printed Name, Title		Release of Lien received, if applicable?	
Date		Sworn Statement Concerning Claims received?	
		Contractor's Affidavit of Completion received, if applicable?	
		Quantities Verified?	
		Price Verified?	
		Release Retainage, if applicable?	
		Purchasing Supervisor, Date	Project Manager, Date

Routing: Contractor > Accounts Payable > Purchasing > KEYS Project Manager > Accounts Payable

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

UTILITY BOARD OF THE CITY OF KEY WEST, FLORIDA
SWORN STATEMENT CONCERNING CLAIMS

PROJECT AND TITLE: _____

SUB -CONTRACTOR: _____

CONTRACT FOR: _____

CONTRACT DATE: _____ CONTRACT AMOUNT: \$ _____

To: Utility Board of the City of Key West ("Keys Energy Services")

Post Office Box 6100

Key West, Florida 33041

In response to your demand, the undersigned contractor or material man _____
_____ submits the following statement of account for:

(Sub Contractor Name) _____

Labor performed to date consists of the following: _____
_____.

Material furnished to date consists of the following: _____
_____.

Labor still to be performed consists of the following: _____
_____.

Material still to be furnished consists of the following: _____
_____.

Amount paid on account to date: \$ _____, Amount now due: \$ _____,

Amount to become due: \$ _____.

[Signature]

[Date]

The State of _____

County of _____

_____, being first duly sworn, deposes and states that _____ [he or she] is the lien holder named in the forgoing statement of account; that _____ [he or she] has read the statement of account and has knowledge of its contents; that the statements contained in the statement of account are true; and that the sum of \$ _____ as set forth in the statement of account is due and owing to lien holder.

Contractor(s), who, being by me duly sworn, subscribed to the foregoing affidavit in my presence.

(Notary Public)

Print Name: _____

My Commission Expires: _____

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

UTILITY BOARD OF THE CITY OF KEY WEST, FLORIDA
CONDITIONAL RELEASE OF LIEN

PROJECT AND TITLE: _____

SUB -CONTRACTOR: _____

CONTRACT FOR: _____

CONTRACT DATE: _____ CONTRACT AMOUNT: \$ _____

To: Utility Board of the City of Key West ("Keys Energy Services")

Post Office Box 6100

Key West, Florida 33041

KNOW ALL MEN BY THESE PRESENTS:

That the undersigned, upon future payment of the sum \$ _____
and _____ (\$ _____) paid by _____ the
prime contractor, will be deemed to have fully released and quit claimed to The Utility Board of the City of
Key West, the KEYS, all liens, lien rights, claims or demands of any kind whatsoever, which the undersigned
now has or might have against the project on account of labor performed and/or material furnished by the
undersigned in the construction of said project through _____.

In witness whereof, I have hereunto set my seal this _____ day of _____, 20____.

Witness:

_____ (SEAL)

by _____

The State of _____

County of _____

_____, being first duly sworn, deposes and states that _____ [he or she] is the lien
holder named in the forgoing statement of account; that _____ [he or she] has read the statement of
account and has knowledge of its contents; that the statements contained in the statement of account are
true; and that the sum of \$ _____ as set forth in the statement of account is due and owing to lien
holder.

Contractor(s), who, being by me duly sworn, subscribed to the foregoing affidavit in my presence.

(Notary Public)

Print Name: _____

My Commission Expires: _____

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

UTILITY BOARD OF THE CITY OF KEY WEST, FLORIDA
RELEASE OF LIEN

PROJECT AND TITLE: _____

SUB -CONTRACTOR: _____

CONTRACT FOR: _____

CONTRACT DATE: _____ CONTRACT AMOUNT: \$ _____

To: Utility Board of the City of Key West ("Keys Energy Services")

Post Office Box 6100

Key West, Florida 33041

KNOW ALL MEN BY THESE PRESENTS:

That the undersigned, for and in consideration of payment of the sum \$ _____ and _____ (\$ _____) paid by _____ the prime contractor, receipt of which is hereby acknowledged, hereby releases and quit claims to The Utility Board of the City of Key West, the KEYS, all liens, lien rights, claims or demands of any kind whatsoever, which the undersigned now has or might have against the project on account of labor performed and/or material furnished by the undersigned in the construction of said project have been fully paid for.

In witness whereof, I have hereunto set my seal this _____ day of _____, 20____.
Witness:

by _____ (SEAL)

The State of _____

County of _____

_____, being first duly sworn, deposes and states that _____ [he or she] is the lien holder named in the forgoing statement of account; that _____ [he or she] has read the statement of account and has knowledge of its contents; that the statements contained in the statement of account are true; and that the sum of \$ _____ as set forth in the statement of account is due and owing to lien holder.

Contractor(s), who, being by me duly sworn, subscribed to the foregoing affidavit in my presence.

(Notary Public)
Print Name: _____
My Commission Expires: _____

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

UTILITY BOARD OF THE CITY OF KEY WEST, FLORIDA
****FINAL** RELEASE OF LIEN**

PROJECT AND TITLE: _____

SUB -CONTRACTOR: _____

CONTRACT FOR: _____

CONTRACT DATE: _____ CONTRACT AMOUNT: \$ _____

To: Utility Board of the City of Key West ("Keys Energy Services")

Post Office Box 6100

Key West, Florida 33041

KNOW ALL MEN BY THESE PRESENTS:

That the undersigned, for and in consideration of payment of the sum \$ _____ and _____ (\$ _____) paid by _____ the prime contractor, receipt of which is hereby acknowledged, hereby releases and quit claims to The Utility Board of the City of Key West, the KEYS, all liens, lien rights, claims or demands of any kind whatsoever, which the undersigned now has or might have against the project on account of labor performed and/or material furnished by the undersigned in the construction of said project have been fully paid for.

In witness whereof, I have hereunto set my seal this _____ day of _____, 20____.
Witness:

by _____ (SEAL)

The State of _____

County of _____

_____, being first duly sworn, deposes and states that _____[he or she] is the lien holder named in the forgoing statement of account; that _____[he or she] has read the statement of account and has knowledge of its contents; that the statements contained in the statement of account are true; and that the sum of \$ _____ as set forth in the statement of account is due and owing to lien holder.

Contractor(s), who, being by me duly sworn, subscribed to the foregoing affidavit in my presence.

(Notary Public)
Print Name: _____
My Commission Expires: _____

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

**UTILITY BOARD OF THE CITY OF KEY WEST, FLORIDA
KEYS ENERGY SERVICES**

CONTRACTOR'S AFFIDAVIT OF CONTRACT COMPLETION

PROJECT AND TITLE: _____

CONTRACTOR: _____

CONTRACT FOR: _____

CONTRACT DATE: _____ CONTRACT AMOUNT: _____

CONTRACTOR'S AFFIDAVIT

I solemnly swear and affirm: That the work under the above named Contract and all amendments thereto have been completed in accordance with the requirements of said Contract; that all costs incurred for equipment, materials, labor, and services against the project have been paid; that no liens have been attached against the project; that no suits are pending by reason of work on the project under the Contract; that all Workmen's Compensation claims are covered by Workmen's Compensation insurance as required by law; that all public liability claims are adequately covered by insurance, and that contractor shall save, protect, defend, indemnify and hold the KEYSs harmless from and against any and all claims which arise as a direct or indirect result of any transaction, event or occurrence related to performance of the work contemplated under said Contract.

CONTRACTOR:

_____ (SEAL)

Title: _____

Date: _____

STATE OF _____

COUNTY OF _____

Personally appeared before me this _____ day of _____, 20____, _____ known
(or made known) to me to be the:

(Partner)

(Corporate Officer-Title)

(Name of Contractor(s))

Contractor(s), who, being by me duly sworn, subscribed to the foregoing affidavit in my presence.

(Notary Public)

Print Name: _____

My Commission Expires: _____

Per attached Sworn Statement(s) Concerning Claims

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

Proposal Page 1 of 2

(Please type or print all information)

Pursuant to and in compliance with your advertisement for bids and other contract documents relating thereto, the undersigned bidder, having familiarized himself with the terms and conditions affecting the performance of the contract contained in the specifications, hereby proposes and agrees to perform within the contract documents, schedules, and specifications for the following amounts.

UNIT PRICE BID SCHEDULE - BASE BID					
Item	Description	Unit	Estimated Qty	Unit Price	Total Price
1	Mobilization/Demobilization	1	1	\$	\$
2	Line-7 Surface cleaning, surface preparation, and coating (90 structures)	EA	90	\$	\$
3	Line-6 Surface cleaning, surface preparation, and coating (25 structures)	EA	25	\$	\$
4	Line-9 Surface cleaning, surface preparation, and coating (11 structures)	EA	11	\$	\$
5	Line-8 Surface cleaning, surface preparation, and coating (15 structures)	EA	15	\$	\$
6	Line-11 Surface cleaning, surface preparation, and coating (1 structure)	EA	1	\$	\$
7	Line-3 Surface Full Pole cleaning, surface preparation, and coating (7 structures)	EA	7	\$	\$
8	Line-5 Surface Full Pole cleaning, surface preparation, and coating (6 structures)	EA	6	\$	\$
9	Appendix A: Praxel's Recommendations 1 & 2	EA	54	\$	\$
10	Spare Material	EA	1	\$	\$
11	Drawings Package	EA	1	\$	\$
12	Indemnity Fee				\$ 10.00
13	Total Project Estimated Cost (line 1+2+3+4+5+6+7+8+9+10+11+12)				\$

KEYS BID 19-25 SPECIFICATIONS FOR TRANSMISSION STEEL POLE CORROSION PROTECTION

Proposal Page 2 of 2

In addition to the proposal pages, Bidders shall submit the following:

- i. Equipment list and staging plan for work to be performed.
- ii. List of qualified personnel to perform inspection and review of work. Do not include identification cards or personal information.
- iii. Preliminary Project Schedule
- iv. Hourly rate sheets for both labor and equipment to be used should additional work/material outside of the scope of work is required.

Company: _____

Contact Person: _____

Address: _____

Telephone: _____

Email: _____

Subcontractor(s) : _____

Submitted by: _____

(Signature and Print Name)

Bid Bond Enclosed (Yes / No) or Cashier's Check: \$ _____

KEYS reserves the right to accept and/or reject any proposal or any portion of a proposal. Bidder shall submit with the proposal any constraints, if any.