



TRANSMISSION &
DISTRIBUTION
ELECTRIC RELIABILITY
REPORT
CALENDAR YEAR 2025

Contents

- KEYS Reliability report cover page 1
- Reliability Program Overview..... 3
- Reliability Program Summary..... 4
- Reliability Indices Summary 5
- Outage Statistics Overview 8
- System improvement reliability plans 9
 - Keys Indices Analysis..... 10
- SAIDI & MAIFI Statistical Overview 11
- Transmission Outage SAIDI Statistic 12
- Distribution Outage Indices 13
 - Muni & IOU indices comparison..... 16
- Keys 2025 distribution reliability summary 17
- Florida muni’s vs. investor owned 18
- Industry indices comparison 19
 - Transmission & Distribution outage analysis 25
- Transmission Outages 26
- 2025 Transmission Outage Detail 28
- Distribution Outages 29



RELIABILITY PROGRAM OVERVIEW

Tracking and measuring the reliability of KEYS' Transmission & Distribution electric system is an important means for KEYS to gauge its performance, evaluate procedures and ensure a high level of service for customers.

KEYS monitors reliability by tracking the number, cause, and location of the outages, as well as the number of customers impacted and length of time.

KEYS uses data to identify potential areas for improvement, such as enhanced tree trimming and vegetation management; call out procedures and response of line crew and updated changes to field equipment/material. The tracked data is also useful for KEYS to determine 1) where funds should be spent and 2) when funds are needed to improve reliability related to the types of outages experienced.

This information is also used to calculate several reliability indices used in the electric utility industry to evaluate reliability performance. These indices help standardize data and allow KEYS to compare its reliability performance to other utilities.

In Florida, Investor Owned Utilities (IOUs) are required to submit an annual Distribution Service Reliability Report to the Florida Public Service Commission (FPSC) as required under Rule 25-6.0455. The PSC uses this information to track service levels and identify any trends or areas in need of attention.

FMPA has been collecting and compiling distribution reliability measurement data from participating municipal electric utilities since 2003. KEYS along with other participating utilities submit distribution reliability data and receive a group report each month. Participants are able to compare performance with other municipals who participate. The FMPA data enables KEYS to compare and benchmark to other Florida utilities. KEYS collects outage data using our own outage tracking and management systems.

The data includes the following:

- Number of customer minutes interrupted
- Total number of customers served
- Total number of customer interruptions
- Sum of all customer momentary events
- Total minutes of interruption
- Total number of outages
- Cause of outages
- Type of outage- overhead, underground

From this data, the reliability indices are calculated – SAIDI, CAIDI, SAIFI, MAIFI, L- Bar.



RELIABILITY PROGRAM SUMMARY

In an effort to mirror the data from the Florida Investor Owned Utilities (IOUs) as closely as possible, the participating municipal utilities, including KEYS, report their data using the same definitions and guidelines required by the Public Service Commission. Chapter 25-6.044 FAC includes the definitions used by the IOUs for the collection and submittal of the distribution reliability data.

Program guideline definitions:

Service Interruption (outage): The complete loss of voltage for at least one minute to a retail customer

Service Interruption Duration: The time interval, in minutes, beginning when a utility first becomes aware of a service interruption to a retail customer and ending at the time of restoration of service.

Planned Service Interruption: A service interruption initiated by the utility to perform necessary scheduled activities, such as maintenance, infrastructure improvements, and new construction due to customer growth. Customers are typically notified in advance of the event.

Momentary Interruption: Complete loss of voltage for less than one minute. This does not include short duration phenomena causing waveform distortion.

In addition to the definitions, KEYS and the other participating Florida Municipal Utilities have also adopted the exclusions provided in Chapter 25-6.0455 FAC. As provided in this section, IOU's may exclude from their Annual Distribution Service Reliability Report outage events directly caused by one or more of the following:

- ✓ *Planned interruptions*
- ✓ *A planned load management event*
- ✓ *An electric generation or transmission event*
- ✓ *A storm named by the National Weather Service*
- ✓ *An extreme weather or fire event causing activation of the county Emergency Operations Center*



RELIABILITY INDICES SUMMARY

In 2006 the Florida Public Service Commission (FPSC) revised the rules to require IOUs to submit an “actual” Annual Distribution Service Reliability Report which lists all outages experienced by the utility as well as an “adjusted” report, which excludes certain service interruptions (outages). For example, in 2025, there were three National Weather Center named storms, Tropical Storm Debby, Hurricane Helene and Hurricane Milton that affected KEYS service area that could have resulted in excluded distribution reliability data.

There are several indices used in the electric utility industry to track and monitor distribution reliability. The KEYS Distribution Reliability program includes the **SAIDI**, **CAIDI**, **SAIFI**, **MAIFI**, **L-Bar** and **ASAI%**. An overview of each of the indices is below:

SAIDI- System Average Interruption Duration Index

SAIDI measures the average duration of interruptions for the average customer.

SAIDI is calculated by taking the sum of all customer interruption durations, in minutes, and dividing it by the total number of customers served.

$$\text{SAIDI} = \frac{\text{Sum of all Customer Minutes Interrupted (CMI)}}{\text{Total number of customers served (C)}}$$

The unit of SAIDI is time (minutes). SAIDI can be stated as: “On average for the year customers of the distribution system were out of service for ____ minutes.”

For example, if Utility X has a CMI of 10,000 annual minutes and 1,000 customers served (C), then the SAIDI for Utility X is 10 minutes per year.

CAIDI- Customer Average Interruption Duration Index

CAIDI is the average time required to restore service to the average customer per sustained interruption.

CAIDI is calculated by dividing the sum of all customer minutes interrupted by the total number of customer interruptions.

$$\text{CAIDI} = \frac{\text{Sum of all Customer Minutes Interrupted (CMI)}}{\text{Total number of customer interruptions (CI)}}$$

The unit of CAIDI is time (minutes). CAIDI can be stated as: “The average customer that experiences an outage on the distribution on the distribution system is out for ____ minutes.”

For example, if Utility X has a CMI of 10 minutes and a CI of 2, then the CAIDI is 5 minutes.

SAIFI- System Average Interruption Frequency Index

SAIFI measures the average frequency of interruptions for the average customer.

SAIFI is calculated by taking the total number of customer interruptions and dividing it by the total number of customers served.

$$\text{SAIFI} = \frac{\text{Total number of customer interruptions (CI)}}{\text{Total number of customers served (C)}}$$

The unit measurement of SAIFI is interruptions. SAIFI can be stated: "On average, customers on the distribution system experienced ____ service interruptions."

For example, if Utility X has an annual CI of 2,000 and 1,000 customers, then the SAIFI for Utility X is 2 interruptions per year for the average customer.

MAIFI- Momentary Average Interruption event Frequency Index

MAIFI measures the average frequency of momentary interruptions for the average customer.

MAIFI is calculated by taking the total number of the customer momentary interruption events and dividing it by the number of customers served.

$$\text{MAIFI} = \frac{\text{Total number of customer momentary interruption events (CME)}}{\text{Total number of customers served (C)}}$$

The unit of MAIFI is "momentary interruptions." MAIFI can be stated: "On the average, customers on the distribution system experienced ____ momentary interruptions." For example, if Utility X has an annual CME of 5 and 1,000 customers, then the MAIFI is .005.

For FMPA participants a momentary event is defined as an interruption that lasts less than one minute. All momentary interruptions associated with the same event are considered to be ONE momentary interruption event. For example, events that result in multiple operations of a recloser (multiple momentary events) are considered one momentary event. This is true even if the resulting total time of the events is greater than one minute. MAIFI is like SAIFI, where SAIFI tracks the frequency of sustained interruptions and MAIFI tracks the frequency of momentary interruptions.

L-BAR

L-Bar is the average length of a single service interruption (outage).

L Bar is calculated by taking the sum of the length of each service interruption and dividing by the number of sustained interruptions. Momentary interruptions are not included in the L-Bar calculation.

$$\text{L Bar} = \frac{\text{Minutes of interruption}}{\text{Total number of interruptions greater than one minute}}$$

The unit of L Bar is time (minutes). L Bar can be stated as: "On average, sustained interruptions on the system have a duration of ___ minutes." For example, if Utility X has 1440 minutes of service interruption and 100 interruptions, then their L- Bar is 14.4 minutes.

ASAI- Average Service Availability Index

ASAI measures the percentage of time electric service is available to customers over a given period (1 year).

ASAI is calculated by taking the total number of the customer minutes of service availability divided by the total customer minutes requested.

$$\text{ASAI} = 1 - \frac{\text{SAIDI (minutes)}}{\text{Minutes in 1 year (525,600)}}$$

The unit of ASAI is a percentage." ASAI can be stated: "Customers on the distribution can expect ___% electric service availability." For example, if Utility X has an annual SAIDI of 50 minutes and there are 525,600 minutes in a year, then the ASAI is 99.9905%.



OUTAGE STATISTICS OVERVIEW

WHAT WE TRACK

- Number of customer minutes interrupted
- Total number of customers served
- Total number of customer interruptions
- Sum of all customer momentary events
- Total minutes of interruption
- Total number of outages
- Cause of outages
- Type of outage (overhead/underground)

WHY WE TRACK

- Meet KEYS goals to reduce outage minutes
- Identify and target problem areas/zones
- Identify faulty construction material and trends
- Assist in vegetation management
- Plan for capital improvement
- Identify weather prone areas
- Compare KEYS to other utilities



SYSTEM IMPROVEMENT RELIABILITY PLANS

Reliability Projects for 2025-2026

Transmission System

- 69kv loop insulator replacement
 - Underway
- Steel pole coating
 - Underway
- Line 4 static wire reconductor
 - Proposed
- Transmission breaker replacements
 - Underway
- US1 Auto Transformer 1 procurement and replacement
 - Underway
- Big Coppitt Substation Transformer procurement and replacement
 - Underway

Distribution System

- Replacement of “reject” poles from lower keys inspection
 - Underway
- KDS 9/TSS 5 feeder tie
 - Underway
- Phase 3 inaccessible easement project
 - Proposed
- BPS switchgear replacement
 - Underway
- Automated capacitor banks
 - Underway
- AMI
 - Underway

Recently Completed Reliability Projects

Transmission System

- Replacement of transmission pole 7-159
- Steel pole inspections
- In water transmission foundation cathodic protection
- Line 7 reclosing
- Summerland Airport (Line 6) insulator replacements

Distribution System

- Storm hardened poles to critical government facilities
- KDS 9/10 separation
- Lattice structure repair and coatings



KEYS INDICES ANALYSIS

SAIDI & MAIFI STATISTICAL OVERVIEW

DISTRIBUTION INDICES COMPARISON

	STATISTICAL DATA		% CHANGE	FL Muni	FPL	Duke	KEYS Goals
	2024	2025	2023-2024	2025	2025	2025	2025
QUANTITY	30	39	30%				
SAIDI	43.9	47.79	9%	53.9	-26%	42.5	1% 64.4 -9% below 60
MAIFI	2.13	1.92	-11%	2	10%	2.0	0% 0.8 -25%

Red= increase Blue= decrease (improvement)

KEYS TRANSMISSION SAIDI COMPARISON

	STATISTICAL	DATA	% CHANGE
	2024	2025	2023-2024
QUANTITY	7	4	-75%
SAIDI	24.2	95.7	296%

KEYS ASAI %



	Percentage
ASAI	99.9908%

KEYS INDICES BY DISTRICT




	CITY	KEYS	AREAS COMBINED	
SAIDI	20.79	27	47.79	
MAIFI	1.09	.825	1.92	
OUTAGE RESPONSE TIME	BUSINESS HOURS	20.8	37	AVG: 28.9
	AFTER HOURS	37	50.2	AVG: 62.1



- ✓ Response time- time begins when crew is assigned to outage to when crew arrives on site.
- ✓ Districts
 - Keys- Refers to all outages from Stock Island to Sunshine Key – approx. 15,200 customers (47.9%)
 - City- Refers to all outages within the city limits of Key West – approx. 16,568 customer (52.2%)

TRANSMISSION OUTAGE SAIDI STATISTIC




DISTRIBUTION OUTAGE INDICES





DISTRIBUTION FEEDER INDICES

SUB	SAIDI	CAIDI	SAIFI	MAIFle	L-BAR
BPS 2	1.66	19.71	0.08	0.06	84.3
BPS 3	5.21	39.56	0.13	0.12	80.2
BPS 4	0.55	24.07	0.02	0.06	87.6
BPS 5					
CKS 2	0.10	87.37	0.00	0.00	87.0
CKS 3	5.13	56.75	0.09	0.12	89.3
CKS 4	2.81	109.35	0.03	0.15	85.7
BCS 2	0.25	73.01	0.00	0.03	70.2
BCS 3	0.63	22.04	0.03	0.02	56.8
BCS 4	8.18	52.94	0.15	0.10	81.3
BCS 5	0.75	101.15	0.01	0.07	89.4
US1 2	0.00	0.00	0.00	0.01	0.0
US1 3	0.00	0.00	0.00	0.00	0.0
US1 5	0.13	5.00	0.03	0.05	5.0
US1 6	0.99	47.53	0.02	0.02	55.7
SSS 2	0.19	362.18	0.00	0.00	213.5
SSS 3	0.31	0.00	0.01	0.00	0.0
SSS 4	0.01	40.00	0.00	0.00	40.5
KDS 2	0.58	36.22	0.02	0.01	40.3
KDS 4	0.79	23.19	0.03	0.05	104.5
KDS 5	4.86	35.81	0.14	0.13	100.3
KDS 8	1.27	55.54	0.02	0.03	71.2
KDS 9	2.58	40.41	0.06	0.07	50.0
KDS 10	0.12	54.91	0.00	0.02	54.0
WSS 2	0.48	136.68	0.00	0.06	153.4
WSS 3	0.00	0.71	0.00	0.00	0.00
WSS 4	0.19	5.35	0.04	0.02	75.5
WSS 5	2.30	47.86	0.05	0.02	132.8
WSS 7	0.06	101.37	0.00	0.07	108.0
KWD 2	0.36	3.51	0.10	0.05	57.0
KWD 3	0.27	8.49	0.03	0.05	26.3
KWD 4	0.07	3.04	0.02	0.02	17.0
KWD 5	0.00	0.00	0.00	0.00	0.0
TSS 2	0.43	14.28	0.03	0.00	86.0
TSS 3	2.54	13.22	0.19	0.21	60.8
TSS 4	0.67	7.29	0.09	0.09	68.0
TSS 5	3.81	22.22	0.17	0.09	89.1
Total	48.29	30.00	1.61	1.80	80.0

A photograph of two utility workers on a red ladder attached to a wooden utility pole. The worker in the foreground is wearing a white hard hat, a light blue long-sleeved shirt with a logo, and a safety harness. He is looking to the right. The worker in the background is also wearing a hard hat and safety glasses. The ladder is red and has various ropes and equipment attached to it. The background is a clear blue sky.

MUNI & IOU INDICES COMPARISON



KEYS 2025 DISTRIBUTION RELIABILITY SUMMARY

This section provides data collected for the 2025 calendar year and includes comparisons between Florida Municipal Utilities (2025), and the Florida IOUs (2025).

In order to make a valid comparison, the data from the Florida Municipal was calculated as if participants were a part of one utility. For example, the data for the number of customers, customer minutes interrupted, total outages, etc. and the indices calculated from this data are based on the sum of all the participating Florida Municipal (vs. averaging). This allows for a more appropriate comparison to the FL IOU data.

When possible, we have tried to make valid comparisons and identify possible conclusions for the results. However, due to the nature of some of this data, there are many instances where no definite conclusion can be drawn from the data.

The data has been divided into the following groups:

KEYS 2025 Distribution Reliability Indices:

- Comparison of the Florida Municipals to the Investor Owned Utilities and Regional Utilities
- Minimum and maximum data points for each index for the Florida Municipals

Comparison of Historical Data Reliability Indices (KEYS 2025):

- Comparison of Florida Municipals, Investor Owned Utilities and SE Regional Utilities

Cause of Outages:

- Comparison of the Florida Municipals to the Investor Owned Utilities by total number of outages and by percentage
- Florida Municipals cause of outages by month
- Comparison of Florida Municipals cause of outages by percentage (KEYS 2025)
- Florida Municipals- cause of outages – overhead vs. underground

FLORIDA MUNI'S VS. INVESTOR OWNED

2025 DISTRIBUTION RELIABILITY INDICES

	FI Muni	KEYS	FPL	TECO	DUKE	FPUC	FL APPA	Ntnl APPA
	2025	2025	2025	2025	2025	2025	2023	2023
SAIDI	53.9	47.79	42.5	77.66	64.40	128.87	195.10	149.41
CAIDI	57	33.67	78.3	74.43	78.40	79.90	183.50	111.92
SAIFI	0.9	1.513	.54	1.04	.82	1.61	1.86	1.26
MAIFI	2	1.92	2	5.09	.80	N/A	N/A	N/A
L- BAR	108	81.41	219	136.54	154.90	107.95	N/A	N/A


Best performance is shown in blue and the second best is shown in orange.

*Averages do not include MEDs (Major Event Days)


** SAIDI goal is less than 60min avg

INDUSTRY INDICES COMPARISON

**2025 Distribution Reliability Indices
SAIDI - Avg Minutes/Interruptions**




**2025 Distribution Reliability Indices
CAIDI - Avg Repair Time/Outage**




2025 Distribution Reliability Indices SAIFI - Avg Frequency Of Interruptions




2025 Distribution Reliability Indices MAIFle - Avg Momentary Events/Customer




Florida Muni & KEYS 2025 Indices




Florida Utilities-SAIDI 2016-2025




Florida Utilities-CAIDI 2016-2025




Florida Utilities-SAIFI 2016-2025



Florida Utilities-MAIFle 2016-2025




Florida Utilities-LBAR 2016-2025



TOTAL NUMBER OF OUTAGES BY PERCENTAGE OF FLORIDA UTILITIES

CAUSE OF OUTAGE	FPL	TECO	DUKE	FPUC	KEYS 2025
WEATHER	7%	20%	11%	7%	25%
VEGETATION	16%	14%	16%	13%	6%
ANIMALS	11%	14%	11%	20%	14%
FOREIGN	0%	0%	0%	0%	0%
HUMAN CAUSE	1%	4%	1%	2%	1%
UNDETERMINED	12%	15%	25%	35%	10%
EQUIPMENT FAILURE	36%	8%	29%	19%	39%
ALL OTHERS	17%	25%	6%	4%	4%

TOTAL NUMBER OF OUTAGES BY PERCENTAGE OF KEYS & IOU'S







TRANSMISSION & DISTRIBUTION OUTAGE ANALYSIS

TRANSMISSION OUTAGES


Transmission Outages by Year




Transmission Outages By Territory



Total Transmission Outages 2025 vs Month



Total Transmission Outages vs Cause 2016 - 2025







2025 TRANSMISSION OUTAGE DETAIL OUTAGES AFFECTING CUSTOMERS

KEYS Area	Time	Duration Minutes	Location	KEYS Cust Affected	Cause	Explanation
08/27/2025	08:35	32	BPS	34,000	Employee Error	Employee disconnected Line 7 fiber connection
12/31/2025	18:28	6	SSS	1,588	Unknown	Fault on 69kV line 5


FKEC Area	Time	Duration Minutes	Location	KEYS Cust Affected	Cause	Explanation
06/10/2025	10:30	74	FKEC	34,000	Vehicle	Dump truck hit broke comm messenger then ended up in transmission line
07/17/2025	14:06	5	FKEC	8,476	UV	Line 5 reclosed and SPS activated shedding 9 feeders




DISTRIBUTION OUTAGES




Total Distribution Feeder Outages vs Month (2016 - 2025)




Distribution Feeder Outages vs Cause (2016 - 2025)




Distribution Feeder Outages From Trees vs Month (2016 - 2025)




Distribution Feeder Outages From Trees vs Year




Distribution Feeder Outages Equipment Failure vs Year




Total Distribution Outages vs Cause (2015-2025)




Average Transmission and Distribution Outage Minutes Per Customer (SAIDI)




Transmission and Distribution Feeder Quantity vs Group Minutes 2025




Transformer and Lateral Outages vs Year



Reclosure Operation vs Feeder 2025





CAIDI vs Feeder 2025







FEEDER OUTAGES BY SUBSTATION




Thompson St. Substation Feeder Outage History vs Year




White St. Substation Feeder Outage History vs Year




Second St. Substation Feeder Outage History vs Year




US1 Substation Feeder Outage History vs Year




Big Coppitt Substation Feeder Outage History vs Year



Cudjoe Key Substation Feeder Outage History vs Year



Big Pine Substation Feeder Outage History vs Year



Outage to Line Distance Ratio and Feeder SAIDI 2025

Substation	FDR	# Of Customers	Circuit Miles	Outage type-- QTY					Total Events Excluded Reclosers	Total Events	Outage to Line Length Ratio	SAIDI Total by Feeder
				REC	SERVICE WIRE	LAT	XFORMER	FDR				
BPS 2	2	2012	42.9	1	1	24	19	1	45	46	1.1	1.7
BPS 3	3	1870	12.6	2	0	15	14	2	31	33	2.6	5.2
BPS 4	4	594	20.1	5	0	7	3	1	11	16	0.8	0.6
CKS 2	2	1386	9.8	0	0	1	4	0	5	5	0.5	0.1
CKS 3	3	997	26.6	4	0	26	23	2	51	55	2.1	5.1
CKS 4	4	1591	44.2	3	0	16	20	0	36	39	0.9	2.8
BCS 2	2	525	6.6	2	0	2	4	0	6	8	1.2	0.2
BCS 3	3	262	8.0	3	0	3	3	3	9	12	1.5	0.6
BCS 4	4	1129	25.9	3	0	8	22	4	34	37	1.4	8.2
BCS 5	5	1170	7.3	2	0	6	7	0	13	15	2.1	0.8
US12	2	344	3.2	1	0	0	0	0	0	1	0.3	0.0
US13	3	515	1.8	0	0	0	0	0	0	0	0.0	0.0
US15	5	851	8.7	2	0	0	0	1	1	3	0.3	0.1
US16	6	519	6.2	1	0	3	3	1	7	8	1.3	1.0
SSS 2	2	168	4.1	0	0	0	2	0	2	2	0.5	0.2
SSS 3	3	1262	5.9	0	0	3	9	0	12	12	2.0	0.3
SSS 4	4	158	1.8	1	0	0	2	0	2	3	1.7	0.0
KDS 2	2	251	2.8	1	0	1	1	1	3	4	1.4	0.6
KDS 4	4	762	3.5	2	0	4	9	0	13	15	4.3	0.8
KDS 5	5	1433	7.7	3	0	0	6	3	9	12	1.6	4.9
KDS 8	8	567	7.0	2	0	2	2	1	5	7	1.0	1.3
KDS 9	9	1126	8.3	2	0	1	3	1	5	7	0.8	2.6
KDS 10	10	651	1.8	1	0	2	2	0	4	5	2.8	0.1
WSS 2	2	1817	8.0	1	0	3	2	0	5	6	0.8	0.5
WSS 3	3	4	1.3	2	0	0	0	2	2	4	3.1	0.0
WSS 4	4	555	3.0	1	0	1	2	1	4	5	1.7	0.2
WSS 5	5	761	2.6	1	0	0	2	2	4	5	1.9	2.3
WSS 7	7	1132	4.0	2	0	0	3	0	3	5	1.3	0.1
KWD 2	2	1643	4.9	1	0	0	2	2	4	5	1.0	0.4
KWD 3	3	504	2.7	3	0	0	1	2	3	6	2.2	0.3
KWD 4	4	645	4.6	1	0	1	0	0	1	2	0.4	0.1
KWD 5	5	149	1.0	0	0	0	0	0	0	0	0.0	0.0
TSS 2	2	907	5.7	0	0	2	8	1	11	11	1.9	0.4
TSS 3	3	1136	4.5	6	0	0	7	4	11	17	3.8	2.5
TSS 4	4	1391	7.1	2	0	3	3	1	7	9	1.3	0.7
TSS 5	5	1386	8.5	2	0	2	3	3	8	10	1.2	3.8
Totals		32173	324.7	63	1	136	191	39	367	430		48.29