



Accessibility Grade	5 out of 5
Access Description	No Significant Barriers to Access Found

Material	Concrete
Length Inspected	16 ft
Area Inspected	96 ft²

Detectable Warning	Truncated Domes
Percent Deteriorated	0%

GPS IMAGES AND COORDINATES HAVE BEEN REMOVED FROM THIS FILE FOR DATA PRIVACY



Scan Data

Metadata		Condition Areas	
Scan ID	190400	Cracked Area	0 ft²
Inspection Date	2025-04-29	Deteriorated Area	0 ft²
GPS Coordinates		Panel Area	96 ft²
Accessibility Grade	5	Percent Deteriorated	0%
Access Description	No Significant Barriers to Access Found		
Material	Concrete		
Detectable Warning	Truncated Domes		
Length Inspected	16 ft		
Area Inspected	96 ft²		

Slopes & Measurements	
Average Cross Slope	1.4%
Max Cross Slope	1.9%
Average Running Slope	1.2%
Max Running Slope	2.6%
Average Width	60.1 in
Min Clear Width	58.5 in

Violations					
Cross Slope		Running Slope		Clear Width	
Extreme	0	Extreme	0	Extreme	0
Severe	0	Severe	0	Severe	0
Moderate	0	Moderate	0	Moderate	0
Minor	0	Minor	0	Minor	0

Annotated Raster Legend

Ramp Violation Thresholds

	Cross Slope		Run Slope		Width	
Severity						
Minor	2.5% - 3%	<div>CS</div>	8.3% - 9%	<div>RS</div>	42" - 46"	<div>CW</div>
Moderate	3% - 4%	<div>CS</div>	9% - 10%	<div>RS</div>	36" - 42"	<div>CW</div>
Severe	4% - 6%	<div>CS</div>	10% - 12%	<div>RS</div>	24" - 36"	<div>CW</div>
Extreme	6+%	<div>CS</div>	12+%	<div>RS</div>	0" - 24"	<div>CW</div>
Score Impact	High		High		High	

Regions

<div></div> <div>Panel</div>	<div></div> <div>Path of Travel</div>
<div></div> <div>Detectable Warning</div>	<div></div> <div>Asphalt</div>
<div></div> <div>Brick</div>	<div></div> <div>Missing Ramp</div>
<div></div> <div>Obstruction</div>	<div></div> <div>Cracked/Deteriorated</div>
<div></div> <div>Debris</div>	

Midblock Violation Thresholds

	Cross Slope		Run Slope		Width	
Severity						
Minor	2.5% - 3%	<div>CS</div>	8.3% - 9%	<div>RS</div>	42" - 46"	<div>CW</div>
Moderate	3% - 4%	<div>CS</div>	9% - 10%	<div>RS</div>	36" - 42"	<div>CW</div>
Severe	4% - 6%	<div>CS</div>	10% - 12%	<div>RS</div>	24" - 36"	<div>CW</div>
Extreme	6+%	<div>CS</div>	12+%	<div>RS</div>	0" - 24"	<div>CW</div>
Score Impact	High		High		High	

Manual Tags



Trip Hazard

