

Annual Drinking Water Quality Report for 2025

Holland Water District #1

47 Pearl St. Holland N.Y. 14080

(Public Water Supply ID#1410126)

INTRODUCTION

To comply with State regulations Holland Water District will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards at the Water St. well. The Legion Dr. well is being used as a secondary source and the iron is under the state mandated maximum contaminant level. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerns about your drinking water, please contact Jason Simmons Holland Water Department @ 716-537-9443. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled Town Board meetings, held in the Town Hall on the second Wednesday of each month at 7:00 pm.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribes regulations which limit the number of certain contaminants in water provided by public water systems. The State Health Departments and the FDA's

regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves 1594 customers through 454 service taps. We have three wells that we will be able to use, two are located on Water Street and the second is located on Legion Drive. The Legion Dr. well is a bedrock well that is 100 foot deep, and this well produces over 150 gallons a minute. The chlorine is added using diaphragm pumps that inject it into the water before it is pumped into the distribution system. The Water Street well produces 135 gallons a minute, located in the Hamlet. Our source is a deep bedrock well, with 50 feet of clay cap, protected by a masonry building. The Legion dr Well is a backup well used when the well pump needs servicing. The water is aerated in a cascade tower to remove sulfur gas, ortho-phosphate is added, and it is disinfected with the injection of chlorine before it is pumped into the distribution system. The average water rate is \$5.73 per thousand gallons, with a quarterly capital improvement charge of \$32.62.

The New York State Department of Health (NYSDOH) has completed a source water assessment for the Town of Holland water system, based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water. It does not mean that the water delivered to consumers is or will become contaminated. See section "Are there contaminants in our drinking water?" for a list of the contaminants that have been detected.

Our water is derived from three drilled wells. The source water assessment has rated these wells as having a medium high susceptibility to enteric bacteria, enteric viruses, cations/anions, halogenated solvents, petroleum products, herbicides/pesticides, other industrial organics, nitrates, and protozoa. These ratings are due primarily to the close proximity of pastures and permitted discharge facilities (industrial/commercial facilities that discharge wastewater into the environment and are regulated by the state and/or federal government) to the wells. Also, the ratings are based on the assumption that the wells draw greater than 100 gallons per minute from the unconfined aquifer.

While the source water assessment rates our well as being susceptible to microbial contamination, please note that our water is disinfected to ensure that the finished water delivered into your home meets New

York State's drinking water standards for microbiological contamination. A copy of the assessment, including a map of the assessment area, can be obtained at the Town Hall office.

In 2025, Holland Water Department pumped 34,193,000 gallons at our Water Street pumping station. The Legion drive pumping station pumped 933,000 gallons. Some of this water is used for flushing water mains, fighting fires, training firefighters, plant processes, equipment and hydrant testing and some of this water was lost due to leaks. 34,854,000 gallons of water were sold to customers.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, inorganic compounds, nitrate, lead and copper, volatile organic compounds, total trihalomethanes, haloacetic acids, radiological and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. We also tested PFO's in our drinking water and they were not detected. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Erie County Health Department at 716-961-6800 fax 716-961-6880.

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit of Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source Contamination
Lead and Copper							
Lead	No	6/18/2025	90%=.003 0.001-0.003	mg/l	0.015	AL=.015	Corrosion of household plumbing systems, Erosion of natural deposits
Copper	No	6/18/2025	90%=0.5 0.02-1.0	mg/l	1.3	AL=1.3	Corrosion of household plumbing , erosion of natural deposits, leaching from wood preservatives
Disinfection by Products							
Total Trihalomethanes (TTHMs- bromodichloromethane, dibromochloromethane, and bromoform	No	8/5/2025	4.6	ug/L	n/a	80	Byproduct of drinking water disinfection needed to kill harmful organism
HALOACETICACID dibromoacetic	No	8/5/2025	0.6	ug/L	n/a	60	Byproduct of drinking water disinfection needed to kill harmful organism
Primary Inorganic Chemicals							
Mercury Well #2	No	11/19/2025	0.2000	ug/l	2	2	Naturally occurring indicative of landfill contamination
Selenium Well #2	No	11/19/2025	3	ug/l	50	50	Naturally occurring indicative of landfill contamination
Secondary Inorganic Contaminants							
Iron Well #1	No	6/4/2025	210	ug/l	n/a	300	Naturally occurring indicative of landfill contamination
Iron Well #2	No	6/4/2025	230	ug/l	n/a	300	Naturally occurring indicative of landfill contamination
Manganese Well #1	No	6/4/2025	50	ug/l	n/a	300	Naturally occurring indicative of landfill contamination
Manganese Well #2	No	6/4/2025	30	ug/l	n/a	300	Naturally occurring indicative of landfill contamination
Principal Inorganic Contaminants							
Barium Well #1	No	6/4/2024	957	ug/l	2000	2000	Discharge of drilling waster or metal refineries erosion of natural deposits
Barium Well #1	No	11/19/2025	864	ug/l	2000		
Disinfectant							
Chlorine residual	No	various	(.70-1.0)	mg/l	n/a	MRDL=4	Water additive used to control microbes
Radioactive Contaminants							
Gross Alpha (including Radon and Uranium) Well #1	No	5/26/2022	2.7	pCi/L	0	15	Erosion of natural deposit
Combined Radium- 226 & 228 Well #1	No	5/26/2022	2.09	pCi/L	0	5	Erosion of natural deposit

Notes:

1 – The level presented represents the 90th percentile of the 20 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead values detected at your water system. On June of 2024, 20 samples were collected from your water system and the 90th percentile was < 0.014 mg/L. All samples were between ND and 0.0028 mg/l, as noted in the table. The action level for lead was not exceeded at any of the sites tested.

2 – The level presented represent the 90th percentile of the 20 sites tested. A percentile is value on a scale of 100 that indicated the percent of a distribution that is equal to or greater than 90% of the copper values detected at our water system. On June of 2024, 20 samples were collected from our water system and the 90th percentile was 0.402 mg/L. All samples were between 0.03 and 0.056 mg/L as noted in the table.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We have learned through our operating and monitoring requirements that some contaminants have been detected however, these contaminants were detected below the level allowed by the state. Our main well source which is Water St pumphouse didn't exceed any MCL in the 2024 season. The Legion Dr. Well also didn't exceed any MCL levels in the 2025 season.

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Holland Water District is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certified to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Holland Water District at 716 537-9443. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

We did not have any violations for the reporting year 2025. We tested for PFOS, PFOA, and 1,4-Dioxane and these levels were non detected. So that means we were way below the maximum containment levels for these. We did the last third quarter test for the year 2023 this concluded our testing for this containment. The State has lowered the sampling requirements for the year 2023. We have met all reporting requirements set by the DOH.

The Holland Water Department system issued a waiver for sampling asbestos. This waiver expires on December 31, 2032. We were also issued a waiver of required sampling for bis-(2-ethylhexyl)-adipate, bis-(2-ethyl-phthalate and benzo-a-pyrene (SOCS); this waiver expires on December 31, 2027.

This ANNUAL WATER QUALITY REPORT is displayed @ www.townofhollandny.com

INFORMATION ON LEAD SERVICE LINE INVENTORY

The Lead and Copper Revision Rule requiring all systems to have completed a Lead Service Line (LSL) inventory by October 16, 2024, was completed. No lead service lines are in the system.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water meets or exceeds State and Federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.

- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office @ 716-537-9443 if you have any questions.