



REGIONAL PROCUREMENT HUB PROGRAM – REGION 1
SUPPLEMENTAL BID BULLETIN NO. 01
FOR PB-ITB-R1-1-2025
PROCUREMENT OF CONSIGNMENT, SUPPLY AND DELIVERY OF DISTRIBUTION TRANSFORMERS


In accordance with Section 4.3.2 of Annex "B" of the NEA Memorandum No. 2025-03, this Supplemental Bid Bulletin is hereby issued to clarify, modify or amend the following items for PB-ITB-R1-1-2025:

Section/Item No.	Issue in the Bidding Documents / Technical Specifications	Clarification / Amendment
Section V. Terms of Reference		
TOR 6.1 Details of Technical Specifications for Items A to D (Construction – Primary Bushing)	With respect to Construction, Primary Bushings under TOR 6.1 and TOR 6.2 , there is a discrepancy in the Voltage Class and BIL Withstand indicated under the Table (1 st Bullet) entitled " <i>Transformer Primary Bushing Number and Characteristics</i> " as against the 4 th bullet of the same specification.	Upon consultation with the Member ECs, it was clarified that the specifications found under the Table (1 st Bullet) is controlling. Thus, the proper specifications for the Distribution Transformers under Items A to J should be: (i) Voltage Class - 15 kV ; and (ii) BIL Withstand of 95kV BIL .
TOR 6.2 Details of Technical Specifications for Items G to J (Construction – Primary Bushing)	The Table provides a Voltage Class of 15 kV and a BIL Withstand of 95kV BIL . However, the 4 th Bullet states that " <i>For double-bushing transformers, the H1 and H2 end shall be designated as the high voltage primary winding, 1.2kV class, 30kV BIL, made from high grade, glazed, wet-process porcelain, colored Light Gray ANSI 70.</i> "	The discrepancy under the 4 th bullet is a mere clerical error. To correct the discrepancy, the 4 th Bullet under Construction, Primary Bushings of TOR 6.1 and TOR 6.2 , as provided below, is hereby deleted , to wit: " For double-bushing transformers, the H1 and H2 end shall be designated as the high voltage primary winding, 1.2kV class, 30kV BIL, made from high grade, glazed, wet-process porcelain, colored Light Gray ANSI 70. "
Section VII. Bid Forms		
Form No. 10 Details of Technical Specifications	Bid Form#10 (Details of Technical Specifications) requires revision to conform with the amendments to TOR 6.1 and TOR 6.2 as provided above.	Bid Form#10 (Details of Technical Specifications) is amended to conform with the revisions to TOR 6.1 and TOR 6.2 above. Please see revised Details of Technical Specifications Form attached herein as Annex "A" .



Issued this 5th day of August 2025 for the guidance and information of all concerned.


MS. THERESITA A. RIVERA
Member
NEA RPH SBAC



ENGR. ERIC B. CAMPOTO
Member
NEA RPH SBAC



ENGR. RODERICK N. PADUA
Member
NEA RPH SBAC


ENGR. FEDERICO P. VILLAR, JR.
Vice-Chairperson
NEA RPH SBAC


ATTY. ALEXANDER PAUL T. RIVERA
Chairperson
NEA RPH SBAC

CONFORME:


ENGR. ALLAN G. CASEM
General Manager
PANELCO III – Confirmed Representative
Electric Cooperative


ENGR. CARLITO P. DEL MUNDO
Authorized Procurement Representative
PANELCO III – Confirmed Representative
Electric Cooperative

Form#10: Details of Technical Specifications

(Letterhead of the Bidder)

Date: _____, 2025

NEA Special Bids and Awards Committee (NEA SBAC)
#57 NEA Building, NIA Road,
Barangay Pinyahan, Government Center Diliman,
Quezon City

Subject: Details of Technical Specifications of [Name of Bidder]

<i>Detailed Technical Specifications for: Items A to F (Transformers, Pole Type, Conventional, 10kVA to 75 kVA, Cu-Cu-Al Winding)</i>			
Particulars	Specifications Prescribed in Bidding Documents	Statement of Compliance	Details of Added Technical Specifications (if any)
Scope	This Technical Specification covers the single-phase, overhead-type, oil-immersed, self-cooled, silicon steel core, brand new and PCB-Free distribution transformers under Items A to F, with primary voltage rating of 7620/13200 Y V, and secondary voltage rating of 120/240 V.		
Site and Service Conditions	Transformers conforming to this specification shall be suitable for operation at rated kVA in a tropical environment and under the following service conditions: • Maximum altitude above sea level - 1000 m • Maximum ambient temperature - 40° C • Average ambient temperature - 30° C		
Applicable Standards	All transformers furnished under this specification shall be designed, manufactured and tested to meet or exceed the requirements of the latest revision of the following IEEE, ANSI/IEEE, NEMA and ASTM Standards or equivalent IEC standards:		

	<ul style="list-style-type: none">• IEEE C57.12.00 Std - Standard General Requirements for Liquid-Immersed Distribution, Power, and Regulating Transformers• IEEE C57.12.20 Std - Requirements for Overhead-Type Distribution Transformers, 500 kVA and Smaller; High-voltage, 13200 Volts and Below; Low-voltage, 7970/13800 Y Volts and Below• IEEE C57.12.70 Std - Terminal Markings and Connections for Distribution and Power Transformers• IEEE C57.12.90 Std - Standard Test Code for Liquid-Immersed Distribution, Power, and Regulating Transformers and Guide for Short Circuit Testing of Distribution and Power Transformers• ANSI/IEEE C57.92 Std - Guide for Loading Mineral-Oil-Immersed Power Transformers• NEMA Standards Publication No. TR 1 - Transformers, Regulators and Reactors• ASTM D3487 - Specifications for Mineral Insulating Oil Used in Electrical Apparatus		
--	--	--	--

Environmental Compliance	PCB Free											
Electrical Characteristics	<p><u>Voltage and Rating Taps</u></p> <ul style="list-style-type: none">The transformer primary voltage rating shall be specified based on the rating shown in the Table below: <table><tr><th colspan="3">Standard Primary Voltage Ratings of Transformers</th></tr><tr><th>Nominal System Voltage(V)²</th><th>Primary Voltage Rating(V)³</th><th>Secondary Voltage Rating(V)</th></tr><tr><td>7620/ 13200</td><td>7620/ 13200 Y</td><td>120/240</td></tr></table> <ul style="list-style-type: none">The transformer shall be provided with a no-load tap changer to provide Two (2) - 2 ½ % tap above and Two (2) - 2½ taps below rated primary voltage. Tap 3 shall be the nominal tap. All tap ratings shall be at rated capacity.	Standard Primary Voltage Ratings of Transformers			Nominal System Voltage(V) ²	Primary Voltage Rating(V) ³	Secondary Voltage Rating(V)	7620/ 13200	7620/ 13200 Y	120/240		
	Standard Primary Voltage Ratings of Transformers											
	Nominal System Voltage(V) ²	Primary Voltage Rating(V) ³	Secondary Voltage Rating(V)									
	7620/ 13200	7620/ 13200 Y	120/240									
<p><u>Frequency</u></p> <p>The transformer shall be designed to operate at 60Hz.</p>												
<p><u>KVA Ratings</u></p> <p>The kVA rating shall be continuous and based on not exceeding either a 65°C average winding temperature rise or an 80°C hottest-spot temperature rise above an ambient of 30°C. The temperature rise of the insulating oil shall not exceed 65°C when measured near the top of the tank.</p>												
<p><u>Insulation Level</u></p> <p>The transformer shall be designed to have coordinated insulation levels at its terminals not less than values specified in the Table below.</p>												

		Transformer Dielectric Insulation Levels													
		Insulation Level	7620/ 13200 Y V	120/240 V											
		Full Wave (BIL) in kV, crest	95	30											
		Chopped Wave in kV, crest	105	33											
		Min. time to Flashover in us	1.8	1.0											
		Applied Voltage Test (kV rms)	-	10											
		Induced Voltage Test (phase to ground) (kV rms)	17	1.4											
<p><u>Percent Impedance</u></p> <ul style="list-style-type: none">Transformers shall have impedance values as specified in the table below. <table><tr><th colspan="3">Standard Primary Voltage Ratings of Transformers</th></tr><tr><th>kVA Range</th><th>% Impedance</th><th>% Tolerance</th></tr><tr><td>3 thru 75</td><td>2.0</td><td>±10%</td></tr></table> <ul style="list-style-type: none">Difference in impedance between transformers of the same rating, when two or more units are produced by one manufacturer at the same time, shall not exceed 7.5% of the specified value.					Standard Primary Voltage Ratings of Transformers			kVA Range	% Impedance	% Tolerance	3 thru 75	2.0	±10%		
Standard Primary Voltage Ratings of Transformers															
kVA Range	% Impedance	% Tolerance													
3 thru 75	2.0	±10%													
<p><u>Losses</u></p> <ul style="list-style-type: none">Transformer losses shall be based on reference temperatures of 30°C for No-Load Losses and 85°C for Load Losses.The No-Load Losses and Load Losses of the transformer unit shall not exceed the values specified in Table below.															

	<table><tr><th colspan="5">Transformer Maximum Losses</th></tr><tr><th rowspan="2">Rated Capacity (KVA)</th><th colspan="2">Silicon Steel Core</th><th colspan="2">Total Losses</th></tr><tr><th>No-Load Losses (w)</th><th>Load Losses (w)</th><th>(Watts)</th><th>(% of Rated kVA)</th></tr><tr><td>10</td><td>36</td><td>120</td><td>156</td><td>1.56</td></tr><tr><td>15</td><td>50</td><td>195</td><td>245</td><td>1.63</td></tr><tr><td>25</td><td>80</td><td>290</td><td>370</td><td>1.48</td></tr><tr><td>37.5</td><td>105</td><td>360</td><td>465</td><td>1.24</td></tr><tr><td>50</td><td>135</td><td>500</td><td>635</td><td>1.27</td></tr><tr><td>75</td><td>190</td><td>650</td><td>840</td><td>1.12</td></tr></table> <ul style="list-style-type: none">Actual transformer losses shall not exceed the values guaranteed in the bid by the manufacturer by 10% for No-Load Losses and 6% for Total Losses.	Transformer Maximum Losses					Rated Capacity (KVA)	Silicon Steel Core		Total Losses		No-Load Losses (w)	Load Losses (w)	(Watts)	(% of Rated kVA)	10	36	120	156	1.56	15	50	195	245	1.63	25	80	290	370	1.48	37.5	105	360	465	1.24	50	135	500	635	1.27	75	190	650	840	1.12		
Transformer Maximum Losses																																															
Rated Capacity (KVA)	Silicon Steel Core		Total Losses																																												
	No-Load Losses (w)	Load Losses (w)	(Watts)	(% of Rated kVA)																																											
10	36	120	156	1.56																																											
15	50	195	245	1.63																																											
25	80	290	370	1.48																																											
37.5	105	360	465	1.24																																											
50	135	500	635	1.27																																											
75	190	650	840	1.12																																											
<p><u>Short Circuit Characteristics</u></p> <p>The transformer shall withstand the mechanical and thermal stresses produced by external short-circuit currents specified in IEEE Std C57.12.00, latest revision.</p>																																															
<p><u>Loading Capability</u></p> <p>The transformer shall be guaranteed to have the loading capability in accordance with ANSI/IEEE Std C57.92, latest revision.</p>																																															

	<p><u>Audible Sound Level</u></p> <p>Transformers shall be designed so that the average sound level does not exceed the values specified in the Table below.</p> <table><tr><th colspan="2">Transformer Audible Sound Level Limit</th></tr><tr><th>kVA Range</th><th>Average Sound Level (Decibels)</th></tr><tr><td>50 and below</td><td>48</td></tr><tr><td>75-100</td><td>51</td></tr></table>	Transformer Audible Sound Level Limit		kVA Range	Average Sound Level (Decibels)	50 and below	48	75-100	51		
Transformer Audible Sound Level Limit											
kVA Range	Average Sound Level (Decibels)										
50 and below	48										
75-100	51										
Construction	<p><u>Cooling Class</u></p> <p>The cooling method employed for transformers supplied under this specification shall be self-cooled (OA or ONAN).</p>										
	<p><u>Core-Coil Assembly</u></p> <ul style="list-style-type: none">• Transformer core shall be manufactured using either low-loss high-permeability grain-oriented silicon steel.• Transformer Windings shall be of high-conductivity Copper or Aluminum [(Cu-Cu) or (Cu-Al)].• The core and coil assembly shall be mounted rigidly in the tank. The assembly shall not shill in direction during shipping, handling, installation, or during normal operation due to vibrations.• The core and coil assembly shall be vacuum processed to ensure maximum penetration of the insulating liquid to the coil insulation system.										

Primary Bushings

- The transformer shall be furnished at the primary side with optional cover-mounted high-voltage bushing. The number and characteristics of bushing/s are shown in Table below.

Transformer Primary Bushing Number and Characteristics	
High-Voltage Bushing Number and Characteristics	Transformer Primary Voltage Rating
	7620/ 13200 Y V
Number	2
Voltage Class (kV)	15
BIL Withstand (kV, min.)	95
60 Hz Withstand, 1-min dry (kV, min.)	35
60 Hz Withstand, 10-s dry (kV, min.)	30
Minimum Creepage Distance, mm (in)	255(10)

- The high-voltage bushings shall be made from high-grade, wet- process porcelain with the entire exposed surface to be glazed. The color of the bushings shall be Light Gray ANSI 70, Munsell Notation 5BG 7.0/0.4.
- The high-voltage bushings shall be designated as H1 & H2 (for double bushing transformer) and shall be arranged in accordance with the latest revision of IEEE Std C57.12.20.

	<p><u>Secondary Bushings</u></p> <ul style="list-style-type: none">• The transformer shall be furnished at the secondary side with sidewall-mounted, low-voltage bushings. The number and characteristics of the low-voltage bushings are shown in the Table below. <table><tr><th colspan="2">Transformer Secondary Bushing Number and Characteristics</th></tr><tr><th rowspan="2">Low-Voltage Bushing Number and Characteristics</th><th>Transformer Secondary Voltage Rating</th></tr><tr><th>120/240 V</th></tr><tr><td>Number</td><td>3</td></tr><tr><td>Voltage Class (kV)</td><td>1.2</td></tr><tr><td>BIL Withstand (kV, min.)</td><td>30</td></tr><tr><td>60 Hz Withstand, 1-min dry (kV, min.)</td><td>10</td></tr><tr><td>60 Hz Withstand, 10-s dry (kV, min.)</td><td>6</td></tr></table> <ul style="list-style-type: none">• The low-voltage bushings shall be made from high-grade, wet- process porcelain with the entire exposed surface to be glazed. The color of the bushings shall be Light Gray ANSI 70, Munsell Notation 5BG 7.0/0.4.• The low-voltage-bushings shall be designated as X1, X2 and X3 depending on the transformer secondary voltage rating, and shall be arranged in accordance with the latest revision of IEEE Std C57.12.20.	Transformer Secondary Bushing Number and Characteristics		Low-Voltage Bushing Number and Characteristics	Transformer Secondary Voltage Rating	120/240 V	Number	3	Voltage Class (kV)	1.2	BIL Withstand (kV, min.)	30	60 Hz Withstand, 1-min dry (kV, min.)	10	60 Hz Withstand, 10-s dry (kV, min.)	6		
Transformer Secondary Bushing Number and Characteristics																		
Low-Voltage Bushing Number and Characteristics	Transformer Secondary Voltage Rating																	
	120/240 V																	
Number	3																	
Voltage Class (kV)	1.2																	
BIL Withstand (kV, min.)	30																	
60 Hz Withstand, 1-min dry (kV, min.)	10																	
60 Hz Withstand, 10-s dry (kV, min.)	6																	
	<p><u>Bushing Terminals</u></p> <ul style="list-style-type: none">• The high-voltage bushing and high-voltage neutral bushing shall be equipped with eyebolt-type connectors made from tinned copper alloy material and provided with stainless steel spring washers. The terminal connectors shall accommodate 8 mm² (AWG No. 8) solid to 30 mm² (AWG No. 2) stranded copper conductor. Terminal detail shall be in accordance with the latest revision of IEEE Std C57.12.20.																	

	<ul style="list-style-type: none">The low-voltage bushings shall be equipped with tinned copper alloy, eyebolt-type connectors or tinned spade terminal pads, arranged for vertical takeoff of cables. Size of terminal openings and cables, and type of spade terminal pads are shown in Table below. <table><tr><th colspan="3">Size of Low-Voltage Terminals and Conductor Range</th></tr><tr><th rowspan="2">Size of Terminal Opening mm(in)</th><th rowspan="2">Size of Conductor that the Terminal Will Accommodate mm² (AWG/kcmil)</th><th>kVA Range for Low-Voltage Rating of:</th></tr><tr><th>120/240 V</th></tr><tr><td>15.9 (5/8)</td><td>14 mm² (AWG No. 6) solid to 100 mm² (AWG No. 4/0) stranded copper conductor</td><td>15& below</td></tr><tr><td>20.6 (13/16)</td><td>30 mm² (AWG No. 2) solid to 700 mm² (350 kcmil) stranded copper conductor</td><td>25-50</td></tr><tr><td>23.8 (15/16)</td><td>50 mm² (AWG No. 1/0) solid to 1000 mm² (500 kcmil) stranded copper conductor</td><td>75</td></tr></table> <ul style="list-style-type: none">Terminal details shall be in accordance with IEEE Std C57.12.20, latest revision.Terminal markings shall be in accordance with IEEE Std C57.12.70, latest revision.	Size of Low-Voltage Terminals and Conductor Range			Size of Terminal Opening mm(in)	Size of Conductor that the Terminal Will Accommodate mm ² (AWG/kcmil)	kVA Range for Low-Voltage Rating of:	120/240 V	15.9 (5/8)	14 mm ² (AWG No. 6) solid to 100 mm ² (AWG No. 4/0) stranded copper conductor	15& below	20.6 (13/16)	30 mm ² (AWG No. 2) solid to 700 mm ² (350 kcmil) stranded copper conductor	25-50	23.8 (15/16)	50 mm ² (AWG No. 1/0) solid to 1000 mm ² (500 kcmil) stranded copper conductor	75		
Size of Low-Voltage Terminals and Conductor Range																			
Size of Terminal Opening mm(in)	Size of Conductor that the Terminal Will Accommodate mm ² (AWG/kcmil)	kVA Range for Low-Voltage Rating of:																	
		120/240 V																	
15.9 (5/8)	14 mm ² (AWG No. 6) solid to 100 mm ² (AWG No. 4/0) stranded copper conductor	15& below																	
20.6 (13/16)	30 mm ² (AWG No. 2) solid to 700 mm ² (350 kcmil) stranded copper conductor	25-50																	
23.8 (15/16)	50 mm ² (AWG No. 1/0) solid to 1000 mm ² (500 kcmil) stranded copper conductor	75																	
	<p><u>Polarity</u></p> <p>Transformers supplied under this specification shall have the polarity specified in Table below.</p> <table><tr><th colspan="2">Transformer Polarity</th></tr><tr><th>KVA Range</th><th>Transformer Primary Voltage Rating Primary 7620/ 13200 Y V</th></tr><tr><td>167 kVA and below</td><td>Additive</td></tr></table>	Transformer Polarity		KVA Range	Transformer Primary Voltage Rating Primary 7620/ 13200 Y V	167 kVA and below	Additive												
Transformer Polarity																			
KVA Range	Transformer Primary Voltage Rating Primary 7620/ 13200 Y V																		
167 kVA and below	Additive																		

	<p><u>Tank</u></p> <ul style="list-style-type: none"> • The transformer tank shall be made of steel. It shall be of sealed type construction with a steel cover. The tank cover shall be provided with a reusable gasket. The tank cover shall be grounded to the tank body using a copper strap adequately sized for the short-circuit rating of the transformer. • The tank shall be provided with a tank grounding connector located near the base of the tank. The connector shall be eyebolt-type, made from tinned copper alloy material, and designed to accommodate 8 mm² (AWG No. 8) to 30 mm² (AWG No. 2) stranded copper conductors. • Standard support lugs shall be provided on-the tank wall for securely mounting the transformer on the pole. The type of support lug to be provided corresponding to the transformer size shall be as shown in IEEE Std C57.12.20, latest revision. • Lifting lugs shall be permanently attached near the top of the transformer tank to allow for a balanced vertical lift. The design of the lifting lugs shall incorporate a safety factor of 5. • Lifting facilities for the core-coil assembly shall be provided. • The tank should have surge arrester mounting for LA adjacent to the high-voltage bushing. It shall consist of two steel pads with a 1/2 inch-13 NC tapped holes 11 mm (0.44 in) deep and located on the side of the tank in line vertically with the high voltage bushing. The arrester mounting provisions shall have centerline-to-centerline spacing as shown in IEEE Std C57.12.20, latest revision. Corrosion-resistant flanged cup shall be installed to protect the threaded opening of the unused arrester mounting pads • The correct oil level at 25 °C shall be marked inside the tank. • The tank shall be painted with two (2) coats of outdoor type, light gray paint conforming to Munsell Notation 5BG7.0/0.4, AN S170 Gray, over a suitable prime coat. 		
--	--	--	--

	<p><u><i>Tank Markings</i></u></p> <ul style="list-style-type: none"> Transformer kVA rating shall be painted in black using 3-inch block letters and numerals. The location of the kVA marking shall be below the low-voltage bushings. 		
	<p><u><i>Tap Changer</i></u></p> <ul style="list-style-type: none"> The transformer shall be provided with a tap changer designed for de-energized operation only. The tap changer shall be provided with an external operating handle mounted on the tank wall that can be rotated in a clockwise direction from a high tap voltage to low tap voltage. It shall be provided with stops when rotating from the highest to the lowest tap positions and shall be designed to prevent accidental operation by requiring a preliminary step before the tap setting can be changed. A caution: "DO NOT OPERATE WHEN ENERGIZED" shall be marked near the tap changer operating handle, clearly visible to the operator. Tap positions are painted and caution markings are marked with reflectorized, non-weathering decals at least 25 mm (1.0 inch) high. The numeral "1" shall be assigned to the highest tap. 		
	<p><u><i>Pressure Relief Valve</i></u></p> <ul style="list-style-type: none"> The transformer shall be provided with a pressure relief valve located on the tank above the expected 140 °C top-oil level to be determined by the manufacturer. The pressure relief valve shall be provided with a pull ring which when pulled using a standard hot-stick, will vent out pressure to atmospheric level. It shall be capable of withstanding a static pull force of 11.34 kg (25 pounds) for one minute without permanent deformation. 		

	<ul style="list-style-type: none">• The venting port on the outward side of the valve-head scat shall be protected from entry of dust, moisture, and insects before and after any valve operation. An indicating device shall he provided to warn an observer on the ground that the pressure relief valve has operated.• The venting and sealing characteristic of the valve shall be as follows:<ul style="list-style-type: none">a) Venting pressure: 69 kPa (10 psig) ± 13 kPa (gauge) (2 psig);b) Resealing pressure: 42 kPa (gauge) (6 psig) minimum;c) Zero leakage from reseal pressure to minus 56 kPa (gauge) (8 psig)d) Flow at 103 kPa (gauge) (15 psig) = 16.5 L/s (35 SCFM) minimum, corrected for air pressure of 101 kPa (14.7 psi) (absolute) and air temperature of 21°C.		
	<p><u>Enclosure Integrity</u></p> <ul style="list-style-type: none">• The completely assembled transformer enclosure shall be of sufficient strength to withstand an internal pressure of 49 kPa (gauge) (7 psig) without permanent distortion to the enclosure.• The enclosure shall also be of sufficient strength to withstand an internal pressure of 138 kPa (gauge) (20 psig) without rupturing or displacing components (excluding the cover gasket and gasket oil leaks) of the transformer.		
	<p><u>Insulating Liquid</u></p> <p>The transformer shall be filled with unused mineral oil meeting the requirements of the latest revision of ASTM D3487 (Specification for Mineral Insulating Oil Used in Electrical Apparatus).</p>		

	<p><u>Hardware</u></p> <p>All energized hardware, i.e., bolts, nuts and washers, shall be made of tinned copper alloy material such as silicon bronze or equivalent. All other hardware shall be hot-dip galvanized.</p>		
	<p><u>Nameplate</u></p> <ul style="list-style-type: none"> • The transformer shall be provided with a nameplate in accordance with the latest revision of IEEE Std C57.12.00. The nameplate shall be made of stainless steel with the technical information etched on the surface and coated with black enamel. • The following minimum information shall appear on the nameplate: <ul style="list-style-type: none"> a) Serial number; b) Class; c) Number of phases; d) Frequency e) Voltage rating f) kVA rating g) Temperature rise, °C h) Polarity; i) Percent Impedance; j) BIL; k) Total weight, kg; l) Connection diagram; m) Name of manufacturer; n) Installation and operating instructions reference; o) The word "Transformer"; p) Type of insulating liquid (generic); q) Conductor material for each winding; r) Equipment identification number. 		

Tests	<p><u>Routine Tests</u></p> <p>Each transformer shall be subjected to the following routine production tests in accordance with procedures specified in IEEE Std C57.12.00 and IEEE Std C57.12.90, latest revisions:</p> <ul style="list-style-type: none">a) Winding resistance measurement tests;b) Ratio Test;c) Polarity test and Phase Relation;d) No-Load Losses and Excitation Current at rated voltage and frequency;e) Impedance voltage and Load loss measurement;f) Induced Potential Test (Low-Frequency Dielectric Test);g) Mechanical (Leak Test);h) Dielectric Test of Insulating Oil; <p>The manufacturer shall conduct the Routine and Design Tests to verify that the Distribution Transformers comply with the requirements of this standard. The Member ECs reserve the right to witness the Routine and Design Tests. and the Supplier shall notify the Member ECs fifteen (15) days before each test is to be conducted. The Supplier is required to furnish the Member ECs with copies of all test reports.</p>		
	<p><u>Design Tests</u></p> <p>Copies of certified test reports shall be submitted as proof of meeting the requirements in the following design tests:</p> <ul style="list-style-type: none">a) Temperature Rise;b) Lightning Impulse;c) Insulation Power Factor;d) Insulation Resistance;		

<p align="center"><i>Detailed Technical Specifications for: Items G to J (Transformer, Pole Type, Conventional, Amorphous, 10 kVA to 37.5 kVA, Cu-Cu-Al Winding)</i></p>			
Particulars	Specifications Prescribed in Bidding Documents	Statement of Compliance	Details of Added Technical Specifications (if any)
Scope	This Technical Specification covers the single-phase, overhead-type, oil-immersed, self-cooled, amorphous core, brand new and PCB-Free distribution transformers under Items G to J, with primary voltage rating of 7620/13200 Y V, and secondary voltage rating of 120/240 V.		
Site and Service Conditions	<p>Transformers conforming to this specification shall be suitable for operation at rated kVA in a tropical environment and under the following service conditions:</p> <ul style="list-style-type: none"> • Maximum altitude above sea level - 1000 m • Maximum ambient temperature - 40° C • Average ambient temperature - 30° C 		
Applicable Standards	<p>All transformers furnished under this specification shall be designed, manufactured and tested to meet or exceed the requirements of the latest revision of the following IEEE, ANSI/IEEE, NEMA and ASTM Standards or equivalent IEC standards:</p> <ul style="list-style-type: none"> • IEEE Std C57.12.00 - Standard General Requirements for Liquid-Immersed Distribution, Power, and Regulating Transformers • IEEE Std C57.12.20 - Requirements for Overhead-Type Distribution Transformers, 500 kVA and Smaller; High-voltage, 13200 Volts and Below; Low-voltage, 7970/13800 Y Volts and Below • IEEE Std C57.12.70 - Terminal Markings and Connections for Distribution and Power Transformers 		

	<ul style="list-style-type: none">• IEEE Std - Standard Test Code for Liquid-Immersed Distribution, Power, and Regulating Transformers and Guide for Short Circuit Testing of Distribution and Power Transformers C57.12.90• ANSI/IEEE Std - Guide for Loading Mineral-Oil-Immersed Power Transformers C57.92• NEMA Standards - Transformers, Regulators and Reactors Publication No. TR 1• ASTM D3487 - Specifications for Mineral Insulating Oil Used in Electrical Apparatus											
Environmental Compliance	PCB Free											
Electrical Characteristics	<p><u>Voltage and Rating Taps</u></p> <ul style="list-style-type: none">• The transformer primary voltage rating shall be specified based on the rating shown in the Table below: <table><tr><th colspan="3">Standard Primary Voltage Ratings of Transformers</th></tr><tr><th>Nominal System Voltage(V)²</th><th>Primary Voltage Rating(V)³</th><th>Secondary Voltage Rating(V)</th></tr><tr><td>7620/ 13200</td><td>7620/ 13200 Y</td><td>120/240</td></tr></table> <ul style="list-style-type: none">• The transformer shall have a no-load tap changer to provide Two (2) - 2 ½ % tap above and Two (2) - 2½ taps below the rated primary voltage. Tap 3 shall be set as the nominal tap for the secondary voltage. All tap ratings shall be at rated capacity.	Standard Primary Voltage Ratings of Transformers			Nominal System Voltage(V) ²	Primary Voltage Rating(V) ³	Secondary Voltage Rating(V)	7620/ 13200	7620/ 13200 Y	120/240		
Standard Primary Voltage Ratings of Transformers												
Nominal System Voltage(V) ²	Primary Voltage Rating(V) ³	Secondary Voltage Rating(V)										
7620/ 13200	7620/ 13200 Y	120/240										

	<p><u>Frequency</u></p> <p>The transformer shall be designed to operate at 60Hz.</p>																							
	<p><u>KVA Ratings</u></p> <p>The kVA rating shall be continuous and based on not exceeding either a 65°C average winding temperature rise or an 80°C hottest-spot temperature rise above an ambient of 30°C. The temperature rise of the insulating oil shall not exceed 65°C when measured near the top of the tank.</p>																							
	<p><u>Insulation Level</u></p> <p>The transformer shall be designed to have coordinated insulation levels at its terminals not less than values specified in the Table below.</p> <table><tr><th colspan="3">Transformer Dielectric Insulation Levels</th></tr><tr><th>Insulation Level</th><th>7620/ 13200 Y V</th><th>120/240 V</th></tr><tr><td>Full Wave (BIL) in kV, crest</td><td>95</td><td>30</td></tr><tr><td>Chopped Wave in kV, crest</td><td>105</td><td>33</td></tr><tr><td>Min. time to Flashover in us</td><td>1.8</td><td>1.0</td></tr><tr><td>Applied Voltage Test (kV rms)</td><td>-</td><td>10</td></tr><tr><td>Induced Voltage Test (phase to ground) (kV rms)</td><td>17</td><td>1.4</td></tr></table>	Transformer Dielectric Insulation Levels			Insulation Level	7620/ 13200 Y V	120/240 V	Full Wave (BIL) in kV, crest	95	30	Chopped Wave in kV, crest	105	33	Min. time to Flashover in us	1.8	1.0	Applied Voltage Test (kV rms)	-	10	Induced Voltage Test (phase to ground) (kV rms)	17	1.4		
Transformer Dielectric Insulation Levels																								
Insulation Level	7620/ 13200 Y V	120/240 V																						
Full Wave (BIL) in kV, crest	95	30																						
Chopped Wave in kV, crest	105	33																						
Min. time to Flashover in us	1.8	1.0																						
Applied Voltage Test (kV rms)	-	10																						
Induced Voltage Test (phase to ground) (kV rms)	17	1.4																						

<u>Percent Impedance</u>											
<ul style="list-style-type: none"> Transformers shall have impedance values as specified in the table below. 											
<table border="1"> <tr> <th colspan="3">Standard Primary Voltage Ratings of Transformers</th></tr> <tr> <th>kVA Range</th><th>% Impedance</th><th>% Tolerance</th></tr> <tr> <td>3 thru 50</td><td>2.0</td><td>±10%</td></tr> </table>			Standard Primary Voltage Ratings of Transformers			kVA Range	% Impedance	% Tolerance	3 thru 50	2.0	±10%
Standard Primary Voltage Ratings of Transformers											
kVA Range	% Impedance	% Tolerance									
3 thru 50	2.0	±10%									
<ul style="list-style-type: none"> Difference in impedance between transformers of the same rating, when two or more units are produced by one manufacturer at the same time, shall not exceed 7.5% of the specified value. 											

<u>Losses</u>																																				
<ul style="list-style-type: none"> Transformer losses shall be based on reference temperatures of 30°C for No-Load Losses and 85°C for Load Losses. The No-Load Losses and Load Losses of the transformer unit shall not exceed the values specified in Table below. 																																				
<table border="1"> <tr> <th colspan="5">Transformer Maximum Losses</th></tr> <tr> <th rowspan="2">kVA Rating</th><th rowspan="2">No-Load Loss (w)</th><th rowspan="2">Load Loss (w)</th><th colspan="2">Total Losses</th></tr> <tr> <th>Watts</th><th>% of rate kVA</th></tr> <tr> <td>10</td><td>12</td><td>120</td><td>132</td><td>1.32</td></tr> <tr> <td>15</td><td>15</td><td>195</td><td>210</td><td>1.4</td></tr> <tr> <td>25</td><td>18</td><td>290</td><td>308</td><td>1.23</td></tr> <tr> <td>37.5</td><td>30</td><td>360</td><td>390</td><td>1.04</td></tr> </table>					Transformer Maximum Losses					kVA Rating	No-Load Loss (w)	Load Loss (w)	Total Losses		Watts	% of rate kVA	10	12	120	132	1.32	15	15	195	210	1.4	25	18	290	308	1.23	37.5	30	360	390	1.04
Transformer Maximum Losses																																				
kVA Rating	No-Load Loss (w)	Load Loss (w)	Total Losses																																	
			Watts	% of rate kVA																																
10	12	120	132	1.32																																
15	15	195	210	1.4																																
25	18	290	308	1.23																																
37.5	30	360	390	1.04																																
<ul style="list-style-type: none"> Actual transformer losses shall not exceed the values guaranteed in the bid by the manufacturer by 10% for No-Load Losses and 6% for Total Losses. 																																				

	<u>Short Circuit Characteristics</u> The transformer shall withstand the mechanical and thermal stresses produced by external short-circuit currents specified in IEEE Std C57.12.00, latest revision.							
	<u>Loading Capability</u> The transformer shall be guaranteed to have the loading capability in accordance with ANSI/IEEE Std C57.92, latest revision.							
	<u>Audible Sound Level</u> Transformers shall be designed so that the average sound level does not exceed the values specified in the Table below. <table><tr><th colspan="2">Transformer Audible Sound Level Limit</th></tr><tr><th>kVA Range</th><th>Average Sound Level (Decibels)</th></tr><tr><td>50 and below</td><td>48</td></tr></table>	Transformer Audible Sound Level Limit		kVA Range	Average Sound Level (Decibels)	50 and below	48	
Transformer Audible Sound Level Limit								
kVA Range	Average Sound Level (Decibels)							
50 and below	48							
Construction	<u>Cooling Class</u> The cooling method employed for transformers supplied under this specification shall be self-cooled (OA or ONAN).							
	<u>Core-Coil Assembly</u> <ul style="list-style-type: none">Transformer core shall be manufactured using either low-loss high-permeability grain-oriented amorphous metal core.Transformer Windings shall be of high-conductivity Copper or Aluminum [(Cu-Cu) or (Cu-Al)].The core and coil assembly shall be mounted rigidly in the tank. The assembly shall not shill in direction during shipping, handling, installation, or during normal operation due to vibrations.The core and coil assembly shall be vacuum processed to ensure maximum penetration of the insulating liquid to the coil insulation system.							

	<p><u>Primary Bushings</u></p> <ul style="list-style-type: none">• The transformer shall be furnished at the primary side with optional cover-mounted high-voltage bushing. The number and characteristics of bushing/s are shown in Table below. <table><tr><th colspan="2">Transformer Primary Bushing Number and Characteristics</th></tr><tr><th rowspan="2">High-Voltage Bushing Number and Characteristics</th><th>Transformer Primary Voltage Rating</th></tr><tr><th>7620/ 13200 Y V</th></tr><tr><td>Number</td><td>2</td></tr><tr><td>Voltage Class (kV)</td><td>15</td></tr><tr><td>BIL Withstand (kV, min.)</td><td>95</td></tr><tr><td>60 Hz Withstand, 1-min dry (kV, min.)</td><td>35</td></tr><tr><td>60 Hz Withstand, 10-s dry (kV, min.)</td><td>30</td></tr><tr><td>Minimum Creepage Distance, mm (in)</td><td>255(10)</td></tr></table> <ul style="list-style-type: none">• The high-voltage bushings shall be made from high-grade, wet- process porcelain with the entire exposed surface to be glazed. The color of the bushings shall be Light Gray ANSI 70, Munsell Notation 5BG 7.0/0.4.• The high-voltage bushings shall be designated as H1 & H2 (for double bushing transformer) and shall be arranged in accordance with the latest revision of IEEE Std C57.12.20.	Transformer Primary Bushing Number and Characteristics		High-Voltage Bushing Number and Characteristics	Transformer Primary Voltage Rating	7620/ 13200 Y V	Number	2	Voltage Class (kV)	15	BIL Withstand (kV, min.)	95	60 Hz Withstand, 1-min dry (kV, min.)	35	60 Hz Withstand, 10-s dry (kV, min.)	30	Minimum Creepage Distance, mm (in)	255(10)		
Transformer Primary Bushing Number and Characteristics																				
High-Voltage Bushing Number and Characteristics	Transformer Primary Voltage Rating																			
	7620/ 13200 Y V																			
Number	2																			
Voltage Class (kV)	15																			
BIL Withstand (kV, min.)	95																			
60 Hz Withstand, 1-min dry (kV, min.)	35																			
60 Hz Withstand, 10-s dry (kV, min.)	30																			
Minimum Creepage Distance, mm (in)	255(10)																			
	<p><u>Secondary Bushings</u></p> <ul style="list-style-type: none">• The transformer shall be furnished at the secondary side with sidewall-mounted, low-voltage bushings. The number and characteristics of the low-voltage bushings are shown in the Table below.																			

		Transformer Secondary Bushing Number and Characteristics					
		Low-Voltage Bushing Number and Characteristics	Transformer Secondary Voltage Rating				
			120/240 V				
		Number	3				
		Voltage Class (kV)	1.2				
		BIL Withstand (kV, min.)	30				
		60 Hz Withstand, 1-min dry (kV, min.)	10				
		60 Hz Withstand, 10-s dry (kV, min.)	6				
		<ul style="list-style-type: none">• The low-voltage bushings shall be made from high-grade, wet- process porcelain with the entire exposed surface to be glazed. The color of the bushings shall be Light Gray ANSI 70, Munsell Notation 5BG 7.0/0.4.• The low-voltage-bushings shall be designated as X1, X2 and X3 depending on the transformer secondary voltage rating, and shall be arranged in accordance with the latest revision of IEEE Std C57.12.20.					
	<u>Bushing Terminals</u>						
	<ul style="list-style-type: none">• The high-voltage bushing and high-voltage neutral bushing shall be equipped with eyebolt-type connectors made from tinned copper-alloy material and provided with stainless steel spring washers. The terminal connectors shall accommodate 8 mm² (AWG No. 8) solid to 30 mm² (AWG No. 2) stranded copper conductor. Terminal detail shall be in accordance with the latest revision of IEEE Std C57.12.20.• The low-voltage bushings shall be equipped with tinned copper alloy, eyebolt-type connectors or tinned spade terminal pads, arranged for vertical takeoff of cables. Size of terminal openings and cables, and type of spade terminal pads are shown in Table below.						

	<table><tr><th colspan="3">Size of Low-Voltage Terminals and Conductor Range</th></tr><tr><th rowspan="2">Size of Terminal Opening mm(in)</th><th rowspan="2">Size of Conductor that the Terminal Will Accommodate mm² (AWG/kcmil)</th><th>kVA Range for Low-Voltage Rating of:</th></tr><tr><th>120/240 V</th></tr><tr><td>15.9 (5/8)</td><td>14 mm² (AWG No. 6) solid to 100 mm² (AWG No. 4/0) stranded copper conductor</td><td>15& below</td></tr><tr><td>20.6 (13/16)</td><td>30 mm² (AWG No. 2) solid to 700 mm² (350 kcmil) stranded copper conductor</td><td>25-50</td></tr></table> <ul style="list-style-type: none">Terminal details shall be in accordance with IEEE Std C57.12.20, latest revision.Terminal markings shall be in accordance with IEEE Std C57.12.70, latest revision.	Size of Low-Voltage Terminals and Conductor Range			Size of Terminal Opening mm(in)	Size of Conductor that the Terminal Will Accommodate mm ² (AWG/kcmil)	kVA Range for Low-Voltage Rating of:	120/240 V	15.9 (5/8)	14 mm ² (AWG No. 6) solid to 100 mm ² (AWG No. 4/0) stranded copper conductor	15& below	20.6 (13/16)	30 mm ² (AWG No. 2) solid to 700 mm ² (350 kcmil) stranded copper conductor	25-50		
Size of Low-Voltage Terminals and Conductor Range																
Size of Terminal Opening mm(in)	Size of Conductor that the Terminal Will Accommodate mm ² (AWG/kcmil)	kVA Range for Low-Voltage Rating of:														
		120/240 V														
15.9 (5/8)	14 mm ² (AWG No. 6) solid to 100 mm ² (AWG No. 4/0) stranded copper conductor	15& below														
20.6 (13/16)	30 mm ² (AWG No. 2) solid to 700 mm ² (350 kcmil) stranded copper conductor	25-50														
<p><u>Polarity</u></p> <p>Transformers supplied under this specification shall have the polarity specified in Table below.</p> <table><tr><th colspan="2">Transformer Polarity</th></tr><tr><th>KVA Range</th><th>Transformer Primary Voltage Rating Primary 7620/ 13200 Y V</th></tr><tr><td>167 kVA and below</td><td>Additive</td></tr></table>	Transformer Polarity		KVA Range	Transformer Primary Voltage Rating Primary 7620/ 13200 Y V	167 kVA and below	Additive										
Transformer Polarity																
KVA Range	Transformer Primary Voltage Rating Primary 7620/ 13200 Y V															
167 kVA and below	Additive															
<p><u>Tank</u></p> <ul style="list-style-type: none">The transformer tank shall be made of steel. It shall be of sealed-type construction with a steel cover. The tank cover shall be provided with a reusable gasket. The tank cover shall be grounded to the tank body using a copper strap adequately sized for the short-circuit rating of the transformer.The tank shall be provided with a tank grounding connector located near the base of the tank. The connector shall be eyebolt-type, made from tinned																

	<p>copper alloy material, and designed to accommodate 8 mm² (AWG No. 8) to 30 mm² (AWG No. 2) stranded copper conductors.</p> <ul style="list-style-type: none">• Standard support lugs shall be provided on-the tank wall for securely mounting the transformer on the pole. The type of support lug to be provided corresponding to the transformer size shall be as shown in IEEE Std C57.12.20, latest revision.• Lifting lugs shall be permanently attached near the top of the transformer tank to allow for a balanced vertical lift. The design of the lifting lugs shall incorporate a safety factor of 5.• Lifting facilities for the core-coil assembly shall be provided.• The tank should have surge arrester mounting for LA adjacent to the high-voltage bushing. It shall consist of two steel pads with a 1/2 inch-13 NC tapped holes 11 mm (0.44 in) deep and located on the side of the tank in line vertically with the high voltage bushing. The arrester mounting provisions shall have centerline-to-centerline spacing as shown in IEEE Std C57.12.20, latest revision. Corrosion-resistant flanged cup shall be installed to protect the threaded opening of the unused arrester mounting pads• The correct oil level at 25 °C shall be marked inside the tank.• The tank shall be painted with two (2) coats of outdoor type, light gray paint conforming to Munsell Notation 5BG7.0/0.4, ANSI70 Gray, over a suitable prime coat.		
	<p><u>Tank Markings</u></p> <ul style="list-style-type: none">• Transformer kVA rating shall be painted in black using 3-inch block letters and numerals. The location of the kVA marking shall be below the low-voltage bushings.		

	<p><u>Tap Changer</u></p> <ul style="list-style-type: none">• The transformer shall be provided with a tap changer designed for de-energized operation only. The tap changer shall be provided with an external operating handle mounted on the tank wall that can be rotated in a clockwise direction from a high tap voltage to low tap voltage. It shall be provided with stops when rotating from the highest to the lowest tap positions and shall be designed to prevent accidental operation by requiring a preliminary step before the tap setting can be changed. A caution: "DO NOT OPERATE WHEN ENERGIZED" shall be marked near the tap changer operating handle, clearly visible to the operator.• Tap positions are painted and caution markings are marked with reflectorized, non-weathering decals at least 25 mm (1.0 inch) high. The numeral "1" shall be assigned to the highest tap.		
	<p><u>Pressure Relief Valves</u></p> <ul style="list-style-type: none">• The transformer shall be provided with a pressure relief valve located on the tank above the expected 140 °C top-oil level to be determined by the manufacturer.• The pressure relief valve shall be provided with a pull ring which when pulled using a standard hot-stick, will vent out pressure to atmospheric level. It shall be capable of withstanding a static pull force of 11.34 kg (25 pounds) for one minute without permanent deformation.• The venting port on the outward side of the valve-head scat shall be protected from entry of dust, moisture, and insects before and after any valve operation. An indicating device shall be provided to warn an observer on the ground that the pressure relief valve has operated.• The venting and sealing characteristic of the valve shall be as follows:		

	<p>a) Venting pressure: 69 kPa (10 psig) \pm 13 kPa (gauge) (2 psig);</p> <p>b) Resealing pressure: 42 kPa (gauge) (6 psig) minimum;</p> <p>c) Zero leakage from reseal pressure to minus 56 kPa (gauge) (8 psig)</p> <p>d) Flow at 103 kPa (gauge) (15 psig) = 16.5 L/s (35 SCFM) minimum, corrected for air pressure of 101 kPa (14.7 psi) (absolute) and air temperature of 21°C.</p>		
	<p><u>Enclosure Integrity</u></p> <ul style="list-style-type: none"> • The completely assembled transformer enclosure shall be of sufficient strength to withstand an internal pressure of 49 kPa (gauge) (7 psig) without permanent distortion to the enclosure. • The enclosure shall also be of sufficient strength to withstand an internal pressure of 138 kPa (gauge) (20 psig) without rupturing or displacing components (excluding the cover gasket and gasket oil leaks) of the transformer. 		
	<p><u>Insulating Liquid</u></p> <p>The transformer shall be filled with unused mineral oil meeting the requirements of the latest revision of ASTM D3487 (Specification for Mineral Insulating Oil Used in Electrical Apparatus).</p>		
	<p><u>Hardware</u></p> <p>All energized hardware, i.e., bolts, nuts and washers, shall be made of tinned copper alloy material such as silicon bronze or equivalent. All other hardware shall be hot-dip galvanized.</p>		
	<p><u>Nameplate</u></p> <ul style="list-style-type: none"> • The transformer shall be provided with a nameplate in accordance with the latest revision of IEEE Std C57.12.00. The nameplate shall be made of stainless steel with the technical information etched on the surface and coated with black enamel. 		

	<ul style="list-style-type: none"> • The following minimum information shall appear on the nameplate: <ol style="list-style-type: none"> a) Serial number; b) Class; c) Number of phases; d) Frequency e) Voltage rating f) kVA rating g) Temperature rise, °C h) Polarity; i) Percent Impedance; j) BIL; k) Total weight, kg; l) Connection diagram; m) Name of manufacturer; n) Installation and operating instructions reference; o) The word “Transformer”; p) Type of insulating liquid (generic); q) Conductor material for each winding; r) Equipment identification number. 		
Tests	<p><u><i>Routine Tests</i></u></p> <p>Each transformer shall be subjected to the following routine production tests in accordance with procedures specified in IEEE Std C57.12.00 and IEEE Std C57.12.90, latest revisions:</p> <ol style="list-style-type: none"> a) Winding resistance measurement tests; b) Ratio Test; c) Polarity test and Phase Relation; d) No-Load Losses and Excitation Current at rated voltage and frequency; e) Impedance voltage and Load loss measurement; f) Induced Potential Test (Low-Frequency Dielectric Test); g) Mechanical (Leak Test); h) Dielectric Test of Insulating Oil; 		

	The manufacturer shall conduct the Routine and Design Tests to verify that the Distribution Transformers comply with the requirements of this standard. The Member ECs reserve the right to witness the Routine and Design Tests. and the Supplier shall notify the Member ECs fifteen (15) days before each test is to be conducted. The Supplier is required to furnish the Member ECs with copies of all test reports.		
	<u>Design Tests</u> Copies of certified test reports shall be submitted as proof of meeting the requirements in the following design tests: a) Temperature Rise; b) Lightning Impulse; c) Insulation Power Factor; d) Insulation Resistance.		

Company Name:

_____ [Name of Bidder]

Authorized Representative:

_____ [Name and Signature of Authorized Representative]

Contact Details:
