


NOTES:

1. GROUNDING ROD TO BE MINIMUM COPPER COATED, 8 FT LENGTH, $\frac{1}{2}$ DIAMETER
2. GROUNDING ROD CLAMP TO BE BRONZE OR COPPER COATED AND SIZED FOR GROUNDING CABLE
3. GROUNDING CONDUCTOR TO BE SOLID COPPER, 12 AWG TO 2 AWG, AND SECURELY LANDED AT GROUNDING ROD CLAMP AND CONTROL PANEL GROUNDING LUG
4. ALL PENETRATIONS IN CONTROL PANEL TO BE 1P68 RATED
5. MAXIMUM 6 IN OF GROUNDING ROD EXPOSED ABOVE GROUND



GROUNDING ROD DETAIL

GENERIC



OPTIRTC, INC.
98 NORTH WASHINGTON ST.
SUITE 210
BOSTON, MA 02114
(844) 678-4782

GROUNDING ROD GENERIC

NOT FOR CONSTRUCTION
REFERENCE USE ONLY
NOT TO SCALE
© OPTIRTC, INC. 2026
ALL RIGHTS RESERVED

REVISED: 04/14/2026

DRAWING NUMBER:
GR-1