

PUBLIC NOTICE MANDATORY LANGUAGE CODING
Tier 2 violation/Non-acute

Mandatory Language for Surface Water Treatment Technique Violation

SURFACE WATER TREATMENT TECHNIQUE: NON-ACUTE

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

The **City of Roma WTP**, PWS ID **TX 2140007**, failed to meet the minimum treatment technique requirements for the month of **November 2025**. Specifically, our water system had a combined filter effluent turbidity reading above 1.0 NTU.

Violation List:

- combined filter effluent turbidity readings above 1.0 NTU.

The City of Roma WTP has taken the following corrective actions to prevent the recurrence of the violation: On 11/19/2025 at approximately 08:00 am while performing maintenance on our equipment (Turbidity Meters) our CFE meter spiked to a reading above 1.0 NTU for 15 minutes. We are taking cautionary measures to avoid another occurrence.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact **Jose A Vela** at **956-847-7006**
Posted /Delivered on: **11/26/2025**
