

Key Business Communication

To Company	Attention / Key Contact	Reason For Sending
All FirePro UK Approved Ambassadors	Board Level	New revision of FirePro Condensed Aerosol Generator Safety Data Sheet (SDS)

Executive Summary

The new revision of FirePro Condensed Aerosol Generator Safety Data Sheet (SDS) applies to all FirePro Condensed Aerosol Generators, with the revision comes a revised UN classification from UN 3268 (SAFETY DEVICES, ELECTRICALLY INITIATED, CLASS 9 IDG), to UN 3559 (FIRE SUPPRESSANT DISPERSING DEVICES, CLASS 9 IDG).

FirePro Systems Ltd has completed the required conformity assessments and obtained the relevant approvals from a competent authority for the shipment of its products under Class 9 UN3559 (Fire Suppressant Dispersing Devices).

New General Use of FirePro Safe Guards - 03.09.2026 document now available outlining changes.

Required Action

The latest SDS, reflecting the adoption of UN3559 for transport by road, is recommended to be available to handlers and couriers in printed form.

All FirePro Condensed Aerosol Generators must always be transported in the packaging as sent to the consignee, with appropriate labelling and marking meeting the criteria of UN3559 which will be provided on the packaging as sent to the consignee. This also applies to decommissioned and expired generators which have been removed but not activated and are transported for disposal and recycling purposes.

Expected Results

Ongoing compliance with the updated guidelines as outlined in the revised SDS.
 Replace any previous version of the SDS in your files with the enclosed Version 2026-4.
 Ensure the SDS is accessible to relevant staff (e.g. facilities, EHS, logistics) and, where units are transported by road, available to drivers in printed form.
 Confirm your storage conditions align with the requirements above.
 Contact us before returning, relocating, or disposing of any unit.

References

- SDS-5000 Version 2026-4 which can be found [HERE](#).
- General Use of FirePro Safe Guards - 03.09.2026 which can be found [HERE](#).

Issued By	Checked By	Issue Date	Ref	
OH	TH	03/09/2026	KBC1005	



Product
Certificate No. 1417a



FirePro UK is certified by BSI to ISO 9001 and is an active subscribing member of the following trade associations