

Permit # FRHR:

Corona Fire Department

NOTICE OF DEFENSIBLE SPACE INSPECTION

	FIRE		
Applicant Name:		Inspection Address:	
Inspection No 1 2 3 Inspector Name:		Contact Number:	No Violations Observed
	e of Defensible Space Inspection		
	department representative has inspected your proper ion(s) indicated below. Failure to correct these violation	-	=
ZONE 1: Within 30 feet of all structures or to the property line:			
	Remove all branches within 10 feet of any chimney or stovepipe outlet.		PRC § 4291(a)(4) 14 CCR § 1299.03(a)(2)
	Remove leaves, needles or other vegetation on roofs, gutters, decks, porches, stairways, etc.		PRC § 4291 (a)(6) 14 CCR § 1299.03(a)(1)
	Remove all dead and dying trees, branches and shrubs or other plants adjacent to or overhanging buildings.		PRC § 4291 (a)(5) 14 CCR § 1299.03(a)(2)
	Remove all dead and dying grass, plants, shrubs, trees, branches, leaves, weeds, and needles.		14 CCR § 1299.03(a)(1)
	Remove or separate live flammable ground cover and shrubs.		PRC § 4291(a)(1) BOF General Guidelines item 1
	Remove flammable vegetation and items that could catch fire which are adjacent to or below combustible decks, balconies, and stairs.		14 CCR § 1299.03(a)(4)
	Relocate exposed wood piles outside of Zone1 unless completely covered in a fire resistive material.		14 CCR § 1299.03(a)(3)
ZONE 2: Within 30-100 feet of all structures or to the property line:			
	Cut annual grasses and forbs to a maximum of 4 inc	hes in height.	14 CCR § 1299.03(b)(2)(B)
	Remove fuels in accordance with the Fuel Separation or Continuous Tree Canopy guidelines.		BOF General Guidelines item 4
	All exposed woodpiles must have a minimum of ten feet (10 feet) clearance, down to bare mineral soil, in all directions.		14 CCR § 1299.03(b)(2)(C)
	Dead and dying woody surface fuels and aerial fuels surface litter, normally consisting of fallen leaves or r and small branches, shall be permitted to a maximur	needles, twigs, bark, cones,	14 CCR § 1299.03(b)(2)(A)
ZONE 3: Within 100 feet of all structures or to the property line:			
	Logs or stumps embedded in the soil must be remove vegetation.		BOF General Guidelines item 3
Other Requirements:			
	Outbuildings and Liquid Propane Gas (LPG) storage (10 ft.) of clearance to bare mineral soil and no flamr additional ten feet (10 ft.) around their exterior		14 CCR § 1299.03(c)(1)
	Address numbers shall be displayed in contrasting or readable from the street or access road	olors (4" min. size) and	2013 CFC § 505.1
	Equip chimney or stovepipe openings with a metal so between 3/8 inch and 1/2 inch	creen having openings	2013 CBC § 2113.9.2.
Comments:			
Fire Department Use Only: Received Date: Processed by: Assigned Inspector:			
Received Date: Processed by: Assigned Inspector:			

Permit Fee Each: \$170.00

Paid: