



CITY OF CORONA LOCAL LIMITS

CONSTITUENT	LIMIT
Arsenic	0.40 mg/L
B.O.D.*	2830 mg/L
Barium	13.45 mg/L
Boron (WS+1 mg/L)	1.3 mg/L
Cadmium	0.02 mg/L
Chloride (WS+200 mg/L)	277 mg/L
Chloroform	0.031 mg/L
Chromium (T)	1.2 mg/L
Cobalt	2.2 mg/L
Copper	2.2 mg/L
Cyanide	0.08 mg/L
Fluoride (WS+1 mg/L)	1.24 mg/L
Hardness (WS+100 mg/L)	343 mg/L
Iron	46 mg/L
Lead	0.60 mg/L
Manganese	0.85 mg/L
Mercury	0.02 mg/L
Nickel	0.40 mg/L
O&G (P)	100 mg/L
O&G (T)*	1355 mg/L
PCBs	0.1 mg/L
Pesticides	0.1 mg/L
pH	5.0-10.5 units
Phenols	8.7 mg/L
Selenium	0.016 mg/L
Silver	0.60 mg/L
Sodium (WS+200 mg/L)	269 mg/L
Sulfate (WS+100 mg/L)	253 mg/L
Sulfide	0.10 mg/L
T.D.S. (WS+1000 mg/L)	1507 mg/L
T.S.S.*	8300 mg/L
T.T.O.	0.58 mg/L
Zinc	1.54 mg/L

WS = Water Supply

BOD, TSS, and TOG concentrations greater than the established limit of 250 mg/L may be subject to surcharge fee to be established by the Utilities Department.