



# **MAINTENANCE CONSULTANCY SUCCESS STORIES**



## OFF-SHORE GAS LIFT COMPRESSOR WELDING RUPTURES

APPLICATION	Floating production storage and offloading (FPSO)
COMPRESSOR TYPE	Reciprocating compressor – 3 stg.
SERVICE	Gas lift compressor
NAMEPLATE POWER	1050 kW
DISCH. PRESSURE	120 bara



*Examples of inadequate supports for piping and instruments*

### CHALLENGE:

#### **SUDDEN WELDING RUPTURES ON MINOR BRANCHES**

- high vibrations since the first start-up
- skid design failed to consider alternating forces
- poor support design

### SOLUTION:

- acoustical study revealed the necessity for:
  - restriction orifices
  - new support installation

**CRITICAL VIBRATIONS LOWERED BELOW THE SWRI DANGER VALUE.  
NO FAILURES OCCURRED SINCE MODIFICATIONS**



## HIGH PIPING VIBRATIONS

END USER	HDPE plant
COMPRESSOR TYPE	n°2 Reciprocating compressors – 3 stg.
SERVICE	C <sub>2</sub> H <sub>2</sub> feed gas
NAMEPLATE POWER	355 kW
DISCH. PRESSURE	29 bara

### CHALLENGE:

#### UNEXPECTED TRIPS FOR GAS LEAKAGE

- welding ruptures of the inlet nozzle on piping
- acoustic resonance and poor piping clamping

### SOLUTION:

- installation of restriction orifices
- stiffening of the existing piping structure
- optimization of clamps disposition

#### CONTINUOUS RUN AVOIDING UNSCHEDULED TRIPS



## EXCESSIVE RIDER BAND WEAR

APPLICATION	Paper mill
COMPRESSOR TYPE	Reciprocating compressor – 1 stg.
SERVICE	30 MW Gas turbine fuel supply
NAMEPLATE POWER	500 kW
DISCH. PRESSURE	37 bara

### CHALLENGE:

#### **FORCED MAINTENANCE EVERY 3 MONTHS**

- rapid wearing of PTFE piston sealing elements


### SOLUTION:

- high performance PEEK material suggested
- scheduled temperature monitoring program

**COMPRESSOR HAS REACHED 8000 HOURS WITH THE SAME PISTON RINGS, AND IS STILL RUNNING**



*Cylinder internal, piston and bands*



*Bearing Vibration Spectrum*

## GAS TURBINE START-UP FAILURE

APPLICATION	Natural gas extraction plant
MACHINE TYPE	Two Double-shaft Heavy-duty Gas Turbines
SERVICE	Power generation
NAMEPLATE POWER	5 MW

### CHALLENGE:

#### TURBINE COULD NOT START

- high vibrations, both low and high frequency, after maintenance stop

### SOLUTION:

- substitution of some bearings with 4-lobe types (low-frequency vibrations)
- trim balancing (for synchronous vibration)

#### TURBINE COULD START AND RUN REGULARLY



*Old bearing*






*New bearing*

## IGC START-UP FAILURE




*Damaged bearing pad and impeller*

APPLICATION	Steel mill
COMPRESSOR TYPE	Integrally geared centrifugal compressor - 3 stg.
SERVICE	Furnace air compressor
NAMEPLATE POWER	4000 kW
DISCH. PRESSURE	50 bara

Item	Mode shape	UNL F (CPM)			
		A	B	C	D
1		10255	4578	4643	4594
2		/	6548	/	6840
3		10774	7462	7565	7605

*Bearing load*



*Lateral analysis*

### CHALLENGE:

#### BEARINGS DESTROYED AFTER FIRST START-UP, FOR TWO TIMES


- high vibrations
- major damages to bearings and impeller

### SOLUTION:

- increased clearances on new bearings
- check of the rotor design
- check of the new bearing arrangement

#### COMPRESSOR STARTED AND STILL WORKING REGULARLY





*Sketch of casing bow*

## STEAM TURBINE FAILURE

END USER	Floating Storage & Regasification Unit (FSRU)
MACHINE TYPE	Steam Turbine
SERVICE	Power generation
NAMEPLATE POWER	10 MW

### CHALLENGE:

#### TURBINE TRIP DURING COMMISSIONING START-UP

- severe damages to the rotors
- casing bow (non uniform expansion), resulting from an insufficient thermal insulation of the casing

### SOLUTION:

- re-calculation of the thickness of the thermal insulation
- suggested correct procedure for turbine warm-up
- revised seals radial clearance

#### TURBINE STARTED AND STILL WORKING REGULARLY



*Rubbing of blades*



*Bottom half cylinder insulation blanket thickness*

## EXCESSIVE PACKING SEAL WEAR



*Ruined packing rings*

APPLICATION	Refinery
COMPRESSOR TYPE	Reciprocating compressor – 2 stg.
SERVICE	Penex process compressor
NAMEPLATE POWER	90 kW
DISCH. PRESSURE	80 bara

### CHALLENGE:

#### ROD PACKING ELEMENTS LIFE WAS <1000 HOURS

- recurrent rod scratching
- chromium on the rod surface

### SOLUTION:


- roughening treatment to increase the transfer film capacity
- suggested high performance PEEK material

#### ROD PACKING ELEMENTS LIFE WAS BROUGHT TO ~8000 HOURS



*Rod wearing*





INGRESSO	26	13.5	25
META*	255	200	15
USCITA	40	24	26
TUBI LATERALI (Basso/Alto)	170/16		150/22
BASAMENTO LATO COMPRESSORE	1.5	1.1	6.0
BASAMENTO META*	4.5	1.2	5.0
BASAMENTO LATO OPPOSTO	1.0	<1	4.8

Cooler vibration

## VIBRATIONS OF AN LDPE HIGH PRESSURE COOLER

APPLICATION	Low Density Polyethylene Plant
COMPRESSOR TYPE	Reciprocating compressor – 2 stg.
SERVICE	LDPE process secondary compressor
NAMEPLATE POWER	5800 kW
DISCH. PRESSURE	3200 bara

### CHALLENGE:

### RUPTURES ON PIPES AND SUPPORTS (EVERY 2-3 MONTHS)


- high vibrations (up to 250 mm/s rms)
- supporting structure inadequacy
- any modification had to be performed in just one week

### SOLUTION:

- optimized modifications verified with FEM
- foundations reinforced through grouting
- follow-up survey to confirm root cause analysis and resolution


**ALL VIBRATIONS LOWERED BELOW SWRI DANGER VALUE.**

**NO FAILURES OCCURRED SINCE MODIFICATIONS**




FEM analysis made to optimize cooler structure reinforcement

## GAS TURBINE CABINET EXPLOSION



*Modified P&I*



*Lube oil tank sketch*

APPLICATION

Gas extraction plant

MACHINE TYPE

Heavy-duty Gas Turbine

SERVICE

Centrifugal compressor drive

NAMEPLATE POWER

10 MW



*Turbine Cabinet*

### CHALLENGE:

#### EXPLOSION IN THE TURBINE CABINET

- failure of oil trap level control loop
- vent line clogged

### SOLUTION:


- lube oil tank fill-up procedure
- lube oil vent system modified

**EVENT DID NOT OCCUR ANYMORE**





*Bearing failures*



*New bush design*

## STIRRER BEARING RUPTURE

APPLICATION

Low Density Polyethylene Plant

MACHINE TYPE

Stirrer of an autoclave reactor

### CHALLENGE:

**BEARING HAD TO BE SUBSTITUTED EVERY 3 MONTHS**


- reported also one catastrophic rupture

### SOLUTION:

- new bush design
- superbolt style tightening method
- detailed tightening procedure

**TWO INSPECTIONS IN THE LAST YEAR REVEALED THAT BEARING WAS STILL FINE**

## TEMPORARY STRAINER CLOGGING



*Temporary strainer schematic*

APPLICATION

Refinery

COMPRESSOR TYPE

Centrifugal compressor

SERVICE


Mild Hydrocracking make-up compress

NAMEPLATE POWER

900 kW

DISCH. PRESSURE

90 bara



*FEM analysis  
results*

### CHALLENGE:

**$\Delta P$  ON A TEMPORARY STRAINER QUICKLY ROSE TO  $\sim 1.3$  BAR**

- customer could not stop production before scheduled maintenance



### SOLUTION:

- finite element analysis and a buckling analysis
- maximum sustainable pressure drop  $\sim 4$  bar

**CUSTOMER STOPPED AFTER ONE YEAR AS SCHEDULED**



## RECIP. COMPRESSOR HIGH VIBRATION (DIAGNOSTIC)



Correlation between rotation speed and vibration

APPLICATION	Gas extraction plant
COMPRESSOR TYPE	Reciprocating compressor – 1 stg.
SERVICE	Gas compression LP
NAMEPLATE POWER	700 kW
DISCH. PRESSURE	30 bara

### CHALLENGE:


#### PERIODICAL HIGH VIBRATION

- correlation between rotation speed and high vibration
- mechanical resonant frequencies

### SOLUTION:

- keep rotation speed over a minimum level

**AVOIDED POSSIBLE FAILURES CAUSED BY HIGH VIBRATIONS**



*Vibration trends*



*Cylinders*

## RECIP. COMPRESSOR HIGH LOAD (DIAGNOSTIC)

APPLICATION	Petrochemical plant
COMPRESSOR TYPE	Reciprocating compressor – 2 stg.
SERVICE	HC Polymerization
NAMEPLATE POWER	1800 kW
DISCH. PRESSURE	40 bara

### CHALLENGE:

#### TWO CYLINDER-DISTANCE PIECE TIE-RODS FOUND BROKEN

- high cylinder vibrations
- high pin load caused by higher suction pressure


### SOLUTION:

- 2<sup>nd</sup> stage cylinder bore diameter modified
- high-resistance rolled thread tie-rods
- volume bottles size increased

#### VIBRATIONS AND PIN LOAD RETURNED TO THE ALLOWABLE VALUES



## RECIP. COMPRESSOR COUPLING FAILURE (DIAGNOSTIC)



APPLICATION	Gas extraction plant
COMPRESSOR TYPE	Reciprocating compressor – 3 stg.
SERVICE	Gas reinjection
NAMEPLATE POWER	1600 kW
DISCH. PRESSURE	150 bara

### CHALLENGE:

#### INCREASING DRIVER FRONT BEARING VIBRATION

- found damaged coupling

### SOLUTION:

- coupling substitution

**AVOIDED UNSCHEDULED STOP AND POSSIBLE CATASTROPHIC FAILURES**



*Damaged coupling*

*Competence at work for Service and Innovation*



[www.cstfirenze.com](http://www.cstfirenze.com)