



CERTIFICATE OF ACCREDITATION

The ANSI National Accreditation Board

Hereby attests that

**Brand Services
39 Kings Highway, Suite A
Gales Ferry, CT 06335**

Fulfills the requirements of

ISO/IEC 17020:2012

In the field of

INSPECTION

This certificate is valid only when accompanied by a current scope of accreditation document.
The current scope of accreditation can be verified at www.anab.org.

A handwritten signature in black ink, appearing to be 'J. Stine', is positioned above a horizontal line.

Jason Stine, Vice President

Expiry Date: 25 September 2026

Certificate Number: AI-3310



An inspection body's fulfilment of the requirements of ISO/IEC 17020:2012 means the inspection body meets both the technical competence requirements and management system requirements that are necessary for it to consistently deliver technically valid inspection results (refer to joint ISO-ILAC-IAF Communiqué dated Sept 2013).

SCOPE OF ACCREDITATION TO ISO/IEC 17020:2012

Brand Services
39 Kings Highway, Suite A
Gales Ferry, CT 06335
Joe Galaski jgalaski@brans-svs.com

**INSPECTION
TYPE A (THIRD PARTY) BODY**

Valid to: **September 25, 2026**

Certificate Number: **AI-3310**

Fire Doors and Other Opening Protectives

Items, Materials OR Products Inspected	Type and Range of Inspection	Methods and Procedures
Verification of Fire Protection Rating for Fire Door Frames	In Service	IP-001 Inspection Procedure (supported by ANSI/SDI 250.8 & NFPA 80 6.3)
Verification of Fire Protection Rating for Swinging Steel Fire Doors	In Service	IP-001 Inspection Procedure (supported by ANSI/SDI 250.8 & NFPA 80 5.2.3.5)
Verification of Fire Protection Rating for Swinging Wood Fire Doors	In Service	IP-001 Inspection Procedures (supported by ANSI/WDMA I.S. 1A-13 & NFPA 80 5.2.3.5)
Verification of Fire Protection Rating for Exit Hardware	In Service	IP-001 Inspection Procedure (supported by manufacture specifications)

Fire Doors and Other Opening Protectives

Items, Materials OR Products Inspected	Type and Range of Inspection	Methods and Procedures
<p>Field Labeling of Fire Protection Rating for Steel Fire Doors and Frames</p>	<p>In Service</p>	 <p>60 MINUTE RATING</p> <p>FIELD INSPECTED & LABELED</p> <p>SN:</p> <p>FIRE RATED DOOR/FRAME</p> <p>NFPA 80 5.1.4-5.1.5 ANSI/SDI 250.8</p> <p>DO NOT REMOVE OR PAINT LABEL</p>  <p>BRAND SERVICES 888.551.4055</p> <p>IP-001 Inspection Procedure (supported by ANSI/SDI 250.8 / NFPA 80 5.1.4 – 5.1.5)</p>

Fire Doors and Other Opening Protectives

Items, Materials OR Products Inspected	Type and Range of Inspection	Methods and Procedures
<p>Field Labeling of Fire Protection Rating for Wood Fire Doors</p>	<p>In Service</p>	<p style="text-align: center;">90 MINUTE RATING</p> <hr/> <p style="text-align: center;">FIELD INSPECTED & LABELED</p> <hr/> <p>SN:</p> <p style="text-align: center;">FIRE RATED DOOR/FRAME</p> <p style="text-align: center;">NFPA 80 5.1.4-5.1.5 ANSI/WDMA I.S. 1A-13</p> <hr/> <p style="text-align: center;">DO NOT REMOVE OR COVER LABEL</p> <div style="text-align: center;">  <p>BRAND SERVICES 888.551.4055</p> </div> <p>IP-001 Inspection Procedure (supported by ANSI/WDMA I.S. 1A-13 NFPA 80 5.1.4 – 5.1.5)</p>

Fire Doors and Other Opening Protectives

Items, Materials OR Products Inspected	Type and Range of Inspection	Methods and Procedures
Field Labeling of Fire Exit Devices	In Service	<div style="border: 1px solid black; padding: 5px;"> <p style="text-align: center;">FIELD INSPECTED</p> <hr/> <p>SN:</p> <p style="text-align: center;">FIRE EXIT HARDWARE</p> <p style="text-align: center;">PER MANUFACTURER SPECIFICATIONS</p> <div style="text-align: center;">  </div> <div style="text-align: center;">  <p>BRAND SERVICES <small>LIFE SAFETY COMPLIANCE & ACCREDITATION</small> 888.551.4055</p> </div> </div> <p>IP-001 Inspection Procedure (supported by manufacture specifications)</p>

Fire Doors and Other Opening Protectives

Items, Materials OR Products Inspected	Type and Range of Inspection	Methods and Procedures
Field Labeling of Fire Protection Plates	In Service	<div style="border: 1px solid black; padding: 5px;"> <p style="text-align: center;">PROTECTION PLATE</p> <hr/> <p style="text-align: center;">FIELD INSPECTED & LABELED</p> <hr/> <p>SN:</p> <p style="text-align: center;">FIRE RATED</p> <p style="text-align: center;">FIRE DOOR ACCESSORY</p> <p style="text-align: center;">NFPA 80 5.1.4-5.1.5 ANSI/BHMA 156.6</p> <hr/> <p style="text-align: center;">DO NOT REMOVE OR PAINT LABEL</p> <div style="text-align: center;">  <p>BRAND SERVICES 888.551.4055</p> </div> </div> <p>IP-001 Inspection Procedure (supported by NFPA 80 5.1.4-6.1.5 / ANSI/BHMA 156.6)</p>

Note:

1. STONINGTON SERVICES, LLC dba Brand Services
2. This scope is formatted as part of a single document including Certificate of Accreditation No. AI-3310.



Jason Stine, Vice President