

FILTER POT *MIDI*

Assembly Instructions

Fit all BSP Filter Pot components together, using a suitable sealing compound on all valves and fittings.

AUTO AIR VENT



AIR VENT ASSEMBLY



2 1/2" DIRTY FLOW ASSEMBLY



PRESSURE GAUGE

(install after insulation jacket)



24L STAINLESS STEEL VESSEL BODY



2 1/2" CLEAN RETURN ASSEMBLY



1/2" FILL/ DRAIN ASSEMBLY



TUNDISH ASSEMBLY




MAGNET GRATE

(inside the Vessel)




SATAINLESS STEEL BAFFLE PLATE

(inside the vessel)



ANTI MICROBIAL FILTER CARTRIDGE

(inside the vessel)



2 PIECE INSULATION JACKET



Building Services Products Ltd



The unit is under pressure!
Risk of potential scalding
in heating systems.
Wear appropriate PPE.



Building Services Products Limited reserves the right to change and/or amend details, specifications and/or dimensions of the BSP Filter Pot Mini at any time and without notice. Version 3.0 06/2026