# REACTION TO FIRE

**Applicant:**

ZFOAM ESPAÑA, S.L.

P.I. ALFAJARIN, PARCELA 10
ES-50172 ALFAJARÍN
Zaragoza

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2023AN2457.

## CLASSIFICATION OF REACTION TO FIRE OF:
## CONSTRUCTION PRODUCTS

**Nº: 23AN2457**

The sample referenced as:

**"Zetatunel Alu 12 mm "**

has been tested according to the standards EN ISO 11925-2:2020 and EN 13823:2020. The classification according to standard EN 13501-1:2018 is:

**"B-s2,d0"**

Date: 26/10/2023 12:53:23
Digitally Signed by:DAVID MARSET GIMENO - NIF:21697288P

Date of Issue

26th of October 2023

Celia Dolçà
Head of Fire Behaviour lab.

Plaza Emilio Sala, 1 · Alcoy (Alicante) 965542200 · info@aitex.es
www.aitex.es