

Approval Number 2209568
Test Report: MA7594/C/1



5th February 2025

Uppercross Enterprises Ltd.
Belgard Square North,
Tallaght,
Dublin,
D24 X8CT

Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYPROPYLENE- COMPONENTS.

5260

'Agriflow PN16 Compression Fittings'. Black coloured, injection moulded polypropylene fittings. For use with water up to 23°C.

APPROVAL NUMBER: 2209568

APPROVAL HOLDER: UPPERCROSS ENTERPRISES LTD.

The Scheme reserves the right to review approval.
Approval 2209568 is valid between September 2022 and September 2027

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

Ian Hughes
WRAS Approvals Manager