





PLAN



ELEVATION


**GENERAL NOTES:**

1. Concrete Strength: Design strength  $f'_c = 5000$  psi
2. Reinforcing: ASTM A775 Grade 60, Epoxy coated
3. Cover to reinforcing: 2 1/2" u.n.o.

| LPB18X30X66 - BILL OF MATERIALS / EMBEDS |                                    |      |    |          |
|------------------------------------------|------------------------------------|------|----|----------|
| CSI ID#                                  | DESCRIPTION                        | QTY  | UM | COMMENTS |
| SBO                                      | 1" CONDUIT SWEEP                   | 1    | EA |          |
| SBO                                      | 3" CONDUIT SWEEP                   | 2    | EA |          |
| SBO                                      | ANCHOR BOLT TEMPLATE               | 1    | EA |          |
| RM-00014                                 | REBAR #4 EPOXY GR 60               | 46   | LB |          |
| RM-00018                                 | REBAR #6 EPOXY GR 60               | 61   | LB |          |
| MX-FA5000SM                              | MIX DESIGN FLY ASH 5000 SUMMER MIX | 0.83 | CY |          |

**All Rebar to be Epoxy Coated**

| LPB18X30X66 Rebar Schedule |     |         |  |
|----------------------------|-----|---------|--|
| MK                         | QTY | LENGTH  |  |
| 401 #4                     | 4   | Varies  |  |
| 402 #4                     | 4   | Varies  |  |
| 601 #6                     | 8   | 5' - 1" |  |



REINFORCING DETAIL



Concrete Systems Inc.  
9 Commercial St., Hudson, NH, 03051  
Phone 603-889-4163  
Fax 603-889-2417

STATE AGENCY

Drawn By

Date

Concrete Cu. Yd.  
0.83

Weight in Tons  
1.68

Approved By

Date

A

Drawing Title

Drawing No.

LPB18X30X66

REV

0

Quantity:

Project No:

SHEET 1 OF 1