

This **Annual Water Quality Report** has been developed to keep you informed about Augusta Water's drinking water quality. Augusta Water is committed to supplying safe water that meets or exceeds state and federal regulations and achieves the highest standards of customer satisfaction.

This report includes details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies.

Please take a few minutes to read this report.

**Where Does Your Water Come From?** Augusta Water purchases water from the City of Staunton for the Rt. 250 West Water System. Sources of this drinking water include groundwater from Gardner Springs and surface water from two reservoirs; Elkhorn and Staunton.

#### **Source Water Assessment**

A source water assessment has been completed by the Virginia Department of Health. More specific information may be obtained by contacting Augusta Water at (540) 245-5670.

#### **How Is Your Water Treated?**

Water enters the Staunton Treatment Plant from the reservoirs or Gardner Springs. Treatment includes:

(1) **Screening** – removes leaves, sticks, and other large debris; (2) **Prechlorination** – kills most disease-causing organisms; (3) **Flash Mix** – chemicals are added and mixed with raw water containing fine particles that will not readily settle or filter out; (4) **Flocculation** – gathers together fine, light particles to form larger particles to aid the settling and filtering processes; (5) **Sedimentation** – settles out large suspended particles; (6) **Filtration** – filters out remaining suspended particles; (7) **Postchlorination** – kills any remaining disease-causing organisms; and (8) **Fluoridation\*** – added to water for cavity prevention.

\*Staunton suspended fluoridation in March 2023 to allow for a system update. The work is contracted for 2026.

The treated water is distributed via an extensive underground piping system and is delivered to your home.

#### **Stay Informed!**

Augusta Water is committed to providing you with information about your water supply, because customers who are well informed are our best allies in supporting improvements necessary to maintain the highest drinking water standards. Refer to the following resources for additional information on drinking water.

American Water Works Association (AWWA) at [www.awwa.org/](http://www.awwa.org/)

Water Environment Federation (WEF) at [www.wef.org/](http://www.wef.org/)

[waterdata.usgs.gov](http://waterdata.usgs.gov) and [www.epa.gov/ground-water-and-drinking-water/](http://www.epa.gov/ground-water-and-drinking-water/)

Safe Drinking Water Hotline (800) 426-4791

Virginia State Health Department (Lexington) (540) 463-7136 [www.vdh.virginia.gov/drinking-water/](http://www.vdh.virginia.gov/drinking-water/)

Monthly Board Meetings are held on the third Thursday of each month at the Augusta Water Field Operations and Facility Maintenance training room located at 846 Laurel Hill Road, Verona. Meetings start at 1:30 p.m.

## **Substances Expected To Be In Drinking Water**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the land's surface or through the ground, it dissolves naturally occurring minerals and radioactive material, and can be polluted by animals or human activity.

Contaminants that may be present in source water include:

Microbiological contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm runoff, industrial or domestic waste water discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems.

Radioactive materials, which can be naturally occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791) or the Virginia State Health Department (540-463-7136).

## **Lead Contaminants**

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Augusta Water is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Augusta Water at (540) 245-5681. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney or nervous system problems.

## **Who's Most Vulnerable?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer under- going chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. Environmental Protection Agency (EPA) and Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

We constantly monitor for various contaminants in the water supply to meet all regulatory requirements. This table lists only the regulated contaminants which had some level of detection in 2025. Many other contaminants have been analyzed but were not present or were below the detection limits of the lab equipment.

### Treated Water Quality Roundup

Substance	Highest Level Allowed (EPA's MCL*)	Highest Level Detected	Ideal Goals (EPA's MCLGs*)	Meets EPA Standards	Date Most Recent Testing Completed	Possible Sources
<b>Regulated at the Treatment Plant</b>						
Alpha Emitters**	15 pCi/L	0.264 pCi/L	0 pCi/L	✓	January 2022	Erosion of natural deposits
Beta Emitters**	50 pCi/L	0.035 pCi/L	0 pCi/L	✓	January 2022	Decay of natural and man-made deposits
Combined Radium**	5 pCi/L	1.395 pCi/L	0 pCi/L	✓	January 2022	Erosion of natural deposits
Turbidity***	TT = 0.3 NTU	0.202 Max. NTU 100%***	N/A	✓	2025, Daily	Soil runoff
Fluoride	4 ppm	<0.2 ppm	4 ppm	✓	January 2025	Water additive
Nitrate Plus Nitrite as Nitrogen	10 ppm	0.66 ppm	10 ppm	✓	January 2025	Runoff from fertilizer use; leaching from sewage; erosion of natural deposits
Chlorine	MRDL = 4ppm	RAA: 1.41 ppm Range: 0.86-1.97 ppm	MRDLG = 4ppm	✓	2025, Daily	Water additive used to control microbes
Barium	2 ppm	0.0213 ppm	2 ppm	✓	January 2025	Erosion of natural deposits
Total Organic Carbon (TOC's)	TT	100 % of required removal	N/A	✓	Quarterly 2025	Naturally present in the environment
<b>Regulated at the Customers' Tap</b>						
Lead ** (90th Percentile)	15 ppb Action Level (AL)	ND ppb 0 of 5 exceeded the AL Range: ND	0 ppb	✓	Sept 2023	Customer plumbing and service connection
Copper ** (90th Percentile)	1.3 ppm Action Level (AL)	0.082 ppm 0 of 5 exceeded the AL Range: 0.007 to 0.109	1.3 ppm	✓	Sept 2023	
<b>Regulated in the Distribution System</b>						
Total Trihalomethanes (TTHM)	80 ppb	46.4 ppb	0 ppb	✓	August 2025	By-product of drinking water chlorination
Haloacetic Acid (HAA)	60 ppb	19 ppb	0 ppb	✓	August 2025	
<p>*Definitions:  <u>(AL) Action Level</u> - The concentration of a contaminant which, if exceeded, triggers a treatment or other requirements which a water system must follow.  <u>(MCL) Maximum Contaminant Level</u> - Highest level of a contaminant that is allowed by EPA in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.  <u>(MCLG) Maximum Contaminant Level Goal</u> - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.  <u>(MRDL) Maximum Residual Disinfectant Level</u> - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.</p>				<p><u>(MRDLG) Maximum Residual Disinfectant Level Goal</u> - The level of a drinking water disinfectant below which there is no known or expected health risk. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.  <u>ND</u> - None detected  <u>(NTU) Nephelometric Turbidity Unit</u> - A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.  <u>(RAA) Running Annual Average</u> - the average of analytical results for samples taken during the previous four calendar quarters.  <u>pCi/L</u> - Picocuries per liter is a measure of the radioactivity in water.  <u>ppb</u> - one part per billion, example is a single penny in \$10,000,000.  <u>ppm</u> - one part per million, example is a single penny in \$10,000.  <u>(TT) Treatment Technique</u> - A required process intended to reduce the level of a contaminant in drinking water.</p>		

\*\*Data presented in the table are the most recent testing performed in accordance with federal and state regulations. The state allows us to monitor for some contaminants less than once a year because the concentrations of these contaminants do not change frequently. Some of our data, though accurate, is more than one year old.

\*\*\*Percent (%) represents the lowest monthly percentage samples which met the turbidity limits. Compliance for turbidity is based on the level being less than or equal to 0.3 NTU in 95% of the measures taken each month. Turbidity has no health effects; however, it can interfere with disinfection and provide a medium for bacterial growth.

### Additional Water Quality Parameters

Parameter	Detected Level	Suggested Limit	Sample Date
Alkalinity	7.5-161 ppm	No Standard	Quarterly 2025
Hardness	128-163 ppm*	No Standard	Monthly 2025
Sodium	3.35 ppm	No Standard	January 2025
Iron	0.0016	No Standard	January 2025

\*This water is considered moderately hard to hard. (equivalent to 7.5-9.5 grains per gallon)

### Service Line Inventory

In 2021, the Environmental Protection Agency (EPA) released the Revised Lead and Copper Rule, requiring water utilities to inventory all public and private water service lines within their distribution systems. The goal of this revision was to find and replace lead service lines. Augusta Water reviewed the public and private service lines using multiple methods including historical records, implementation dates of local, state and federal lead bans, field verification and an approved statistical method. We are pleased to report we did not find lead water service lines in the Rt. 250 West Water System.

The Rt. 250 West Water System Service Line Inventory is available for review upon request at the Augusta Water main office located in the Augusta County Government Center in Verona, Virginia.

### Additional Information

Augusta Water purchases water from the City of Staunton for the Route 250 West Water System. The City of Staunton has issued the following Notice of Violation for a monitoring failure in 2025.

#### **Notice of Violation**

#### **Failure to Monitor for Synthetic Organic Chemicals (SOCs)**

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2023-2025, we only tested once for, alachlor, atrazine, benzo(a)pyrene, carbofuran, chlordane, dalapon, di(2-ethylhexyl)adipate, di(2-ethylhexyl)phthalate, 1, 2,4-dichlorophenoxyacetic acid, dinoseb, endrin, heptachlor, heptachlor epoxide, hexachlorobenzene, hexachlorocyclopentadiene, lindane, methoxychlor, oxamyl, pentachlorophenol, picloram, polychlorinated biphenyls, simazine, toxaphene, 2,4,5-trichlorophenoxypropionic acid and therefore cannot be sure of the quality of your drinking water during that time.

We are required to collect two (2) samples for each of the above contaminants during each three-year monitoring period; however, we only collected one. Historically, the City of Staunton has not had any SOC's detected.

#### **What should I do?**

There is nothing you need to do at this time. You may continue to drink the water. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

#### **What is next to be done?**

We collected our 2026-2028 SOC's compliance samples in April, 2026 and will be collecting the required, second quarterly samples in July, 2026.

#### **What are SOC's?**

Synthetic Organic Compounds (SOCs) are a group of chemicals that the EPA has mandated to be monitored for in drinking water. This sampling is overseen by the Virginia Department of Health (VDH). These are man-made chemicals like pesticides, herbicides, and industrial pollutants. If detected, these chemicals may cause health effects such as liver and kidney problems, central nervous system and reproductive difficulties and may even increase the risk of certain kinds of cancers. As stated above, the City of Staunton has had no detections for SOC's in the past and has currently already sampled for SOC's in April, 2026 for our current 2026-2028 monitoring period.