

## দরপত্র আহ্বান

তারিখ: ১৯/০৫/২০২৬

বিষয় : অগ্নি প্রতিরোধ ব্যবস্থার জন্য প্রয়োজনীয় উপকরণ সরবরাহ ও স্থাপন।

সংস্থার বুরো প্রশিক্ষণ কেন্দ্র-সাভার এর ভবনের অগ্নি প্রতিরোধ ব্যবস্থার (Fire Protection & Fire Detection system.) জন্য প্রয়োজনীয় উপকরণ সরবরাহ ও স্থাপনে অভিজ্ঞ প্রতিষ্ঠান/কোম্পানীর নিকট থেকে নিম্নের শর্ত পূরণ এবং সংযুক্ত ফরমেট/তালিকা অনুযায়ী দরপত্র আহ্বান করা যাচ্ছে। বুরো বাংলাদেশ এর নিজস্ব ওয়েবসাইট [www.burobd.org](http://www.burobd.org) এর মাধ্যমে দরপত্র প্রকাশ করা হয়েছে।

মুখবন্ধ খামে দরপত্র আগামী ২২/০৬/২০২৬ তারিখ বেলা ১২ : ০০ ঘটিকার মধ্যে বুরো বাংলাদেশ, বাড়ি নং-১২/এ, রোড নং-১০৪, ব্লক নং-সি.ই.এন (এফ), গুলশান-২ এই ঠিকানায় দরপত্র বাক্স সরাসরি জমা করা যাবে এবং ঐ দিন বেলা ১২ : ৩০ ঘটিকার সময় দরদাতাদের উপস্থিতিতে (যদি কেউ উপস্থিত থাকেন) দরপত্র খোলা হবে।


বিবরণ:

#	বিবরণ	পরিমাণ
০১	Fire Protection, Fire Detection, Fire Door, & Fire Extinguisher system etc. Installation with all materials as per design	Full job

শর্তাবলী:

১. দরদাতা প্রতিষ্ঠানকে Fire Protection & Fire Detection system যন্ত্রপাতি আমদানী ও স্থাপনে বৈধ লাইসেন্সধারী হতে হবে।
২. নক্সা এবং সংযুক্ত ফরমেট অনুযায়ী প্রতিটি আইটেমের পার্শ্ব ব্র্যান্ড কান্ডি অব অরিজিন ও প্রস্তুতকারী দেশের নামসহ দর প্রদান এবং সকল মালামালের সংখ্যা ও ওয়ারেন্টি/গ্যারান্টির সময়সীমা উল্লেখ করতে হবে।
৩. ভ্যাট নিবন্ধনপত্র ও আয়কর সনদপত্রসহ কোম্পানীর অন্যান্য কাগজপত্র (ট্রেড লাইসেন্স, পূর্ববর্তী এ ধরনের কাজের গ্রাহকের তালিকা ও Bank Solvency Certificate) দরপত্রে সংযুক্ত করতে হবে।
৪. দুই নং শর্তে বর্ণিত দরপত্র প্রদানকারী প্রতিষ্ঠান কর্তৃক একটি প্রস্তুতকৃত পৃথক নক্সা দরপত্রের সাথে অবশ্যই দাখিল করতে হবে।
৫. দরদাতাগণকে আইটেম এর বিবরণ (যদি থাকে) সংযুক্ত করতে হবে।
৬. ত্রুটিযুক্ত ও অসম্পূর্ণ দরপত্র বাতিল বলে গণ্য হবে।
৭. কর্তৃপক্ষ সর্বনিম্ন দরপত্রদাতাকে কার্যাদেশ প্রদান করতে বাধ্য নয়।
৮. কর্তৃপক্ষ যে কোন সময় দরপত্র বাতিল ও গ্রহণ করার অধিকার সংরক্ষণ করেন।
৯. ভ্যাট এবং ট্যাক্স সরকারী বিধি মোতাবেক বিল হতে কর্তন করা হবে।
১০. কার্যাদেশ প্রাপ্তির ৬০ দিনের মধ্যে সকল কাজ সম্পন্ন করতে হবে।
১১. নির্বাচিত প্রতিষ্ঠানকে কার্যাদেশ প্রদানের সময় প্রতিষ্ঠানের সাথে একটি চুক্তিতে আবদ্ধ হতে হবে, ঐ সময় প্রতিষ্ঠানের নামে কাজের নিরাপত্তা ও জামানত হিসেবে কার্যাদেশে উল্লেখিত মোট মূল্যের ১০% টাকা ০২ বৎসর পর্যন্ত উল্লেখিত যন্ত্রাংশগুলির জামানত হিসেবে যে কোন সিডিউল ব্যাংক এর Bank Guarantee প্রদান করতে হবে। Bank Guarantee যাচাইয়ে কোন অসঙ্গতি পাওয়া গেলে সংশ্লিষ্ট প্রতিষ্ঠানের বিরুদ্ধে আইনগত ব্যবস্থা গ্রহণ করা হবে।
১২. বুরো বাংলাদেশ এর বুরো প্রশিক্ষণ কেন্দ্র - সাভার, হোল্ডিং নং-২২/২, ব্লক নং-এ, ওয়ার্ড নং-০৯, সিটিলেন, আনন্দপুর, সাভার, ঢাকা-এই ঠিকানায় অগ্নি প্রতিরোধ ব্যবস্থা স্থাপন করতে হবে।
১৩. ফায়ার সার্ভিস কর্তৃক অনুমোদিত নক্সা ও স্থাপত্যসহ অন্যান্য নক্সা সংগ্রহ ও প্রয়োজনীয় তথ্য ও অনুসন্ধানের জন্য যোগাযোগ: ১. মোঃ শামছুজ্জামান টুটুল, সহকারী কর্মকর্তা, সরবরাহ ও সেবা, ০১৭০৮-৪০৯৪৪২,

ধন্যবাদান্তে,

 19/05/2026

সহকারী সমন্বয়কারী -সরবরাহ ও সেবা  
বুরো বাংলাদেশ, প্রধান কার্যালয়।

### Head Office

House: 12/A, Road:104, Block: CEN (F), Gulshan-2, Dhaka-1212, Bangladesh  
Tel: +88-02-55059860-62, Hotline: 09610443322, Email: [buro@burobd.org](mailto:buro@burobd.org), Web: [www.burobd.org](http://www.burobd.org)

**BURO Bangladesh**

**Tender Schedule for Fire Protection & Detection System at Training Center-Saver.**

SL	Description of Items	Amount in BDT
A	Fire Protection/Hydrant system	0.00
B	Fire Detection system	0.00
C	Fire Door	0.00
D	Fire Entinguisher	0.00
<b>Total Amount in BDT(Vat and Tax As Per Govt. Rules) =</b>		<b>0.00</b>


*[Signature]*  
31/03/2026

*[Signature]*  
31/03/2026

BURO Bangladesh

Tender Schedule for Fire Protection, Detection System, Fire Door & Fire Gas Suppression at Training Center-Saver.

SL	Description of Items	Brand	Country of Origin	Country of Manufacturer	Period of Warranty	Unit	Qty	Unit Price	Total Price
(A)	Fire Protection/Hydrant system								
1	Fire Engine Driven Pump, 500 US GPM @ 9 Bar With Control Panel								
	Supply & installation of end suction, vertical discharge, direct coupled centrifugal Engine Driven Pump of capacity 500 US GPM at a head of 90 M of water c/w silencer, Radiator, 12V start & mounted base plate & coupling, 2900 rpm c/w Engine. Country of origin shall be JAPAN/USA/UK/ HOLLAND / CANADA/ GERMANY/ ITALY /UAE/ equivalent. with Battery & Cable					Nos	1.00		0.00
2	Jockey Pump, 20 US GPM @ 10 Bar with control Panel								
	Supply, installation of vertical multistage, direct coupled centrifugal pump of capacity 20 US GPM at a head of 100 M of water complete motor with Cable. Power supply shall be 415 V/50Hz, 3Phase 2950 rpm. Country of origin shall be JAPAN/USA/UK/ HOLLAND / CANADA/ GERMANY/ ITALY /UAE/ equivalent.					Nos	1.00		0.00
2	Fire Brigade Connection, 100mm, 2 Way					Nos	1.00		0.00
3	Supply & installation of fire brigade connection 4 way of 65mm dia complete with easy removable end cap with chain, companion flange, nut bolt gasket etc. Country of origin shall be SINGAPORE /JAPAN/ USA/ U K/ MALAYSIA/ equivalent.								
	Filler Hydrant-100mm, 2 way					Nos	1.00		0.00
	a) Supply and installation of Cast Iron body Double Headed Pillar Hydrant complete with Two (02) nos. cast brass made controllable outlet of 65mm dia with female instantaneous outlet, Inlet shall be 100mm dia flanged. Country of origin shall be SINGAPORE /JAPAN/ USA/ U K/ MALAYSIA/ equivalent.								
	Out door Hydrant box for hose pipe (Size: 40" x 30" x 10")					Nos	1.00		0.00
4	Supply & installation of hydrant steel cabinet of suitable size (as per site measurement and requirement / recommended by the Engineer in charge. The cabinet shall be with swing type door with or without breakable glass. The cabinet shall be made with 18 SWO sheet steel powder coated of red color. Country of origin shall be SINGAPORE /JAPAN/ USA/ U K/ MALAYSIA/ equivalent.								
5	Fire hose pipe, 65mm dia, 30 meter long UL Listed					Set	1.00		0.00
	Supply & installation of 1.5" dia hose pipe of 30 meter long. Nozzle shall also be hand control type for controlling the outflow of water to provide either a jet & spray to shut off the flow. The hose reel box shall be made with 18 SWG sheet steel powder coated of red color. Country of origin shall be SINGAPORE /JAPAN/ USA/ U K/ MALAYSIA/ equivalent.								
	Jet/Spray Nozzle 65mm dia					Nos	1.00		0.00
6	Supply and installation of jet /spray nozzle having 65 mm dia male instantaneous coupling. The nozzle shall be operable in three modes : jet-spray- shut off. The Nozzle shall be of aluminum and Nylon. Working pressure shall be not less than 7 KG/CM <sup>2</sup> . Flow shall be not less than 100lpm @7KG/cm <sup>2</sup> . Nozzle shall be install inside the cabinet. Country of origin shall be SINGAPORE /JAPAN/ USA/ U K/ MALAYSIA/ equivalent.								
6	Fire Hose Reel, 25mm dia, 30 meter long LPCB					Set	12.00		0.00
7	Supply & installation of 1" dia hose pipe of 30 meter long. Country of origin shall be SINGAPORE /JAPAN/ USA/ U K/ MALAYSIA/ equivalent.								
	65mm dia Oblique Landing Valve					Nos	6.00		0.00
	Supply and installation of hose Angle valve /Landing valve of 2 1/2" (65mm dia ) shall be made with brass /bronze with instantaneous female outlet. The valve shall be BS Kikmark approved and working pressure shall not be less than 10 Kg/cm <sup>2</sup> . Country of origin shall be SINGAPORE /JAPAN/ USA/ U K/ MALAYSIA/ equivalent.								
8	Valve & Accessories:								
9	Supply & installation of pipe accessories such as gate valve, non-return valve, flexible joint, foot valve etc. Pipe accessories shall be suitable to with stands a pressure of 200 psig. Valve above 65mm dia shall be of iron body flange end type complete with companion flange gaskets, nut bolts etc. Country of origin shall be SINGAPORE /JAPAN/ USA/ U K/ MALAYSIA/ equivalent.								
	Gate valve								
	100mm dia					Nos	2.00		0.00
10	80 mm dia					Nos	1.00		0.00
	Non-Return valve								
11	100mm dia					Nos	2.00		0.00
	80 mm dia					Nos	1.00		0.00
	Y Strainer								
	100 mm					Nos	1.00		0.00

  
31.03.26

  
31/3/26

SL	Description of Items	Brand	Country of Origin	Country of Manufacturer	Period of Warranty	Unit	Qty	Unit Price	Total Price
	50 mm					Nos	1.00		0.00
12	Flexible joint								
	100 mm					Nos	1.00		
	50 mm dia					Nos	2.00		0.00
13	Foot Valve / Anti Vortex Plate								
	100 mm					Nos	1.00		
	50 mm					Nos	1.00		
14	Ball valve								
	50mm dia					Nos	2.00		0.00
	25mm dia					Nos	18.00		0.00
15	Pressure gauge					Nos	3.00		0.00
	Supply & installation of pressure gauge shall be of dial type of 100 mm dia suitable to read 0 to 10 kg/cm <sup>2</sup> pressure & shall be complete with pet cock, pressure screw bar & nipple etc. Country of origin shall be SINGAPORE / JAPAN/ USA/ U K/ MALAYSIA/ equivalent.								
16	Pressure switch					Nos	2.00		0.00
	Supply & installation of pressure switch suitable to cut out & cut in to its pre-set pressure including all fitting & accessories. Country of origin shall be SINGAPORE / JAPAN/ USA/ U K/ MALAYSIA/ equivalent.								
17	Automatic vent valve					Nos	1.00		0.00
	Supply & installation of auto vent valve of floating type complete with inlet & outlet connection. The valve shall be suitable to connect with 3/4" dia pipe. Country of origin shall be SINGAPORE / JAPAN/ USA/ U K/ MALAYSIA/ equivalent.								
18	Black Steel Pipe for Hydrant & Sprinkler Pipe Work: Supply and installation of black steel pipe of schedule 40 welded type suitable to withstand a test pressure 15 kg of water complete with bends, tees, elbows, reducers, socket, union etc. as per drawing and direction. Cutting of pipe welding, threading and sealing the thread with proper type of sealing compound shall be done leak proof. Pipe work along with fittings shall be suitable to withstand a test pressure of 15 Kg/cm <sup>2</sup> . Required flanges shall be provided in main pipe as per direction All Pipe including M/S. materials including outside of Black steel pipe work shall be provided with two coats of cold galvanisation after proper cleaning. All underground pipes shall be protected with black tape wrapping. Earth cutting, filling with sand etc pipe support at an interval of 3 meter shall be done for out door underground pipe work. All pipe work shall be completed with support, bracket etc. complete as per drawing and direction. Country of origin shall be JAPAN/ KOREA/ MALAYSIA/ EQUIVALENT.								
	100mm dia					RFT	60.00		0.00
	80mm dia					RFT	220.00		0.00
	50mm dia					RFT	20.00		0.00
	25mm dia					RFT	20.00		0.00
19	Fitting & Others Items (Fire Hydrant)					Lot	1.00		0.00
20	Consumable Items (Fire Hydrant & Pump)					Lot	1.00		0.00
21	Installation, Testing & Commissioning					Lot	1.00		0.00
22	As Built Drawing					Lot	1.00		0.00
<b>Total Amount in BDT(Vat and Tax As Per Govt. Rules) =</b>									<b>0.00</b>



31.03.26

  
31/03/26

**BURO Bangladesh**

**Tender Schedule for Fire Protection, Detection System, Fire Door & Fire Gas Suppression at Training Center- Saver.**

SL	Description of Items	Brand	Country of Origin	Country of Manufacturer	Period of Warranty	Unit	Qty	Unit Price	Total Price
(B)	<b>Fire Detection System</b>								
1	<b>Conventional Type fire alarm control panel, 4 Zone with Battery, LPCB / EN Approved</b> Country of origin shall be UK/Malaysia/ Equivalent					Nos	1.00		0.00
2	<b>Manual Pull/Call Station, LPCB/EN Approved</b> Country of origin shall be Malaysia/ Equivalent					Nos	19.00		0.00
3	<b>Conventional Sounder with Strobe, LPCB / EN Approved</b> Country of origin shall be UK/Equivalent					Nos	13.00		0.00
4	<b>Fire resistance cable, LPCB / EN Approved 1.5 X 2C</b> Supply and Installation of Fire retardant type single/ multi core PVC insulated, PVC sheathed electrical cable of copper conductor of required size as per drawing and direction. Cable shall be complete with supply & return loop. The work shall be complete with water grade PVC conduit, conduit bends, tees, junction box, pull box etc. complete as per direction and standard. Cutting of walls floor, roof etc. mending good the damage shall be as per direction. Termination and cable jointing shall be done as per standard practice. Cable work shall be done as per drawing and direction. The Authority shall supply required power up to panel. The shall be able to with stand at 400°C. Installation of Fire resistance Cable shall be at location shown in the drawing and shall be as per recommendation of the manufacturer. Approved type of uPVC type shall be used					RM	500.00		0.00
5	<b>PVC Conduite, Fittings &amp; Accessories</b>					RM	500.00		0.00
6	<b>Exit Sign, Standard</b> Country of origin shall be Malaysia/ China /Equivalent					Nos	11.00		0.00
7	<b>Evacuation light, Standard</b> Emergency Light of 12 V complete with rechargeable battery and charger. Light shall be suitable for AC/DC. Power supply shall be 220V/ single phase					Nos	11.00		0.00
8	<b>Installation, Testing &amp; Commissioning (fire Detection)</b> After complete installation, testing, commissioning & balancing the system, the contractor shall have to hand over the system to the authority. After that maintenance period shall start. During installation and during maintenance period contractor shall have to provide training to the representatives of the owner.					Job	1.00		0.00
<b>Total Amount in BDT(Vat and Tax As Per Govt. Rules) =</b>									<b>0.00</b>

*[Signature]*  
31.03.26

*[Signature]*  
31/3/26

BURO Bangladesh

Tender Schedule for Fire Protection, Detection System, Fire Door & Fire Gas Suppression at Training Center-Barishal.

SL	Description of Items	Brand	Country of Origin	Country of Manufacturer	Period of Warranty	Unit	Qty	Unit Price	Total Price
	<p>(C) FIRE RATED DOOR WITH UL STANDARD ACCESSORIES                      Supply &amp; Installation of fire Rated Door completed with Panic Bar.                      The door shall be made with 1.5mm thick sheet steel painted with approved red color over a coat of primer. Thickness of the leaf shall be 40mm and filled with fire proof/ resisting materials of minimum two hours rated. The Panic bar shall be Horizontal type. Made of Aluminium Alloy / steel chrome plated. c/w with security lock to operated from outside. Door frame shall be made with same sheet steel of similar thickness. Hinges shall be quite smooth, robust and aligned properly. Peripheral clearance of the shutter should be as per standard code of practice. The opening of the door should be in one direction. Measurement of the door shall include Frame</p>								
1	Size: L- 1000 x H-2100mm					Nos	11		0
2	Size: L- 1525 x H-2100mm					Nos	3		0
3	Installation Charge (with out Civil work)					Nos	14		0
Total Amount in BDT (Vat and Tax As Per Govt. Rules) =									0


*M. Hossain*  
31.03.26

*31/03/2026*

**BURO Bangladesh**

**Tender Schedule for Fire Protection, Detection System, Fire Door & Fire Gas Suppression at Training Center- Saver.**

SL	Description of Items	Brand	Country of Origin	Country of Manufacturer	Period of Warranty	Unit	Qty	Unit Price	Total Price
<b>(D)</b>	<b>Fire Extinguisher</b>								
1	Fire Extinguisher ABC-5kg					Nos	10.00		0.00
	DRY CHEMICAL POWDER TYPE. Supply & fixing of the following capacities multi purpose ABC dry chemical powder stored pressure type with manometer system fire extinguisher suitable for repeated use complete with wall bracket, Nitrogen (N2) cartridge, easy refilling system etc. as per sample accepted & approved by the Engineer in Charge. Mono Ammonium Phosphate (minimum 40%) based ABC dry chemical agent 8; has a moisture-proof, anti-coking properties. Working pressure:12 DAR minimum 8; Test pressure : 25 BAR minimum. Proper fire rating (as per NFPA 10/BS/EN) according to the capacity of the extinguisher. Manufacturer's certificate shall have to be submitted if needed. Also sample of the dry chemical powder will be tested by the proper authority in Bangladesh if needed. Country of origin: CHINA / MALAYSIA or equivalent product.								
2	Fire Extinguisher CO2-5kg					Nos	10.00		0.00
	Supply & fixing of the following capacities Carbon-di-Oxide stored pressure type with manometer system fire extinguisher suitable for repeated use complete with wall bracket, CO2 cartridge, easy refilling system etc. as per sample accepted & approved by the Engineer in Charge. Working pressure : 12 BAR minimum & Test pressure : 25 BAR minimum. Proper fire rating (as per NFPA 10 / BS / EN) according to the capacity of the extinguisher. Manufacturer's certificate shall have to be submitted if needed. Also sample of the Carbon-di-Oxide will be tested by the proper authority in Bangladesh if needed. Country of origin: CHINA / MALAYSIA or equivalent product.								
3	Fire Extinguisher CO2-25kg (Kitchen Room)					Nos	1.00		0.00
	Supply & fixing of the following capacities Carbon-di-Oxide stored pressure type with manometer system fire extinguisher suitable for repeated use complete with wall bracket, CO2 cartridge, easy refilling system etc. as per sample accepted & approved by the Engineer in Charge. Working pressure : 12 BAR minimum & Test pressure : 25 BAR minimum. Proper fire rating (as per NFPA 10 / BS / EN) according to the capacity of the extinguisher. Manufacturer's certificate shall have to be submitted if needed. Also sample of the Carbon-di-Oxide will be tested by the proper authority in Bangladesh if needed. Country of origin: CHINA / MALAYSIA or equivalent product.								
4	Installation Charge					Lot	1.00		0.00
<b>Total Amount in BDT(Vat and Tax As Per Govt. Rules) =</b>									<b>0.00</b>

  
31.03.26

  
31/03/26