

দরপত্র বিজ্ঞপ্তি

তারিখ: ১৮/০৮/২০২৬

বিষয়: ৪০০ কেভিএ সাব-স্টেশন স্থাপনের দরপত্র বিজ্ঞপ্তি।

বুরো বাংলাদেশ এর বুরো প্রশিক্ষণ কেন্দ্র, বরিশাল এর জন্য লাইসেন্স বোর্ডসহ ৪০০ কেভিএ সাব-স্টেশনের জন্য প্রয়োজনীয় সকল উপকরণ সরবরাহ ও স্থাপনের কাজে দেশের খ্যাতনামা কোম্পানীর নিকট থেকে সংযুক্ত ফরমেট এবং নিম্নের শর্তপূরণ সাপেক্ষে দরপত্র আহ্বান করা যাচ্ছে। দরপত্র বিজ্ঞপ্তিটি প্রতিষ্ঠানের নিজস্ব ওয়েবসাইট www.burobd.org এর মাধ্যমে প্রকাশ করা হয়েছে। মুখবন্ধ খামে আগ্রহী দরদাতাগণ দরপত্র আগামী ১৩/০৯/২০২৬ তারিখ ১২:০০ ঘটিকার মধ্যে বুরো বাংলাদেশ, প্রধান কার্যালয়, বাড়ি নং-১২/এ, রোড নং-১০৪, ব্লক নং-সি.ই.এন (এফ), গুলশান-২ এই ঠিকানায় নীচ তলায় রক্ষিত দরপত্র বাক্সে সরাসরি জমা দিতে পারবেন। একই দিন দুপুর ১২:৩০ মিনিট এর সময় দরপত্রদাতাগণের উপস্থিতিতে (যদি কেউ উপস্থিত থাকেন) দরপত্র সমূহ খোলা হবে।

শর্তাবলী:

- ১ সাব-স্টেশন তৈরী ও স্থাপনে বৈধ লাইসেন্সধারী হতে হবে এবং সাব-স্টেশন সাপ্লাই ইন্টলেশনের কাজ অথবা ট্রান্সফরমার ম্যানুফ্যাকচারিং-এ ন্যূনতম ৫ বছরের অভিজ্ঞতা থাকতে হবে।
- ২ দরপত্রে প্রতিটি আইটেমের পাশে ব্র্যান্ড ও প্রস্তুতকারী দেশের নামসহ দর প্রদান এবং সকল মালামালের ওয়ারেন্টি/গ্যারান্টির সময়সীমা উল্লেখ করতে হবে।
- ৩ টিন সার্টিফিকেট, ভ্যাট নিবন্ধনপত্র ও হালনাগাদ আয়কর সনদপত্রসহ/ Return Acknowledgement Receript এবং কোম্পানীর অন্যান্য কাগজপত্র যেমন, বৈধ ট্রেড লাইসেন্স, ইলেকট্রিক লাইসেন্সিং বোর্ড কর্তৃক ABC সুপারভাইজরি লাইসেন্স পূর্ববর্তী এ ধরনের কাজের গ্রাহকের তালিকা ও Bank Solvency Certificate দরপত্রে সংযুক্ত করতে হবে। ত্রুটিযুক্ত ও অসম্পূর্ণ দরপত্র বাতিল বলে গণ্য হবে।
- ৪ সরবরাহকারী ম্যানুফ্যাকচারার না হলে, সরবরাহকারীকে অবশ্যই ম্যানুফ্যাকচারার এর অনুমোদনের চিঠি সংযুক্ত করতে হবে।
- ৫ ট্রান্সফরমার ম্যানুফ্যাকচারারকে অবশ্যই BUET/RUET//CUET/DUET/MIST কর্তৃক সমতুল্য ক্ষমতা বা তদুর্ধ্ব টেস্ট সার্টিফিকেট থাকতে হবে। যাহার পরীক্ষাকালীন সময়সীমা ৫ বছরের মধ্যে হতে হবে।
- ৬ ম্যানুফ্যাকচারার প্রতিষ্ঠানকে টাইপ টেস্ট (IEC মান অনুযায়ী) সমতুল্য ক্ষমতা বা তদুর্ধ্ব টেস্ট সার্টিফিকেট থাকতে হবে। টাইপ টেস্ট সার্টিফিকেট ৫ বছরের মধ্যে থাকা বাধ্যতামূলক।
- ৭ বৈধ ISO - 9001 সনদ প্রাপ্ত প্রতিষ্ঠান হতে হবে।
- ৮ কর্তৃপক্ষ সর্বনিম্ন দরপত্রদাতাকে কার্যাদেশ প্রদান করতে বাধ্য নয়।
- ৯ কর্তৃপক্ষ যে কোন সময় দরপত্র বাতিল করার অধিকার সংরক্ষণ করেন।
- ১০ ভ্যাট এবং ট্যাক্স সরকারী বিধি মোতাবেক প্রযোজ্য হবে।




Page 1 of 2
Head Office

House: 12/A, Road:104, Block: CEN (F), Gulshan-2, Dhaka-1212, Bangladesh
Tel: +88-02-55059860-62, Hotline: 09610443322, Email: buro@burobd.org, Web: www.burobd.org

- ১১ কার্যাদেশ প্রাপ্তির ৯০ দিনের মধ্যে সকল কাজ সম্পন্ন করে হস্তান্তর করতে হবে।
- ১২ নির্বাচিত প্রতিষ্ঠানকে কার্যাদেশ প্রদানের সময় প্রতিষ্ঠানের নামে কাজের নিরাপত্তা জামানত হিসেবে কার্যাদেশের মোট মূল্যের ৫% অর্থ পে-অর্ডারের মাধ্যমে জমা করতে হবে। পে-অর্ডারের অর্থ প্রজেক্ট হ্যান্ডওভারের ১ বৎসর পর ফেরত প্রদান করা হবে এবং জমাকৃত পে-অর্ডার এর উপর কোন প্রকার ইন্টারেস্ট প্রদান করা হবে না।
- ১৩ সাব-স্টেশন বুরো প্রশিক্ষণ কেন্দ্র, বরিশাল, সি এন্ড বি রোড, নতুল্লাবাদ বরিশাল, বরিশাল সদর বরিশাল (মোবাইল নং: ০১৫৭১-৭২২০০৩, ০১৭৩৩২২০১০০) এই ঠিকানায় স্থাপন করতে হবে।
- ১৪ এই দরপত্র প্রতিষ্ঠানের নিজস্ব ওয়েবসাইট www.burobd.org এই ঠিকানায় পাওয়া যাবে।
- ১৫ প্রয়োজনীয় তথ্য ও অনুসন্ধানের জন্য যোগাযোগ: মোহাম্মদ আসাদুজ্জামান খান- কর্মকর্তা, সরবরাহ ও সেবা, মোবাইল: ০১৭৩৩২২০৮৩৭।

ধন্যবাদান্তে,



সহকারী সমন্বয়কারী-সরবরাহ ও সেবা

বুরো বাংলাদেশ, প্রধান কার্যালয়।

BURO Training Centre, Barishal, BURO Bangladesh

PRICE SCHEDULE OF 400kVA, 11/0.415 kV SUB-STATION

1.0	PART A: SUPPLY OF SUBSTATION EQUIPMENT				
S/L	Descriptions	Qty.	Unit	Unit Price	Total Price
1.1	11 KV LIGHTNING ARRESTOR	1	Set		
1.2	11 KV DROP OUT FUSE	1	Set		
1.3	HEAT SHRINK CABLE KIT	6	Sets		
1.4	CROSS ARM	1	Set		
1.5	11 kV HT SWITCHGEAR (LBS)	1	Set		
1.6	400 kVA, 11/0.415 kV (OIL IMMersed) TRANSFORMER	1	Set		
1.7	LT PANEL	1	Set		
1.8	EMDB-1	1	Set		
1.9	EMDB-2	1	Set		
1.10	240 kVAR AUTO/MANUAL PFI PLANT	1	Set		
1.11	EARTHING BAR (30mmx10mmx300mm)	4	Set		
Sub-Total Price (Part A)					
2.0	PART B: INSTALLATION TESTING & COMMISSIONING OF S/S EQUIPMENT				
S/L	Descriptions	Qty.	Unit	Unit Price	Total Price
2.1	INSTALLATION TESTING & COMMISSIONING OF S/S EQUIPMENT WITH CABLE ACCESSORIES INCLUDING THE HT & LT, PFLATS, EMDB-1, EMDB-2 CABLE LAYING, EARTHING CABLE LAYING, ALL INCOMING & OUTGOING CABLE LAYING & CONNECTION. (WITHOUT CABLE, CIVIL WORK, FENCING, CABLE TRAY)	1	Lot		
2.2	DELIVERY, LOADING & UNLOADING OF S/S EQUIPMENT	1	Job		
Sub-Total Price (Part B)					
3.0	PART C: ELB WORKS				
S/L	Descriptions	Qty.	Unit	Unit Price	Total Price
3.1	GOVT. COST FOR ELECTRICAL LICENSING BOARD (ELB)	1	Job		
3.2	MISCELLANEOUS COST FOR ELECTRICAL LICENSING BOARD (ELB) PERMISSION.	1	Job		
Total Price (Part C)					
4.0	PART D: LOAD SANCTION				
S/L	Descriptions	Qty.	Unit	Unit Price	Total Price
4.1	LOAD SANCTION FOR (MAIN METER) GOVT. FEE (AT ACTUAL)	320	kW		
4.2	MISCELLANEOUS COST FOR LOAD SANCTION	1	Job		
4.3	HT METER WZPDCL (WITH ENCLOSURE) TESTING & INSTALLATION.	1	Job		
4.4	MATERIAL BILL-AT ACTUAL WITH (CONNECTION & SHUT-DOWN FEE)	1	Job		
Sub-Total Price (Part D)					
PRICE SUMMARY					
S/L	Descriptions	Qty.	Unit	Unit Price	Total Price
1.0	PART A: SUPPLY OF SUBSTATION EQUIPMENT	1	Lot		
2.0	PART B: INSTALLATION TESTING & COMMISSIONING OF S/S EQUIPMENT	1	Lot		
3.0	PART C: ELB WORKS	1	Lot		
4.0	PART D: LOAD SANCTION	1	Lot		
Total Price (VAT & Tax As Per Govt. Rules)					
In Words:					

M
02.08.26

[Signature]
02/08/26

[Signature]

TECHNICAL SPECIFICATION OF 400kVA, 11/0.415 kV SUB-STATION
BURO Training Centre, Barishal, BURO Bangladesh

S/L No.	Qty.	Description
01	1 SET	11kV DROPOUT FUSE (1SET = 3 NOS.) Rated Voltage (Nominal) : 11 kV Rated Max. Voltage : 15 kV Rated Frequency : 50 Hz Interrupting Current RMS : 10 kA BIL : 75 kV Withstand Test Voltage Dry, 1Min. : 30 kV Wet, 10 Sec : 30 kV Fuse Link Brand: WZPDCL Approved
02	1 SET	11kV LIGHTNING ARRESTOR (1SET = 3 NOS.) Rated system Voltage : 9 kV Rated maximum System Voltage : 12 kV Frequency : 50 Hz Min.Spark Over(rms) : 14 kV Max.Spark Over(rms) : 40 kV Withstand Voltage Wet. 10 Sec. : 24 kV Dry. 1 Min : 28 kV Impulse Current withstand : 55 kV Brand: WZPDCL Approved
03	6 SETS	11kV HEAT SHRINKABLE KIT Supply & Installation of Heat Shrink Cable Termination Kit (Indoor Type 5 sets & Outdoor type 1 set) complete with all necessary accessories.
04	1 SET	11 kV HT SWITCHGEAR (LBS) Supply of 'HT SWITCHGEAR' sheet steel clad (14 & 16 SWG) with powder coating in selected finish & and color. The standard construction shall include removable hinged door key locks, gland plates, cover plates & and replaceable neoprene foam gaskets including LBS with internal cabling and all related accessories as per detailed drawings and specifications. System operation will be 11 kV, 50 Hz, indoor type HT Panel complete with hard drawn electrolytic copper busbars of 800A, TP & 50%E as per BNBC, RSC regulations and equipped with: Incoming: 1 No 630 A, 11 kV, breaking current 20kA (3 sec.), TP Load Breaking Switch with Fuse, Brand: F&G, Germany. 2 Nos Cast resin insulated, double pole, Potential Transformer, ratio: 11/0.110 kV, Class 0.5, 50 VA (for open-delta connection). 3 Nos Cast Resin Insulated 11 kV dry type double core C.T Ratio: 30/5/5A 1st core for metering.


02.08.26


02/08/2026



SL No.	Qty.	Description
		Core 1 : 10 VA, Class 0.5M10 Triple pole MCB for PT secondary protection. Digital Multifunction meter. Indicating lamps: ON /OFF Panel space heater with thermostat. 1 X Enclosure with Powder Coated gray paint equipped with :- 1 Lot TP + 50%E 800A Hard Down Electrolytic copper bus-bar as per IEC, Covered with Heat Shrink tube. 1 Lot Control Wiring Cable, Cable Lugs, S.S Nut-Bolts with other accessories. suitable for 11000V, 3 Phase, 3 Wire operation. Copper Brand : Coppertech LBS Brand & Origin: F&G, Germany.
05	1 SET	400 kVA, 11/0.415 kV (OIL IMMERSED) TRANSFORMER Supply of 400kVA Oil Immersed Distribution Transformer according to IEC 60076 standards with Rating plate, Earthing terminals, Lifting lugs, 3 Primary bushing & 4 secondary bushing, Oil Conservator, Oil filling cap, Oil level gauge, Name plate etc. Rated output : 400 kVA Voltage ratio : 11/0.415 kV Phase : TP Frequency : 50 Hz Type of Cooling : ONAN Installation : Indoor Taps on HV Side: : ±2.5%, 0, -5%, -7.5% Vector group : Dyn11 BIL : 75 kV No Load Loss : 850 W Full Load Loss : 5200 W Impedance : 4 % Ambient temp. : 40 deg.C Winding Materials : Copper Temperature rise: - In Oil : 60 deg.C -In Coil : 65 deg.C Max.Service altitude : 1000 m Accessories: - Silicagel Breather - Oil Level Indicator - Explosive vent Core: JFE, Japan/ POSCO, Korea/ Equivalent. Copper: RR/ Gazi, Bangladesh/ Coppertech / Equivalent Insulation: ABB, Italy (Roman Board)/ Equivalent. Transformer Oil: Savita, India. Super Enameled Copper: Gazi Wire/BRB , Bangladesh .


02.08.26


2/8/26



S/L No.	Qty.	Description
06	1 SET	LT PANEL Supply of "LT PANEL" fabricated sheet steel (14 & 16 SWG) with powder coating in selected finish & color. The standard construction shall include removable hinged door key locks, gland plates, cover plates, and replaceable neoprene foam gaskets including MCCB, MCB with internal cabling, and all related accessories as per detailed drawings and specifications. System operation will be 415 V, 50 Hz, indoor type LT PANEL complete with hard drawn electrolytic copper busbars of adequate rating, TPN & 50%E as per IEC, BNBC, RSC regulations and equipped with: Incoming: 1 No. 630A, 50kA TP MCCB with built-in adjustable thermally delayed overload and adjustable short-circuit releases Electronic Trip Unit, LS/I function. 1 No. Digital Multifunction Meter (A, V, Hz, KW). Brand: Selec, Schneider/equivalent. 3 Nos. Current Transformer (CT) Having ratio 600/5 with suitable accuracy. 3 Nos. Phase Indication Lamp [R, Y, B]. Brand: Schneider, China 1 Set MCB for protection of Indication lamps, Cooling fan etc. Outgoing: 1 Nos. 400A, 36kA TP MCCB with built-in adjustable thermally delayed overload and adjustable short-circuit releases Electronic Trip Unit.(For PFI) 1 No. 250A, 36kA TP MCCB with built-in adjustable thermally delayed overload and adjustable short-circuit releases Thermomagnetic Trip Unit.(For Fire DB) 1 No. 200A, 36kA TP MCCB with built-in adjustable thermally delayed overload and adjustable short-circuit releases Thermomagnetic Trip Unit.(For ATS-1) 4 Nos. 100A, 25kA TP MCCB with built-in adjustable thermally delayed overload and adjustable short-circuit releases Electronic Trip Unit.(For VRF ODU) 1 No. 100A, 25kA TP MCCB with built-in adjustable thermally delayed overload and adjustable short-circuit releases Thermomagnetic Trip Unit.(For ATS-2) 1 No. 80A, 25kA TP MCCB with built-in adjustable thermally delayed overload and adjustable short-circuit releases Thermomagnetic Trip Unit.(For VRF ODU) 4 No. 40A, 25kA TP MCCB with built-in adjustable thermally delayed overload and adjustable short-circuit releases Thermomagnetic Trip Unit.(FDB for Geyser) 1 No. 63A, 25kA TP MCCB with built-in adjustable thermally delayed overload and adjustable short-circuit releases Thermomagnetic Trip Unit.(Spare) 1 X Enclosure Size: (Adequate Size)mm with Powder Coated gray paint equipped 1 Lot 800A TPN+50%E Hard Drawn Electrolytic copper bus-bar as per IEC, Covered with Heat Shrink tube. 2 Set 6" Ventilation Fan/Cooling Fan with dust filter. 1 Lot Control Wiring Cable, cable socket, cable lugs, cable gland, S.S Nut-Bolts with other accessories. suitable for 415V, 3 Phase, 4 wire, 50Hz operation. Copper Brand : Coppertech MCCB Brand & Origin: ABB, Italy MCB Brand & Origin: ABB, Germany


02.08.26


28/8/26



S/L No.	Qty.	Description
07	1 SET	EMDB-1 Supply of "LT PANEL" fabricated sheet steel (14 & 16 SWG) with powder coating in selected finish & color. The standard construction shall include removable hinged door key locks, gland plates, cover plates, and replaceable neoprene foam gaskets including MCCB, MCB with internal cabling, and all related accessories as per detailed drawings and specifications. System operation will be 415 V, 50 Hz, indoor type LT PANEL complete with hard drawn electrolytic copper busbars of adequate rating, TPN & 50%E as per IEC, BNBC, RSC regulations and equipped with: Incoming: 1 No. 200A, 25kA TP MCCB with built-in adjustable thermally delayed overload and adjustable short-circuit releases Electronic Trip Unit, LS/I function. 1 No. Digital Multifunction Meter (A, V, Hz). Brand: Selec, Schneider/equivalent. 3 Nos. Current Transformer (CT) Having ratio 200/5 with suitable accuracy. 3 Nos. Phase Indication Lamp [R, Y, B]. Brand: Schneider, China 1 Set MCB for protection of Indication lamps, Cooling fan etc. Outgoing: 2 Nos. 100A, 25kA TP MCCB with built-in adjustable thermally delayed overload and adjustable short-circuit releases Electronic Trip Unit.(For VRF ODU) 1 Nos. 63A, 25kA TP MCCB with built-in adjustable thermally delayed overload and adjustable short-circuit releases Electronic Trip Unit.(For Lift) 7 Nos. 63A, 25kA TP MCCB with built-in adjustable thermally delayed overload and adjustable short-circuit releases Electronic Trip Unit.(For FDB) 1 No. 40A, 25kA TP MCCB with built-in adjustable thermally delayed overload and adjustable short-circuit releases Thermomagnetic Trip Unit.(Spare) 1 X Enclosure Size: (Adequate Size)mm with Powder Coated gray paint equipped 1 Lot 250A TPN+50%E Hard Drawn Electrolytic copper bus-bar as per IEC, Covered 2 Set 4" Ventilation Fan/Cooling Fan with dust filter. 1 Lot Control Wiring Cable, cable socket, cable lugs, cable gland, S.S Nut-Bolts with Copper Brand : Coppertech MCCB Brand & Origin: ABB, Italy MCB Brand & Origin: ABB, Germany
08	1 SET	EMDB-2 Supply of "LT PANEL" fabricated sheet steel (14 & 16 SWG) with powder coating in selected finish & color. The standard construction shall include removable hinged door key locks, gland plates, cover plates, and replaceable neoprene foam gaskets including MCCB, MCB with internal cabling, and all related accessories as per detailed drawings and specifications. System operation will be 415 V, 50 Hz, indoor type LT PANEL complete with hard drawn electrolytic copper busbars of adequate rating, TPN & 50%E as per IEC, BNBC, RSC regulations and equipped with: Incoming:

M
02.08.26

2/8/26

2/8/26

S/L No.	Qty.	Description
	1 No.	100A, 25kA TP MCCB with built-in adjustable thermally delayed overload and adjustable short-circuit releases Electronic Trip Unit, LS/I function.
	1 No.	Digital Multifunction Meter (A, V, Hz). Brand: Selec, Schneider/equivalent.
	3 Nos.	Current Transformer (CT) Having ratio 100/5 with suitable accuracy.
	3 Nos.	Phase Indication Lamp [R, Y, B]. Brand: Schneider, China
	1 Set	MCB for protection of Indication lamps, Cooling fan etc.
		Outgoing:
	1 Nos.	63A, 25kA TP MCCB with built-in adjustable thermally delayed overload and adjustable short-circuit releases Electronic Trip Unit.(For Lift)
	4 Nos.	63A, 25kA TP MCCB with built-in adjustable thermally delayed overload and adjustable short-circuit releases Electronic Trip Unit.(For FDB)
	1 Nos.	40A, 25kA TP MCCB with built-in adjustable thermally delayed overload and adjustable short-circuit releases Electronic Trip Unit.(Spare)
		1 X Enclosure Size: (Adequate Size)mm with Powder Coated gray paint equipped
		1 Lot 150A TPN+50%E Hard Drawn Electrolytic copper bus-bar as per IEC, Covered with Heat Shrink tube.
		2 Set 4" Ventilation Fan/Cooling Fan with dust filter.
		1 Lot Control Wiring Cable, cable socket, cable lugs, cable gland, S.S Nut-Bolts with other accessories. suitable for 415V, 3 Phase, 4 wire, 50Hz operation.
		Copper Brand : Coppertech
		MCCB Brand & Origin: ABB, Italy
		MCB Brand & Origin: ABB, Germany
09	1 SET	240kVAR AUTO/MANUAL PFI PLANT
		Supply of 'PFI Plant' fabricated (14 & 16 SWG) Sheet steel enclosed, dust & vermin proof, free-standing, floor mounting, 415V, 50 Hz, Indoor type 240 kVAR Auto/Manual Power Factor Improvement Plant in 12 switching steps having TP Copper Busbar, comprising:
	1 No.	5 kVAR, 415V, 50 Hz, 3 Phase Power Capacitor Bank with built-in discharge resistor
	1 No.	5 kVAR, 415V, 50 Hz, 3 Phase Power Capacitor Bank with built-in discharge resistor.
	1 No.	10 kVAR, 415V, 50 Hz, 3 Phase Power Capacitor Bank with built-in discharge resistor.
	2 Nos.	10 kVAR, 415V, 50 Hz, 3 Phase Power Capacitor Bank with built-in discharge resistor.
	2 Nos.	12.5 kVAR, 415V, 50 Hz, 3 Phase Power Capacitor Bank with built-in discharge
	3 Nos.	25 kVAR, 415V, 50 Hz, 3 Phase Power Capacitor Bank with built-in discharge resistor.
	2 Nos.	50 kVAR, 415V, 50 Hz, 3 Phase Power Capacitor Bank with built-in discharge resistor.
		Capacitor Brand: Epcos, India.
	2 Nos.	100A, 18KA, TP MCCB.
	10 Nos.	TP MCB with adequate rating.
	11 Nos.	Magnetic Contactor of adequate rating.
	1 No.	12 Stage Micro-processor Controlled Automatic Power Factor Correction Relay with in-built Digital Power Factor Meter. Brand- MIKRO, MALAYSIA.
	3 Nos.	Auxiliary Contactor Relay, 4 NO+ 4 NC .
	1 No.	AUTO/MANUAL Selector Switch

[Signature]
02.08.26

[Signature]
2/8/26

[Signature]

S/L No.	Qty.	Description
	22 Nos.	ON/OFF Switch
	11 Nos.	Indicating Lamps
	1 Nos.	Set of Control fuses/MCB
		1 X Enclosure with Powder Coated gray paint equipped with 1 Lot TP & 50%E Hard Drawn Electrolytic copper bus-bar as per IEC, Covered with 1 Lot Control Wiring Cable, cable socket, cable lugs, cable gland, MCCB Separator, S.S Nut-Bolts with other accessories. suitable for 415V, 3 Phase, 4 wire, 50Hz Copper Brand : Coppertech MCCB Brand & Origin: ABB, Italy. MCB Brand & Origin: ABB, Germany. Magnetic Contactor Brand: ABB, Bulgaria.
10	4 SET	<u>EARTHING BAR</u>
		a) Copper Earthing Bar (30mmx10mmx300mm)- 4 no. b) Insulator for Earthing Bar: 8 Nos.


02.08.26


02/8/26

