



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE
PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

| | |
|----------------------------|---|
| LISTING No.: | 8140-2084:0006 |
| PARENT LISTING No.: | 8140-2041:0008 |
| CATEGORY: | 8140 - EXTERIOR WALL SIDING AND SHEATHING FOR WILDLAND URBAN INTERFACE (W.U.I) |
| LISTEE: | WESTERN WOODS INC. P.O. Box 4402, Chico, CA, 95973 Contact: Yale, Linda (530) 343-5821 (530) 343-3851 Email: linday@westernwoodsinc.com |
| DESIGN: | <p>Solid-sawn "Wood" siding with no through holes or loose knots, installed over structural plywood or oriented strand board (OSB) with a 7/16" minimum thickness and complying with Voluntary Product Standard PS1 or Voluntary Product Standard PS2, with the following interlocking designs when installed in accordance with industrial technical guide. Refer to the manufacturer's installation instructions and product data sheets.</p> <p>Board on Board: When applied in a vertical orientation with minimum nominal 8" wide and nominal 1" thick boards, and 3/4" thick x 3-1/2" wide plywood inserts between boards, with boards and plywood inserts installed with a gap not more than 1/8" between them and fastened to the wood frame with not less than 3" long fasteners at a schedule not more than 24" on center, and boards made of a wood species "Redwood", "Western Red Cedar", "Incense Cedar", "Port Orford Cedar", "Alaska Yellow Cedar", or any other wood species having a Flame Spread Rating not greater than 75 (Class B) when tested in accordance with ASTM E84.</p> <p>All nominal board sizes shall comply with the applicable provisions of American Softwood Lumber Standard DOC PS 20. Edge and end glued siding is permitted to be used interchangeably with solid sawn members. The recommended installation practice for solid wood siding in wall construction regarding butt and overlapping joints is: butt joints between pieces should be staggered a minimum of 12" and all butt joints should be flush with no gap. Nail joints into the studs or blocking members. One nail at each crossing with the wood frame support member shall be used for nominal 6" siding and 2 nails for nominal 8" or wider siding. Refer to the manufacturer's installation instructions and product data sheets.</p> |
| RATING: | Compliance with Chapter 7A of the California Building Code. |
| INSTALLATION: | In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. |
| MARKING: | Listee name. Model number, rating and SFM label. |



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE
PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

APPROVAL:

Listed as solid wood sidings for use in the Wildland Urban Interface areas.

NOTES:

11-23-11 bh



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 06/12/2025

Listing Expires: 06/30/2026

Authorized By: **Michael Huang** , Program Coordinator
Fire Engineering & Investigations Division