



SAMOA PORTS AUTHORITY

P O Box 2279, Matautu Tai, Apia, Samoa

Phone (685) 64400

Fax: (685) 25870

Email: spa@spasamoa.ws Website: www.spasamoa.ws

Date: 16 July 2025

Notice to Bidders - N° CT 1

Project: Enhancing the Safety, Security and Sustainability of the Apia Port (ESSSAP)

Contract: Control Tower

Contract N°: ESSSAP-W-03

Response to Questions

Design of stairs

The layout of the stairs has been shown on the drawings. The detailing of the design including the connection to the main structure is the responsibility of the Contractor.

Lightning Arrestor and Earthing Point

A lightning arrestor is required. A Eritech System 3000 or equivalent as per Clause G4.P.10 in the National Building Code of Samoa shall be provided, connecting the steel structure to one of the steel pile casings beneath the wharf structure. The cable shall be installed in a hole cored through the existing slab at a location agreed on site.

Is there any BOQ list for this tender

There is no BOQ as the contract is a Lump Sum. There is a breakdown of the lump sum figure, but with no quantities

The Tenderer is to acknowledge in the tender that the Price is in accordance with this Notice.

Please acknowledge receipt of this Notice to Bidders by email to:

Leasi V. Galuvao leasi.pmu@spasamoa.ws

John Youdale john.youdale@beca.com

Stating name, job title and bidding company.

Signed

Name Moe Lene

Acting-CEO