

FLAMESAFE MAXISOFT LTD
ROYAL ROAD
TOMBEAU BAY
MAURITIUS

REPORT ISSUED BY THE RESEARCH ASSOCIATION OF THE TEXTILE
INDUSTRY, AITEX
N° 2018CN0189

1/28

The test was carried out at :High Current Laboratory located at Polígono Industrial Fuente del Jarro. C/ Ciudad de Gibraltar, 5; 46988 – Paterna (Valencia); which property is shared at 50% between research institutes AITEX and ITE

Applicant

FLAMESAFE MAXISOFT LTD

Date of reception

14/05/2018

Data test

Starting : 14/05/2018

Ending: 17/05/2018

Identification of samples

- "Fabric WKS-350"

According to information supplied by the customer:

Fabric reference: WKS-350

Composition: Modacrylic Cotton

Fabric structure: Single Fleece

Color: Navy

Weight: 350 g or 10.3 oz/yd²

Test Carried out

- ELECTRIC ARC EXPOSURE TEST: DETERMINATION OF THE ARC RATING (ATPV or EBT50) OF FLAME RESISTANT MATERIALS FOR CLOTHING
- PRE-TREATMENT FOR DOMESTIC WASHING AND DRYING PROCEDURES FOR TEXTILE TESTING

RESULTS

PRE-TREATMENT FOR DOMESTIC WASHING AND DRYING PROCEDURES FOR TEXTILE TESTING

Standard

AATCC TM135:2015

Standard deviation

Reference

Sample 1 Fabric WKS-350

Washing machine

13373I12

Washing cycles

3

Washing procedure

IV

Dryer machine

Whirlpool 13098I12

Drying procedure

Aiii

Washing powder

AATCC 1993 WOB

Start and finish data test

14/05/2018 - 15/05/2018

///

RESULTS

ELECTRIC ARC EXPOSURE TEST: DETERMINATION OF THE ARC RATING (ATPV OR E_{BT50}) OF FLAME RESISTANT MATERIALS FOR CLOTHING

Standard

ASTM F1959/F1959M-14

Test results

The test program includes minimum of twenty individual panel arc trials.

The following test data was recorded for each trial:

Arc exposure electrical conditions: arc trial number, RMS arc current, peak arc current, arc voltage, arc duration, energy dissipated in arc, plots of arc current and arc voltage.

Temperature rise response from two monitor sensors for each panel in each trial, plot of average responses from two monitor sensors.

Pictures after arc exposure.

Video

Essential test data and test results are presented in the following pages as follows:

Arc rating: ATPV or E_{BT50} or both and plots of the burn injury probability (ATPV) or break open probability (E_{BT50}) or both versus Ei.

Heat attenuation factor (HAF) and plot of HAF on Ei.

Test specimen description and order of layer.

Distance from an arc center line to the panel surface.

Subjective evaluation.

Pictures after arc exposure.

Ignition probability value (if determined during testing).

>>>

RESULTS

Test conditions	
Date test.	17/05/2018
Arc current	(8 ± 1) kA
Stainless steel electrodes, gap of the electrodes	(300 ± 5) mm
Distance between the electrodes and sample	(300 ± 5) mm
Fuse wire	0.5 mm
Number of samples tested	21
Starting and ending pre-treatment date	14/05/2018 - 15/05/2018
Starting and ending conditioning date	16/05/2018 - 17/05/2018
Conditioning	24 h; 21 ± 1°C, 65 ± 2 % Hr.

>>>

RESULTS

Reference Fabric WKS-350

Sample description according to the information supplied by the customer

Navy knitted fabric style WKS-350, Modacrylic Cotton, 350 g/m².

Pre-treatment

3 washing cycles at 49°C, according to standard AATCC TM135-2015, method IV and type Aiii drying.

Washed sample weight before test

388,26 g/m²


Deviation from the standard

>>>

RESULTS

Determination of ATPV, 50% of Probability of 2nd degree burn

ATPV	19,1 cal/cm ²
------	--------------------------



Probability %	5	10	20	30	40	50	60	70	80	95
E _i cal/cm ²	15,3	16,3	17,4	18,0	18,6	19,1	19,7	20,2	20,9	22,9


ATPV points above	5
ATPV points 20%	14
ATPV points below	6
ATPV points mix zone	10

>>>

RESULTS

Determination of HAF, confidence Intervals 95%

HAF	87,9 %
-----	--------



% HAF value :	87,9
Upper Confidence Level %:	88,9
Lower Confidence Level %:	86,9
Points above:	8
Points below:	5
Points between:	8
Total Points:	21

>>>

RESULTS

Summary of measured energy and subjective evaluation:

Test	Time (ms)	Cycles 50Hz	Ei cal/cm ²	SCD cal/cm ²	HAF %	Burn	Break Open
1-A	163,6	8,18	9,4	-0,39	83,3	N	N
1-B	163,6	8,18	8,4	-0,47	82,3	N	N
1-C	163,6	8,18	9,4	-0,56	86,7	N	N
2-A	403,6	20,18	23,3	0,3	88,7	Y	N
2-B	403,6	20,18	20,8	0,57	86,2	Y	N
2-C	403,6	20,18	21,0	-0,05	90,1	N	N
3-A	503,8	25,19	29,8	0,78	91,7	Y	Y
3-B	503,8	25,19	26,0	0,6	89,2	Y	Y
3-C	503,8	25,19	22,4	0,03	89,6	Y	N
4-A	363,2	18,16	23,2	0,56	88,0	Y	N
4-B	363,2	18,16	18,8	0,17	87,1	Y	N
4-C	363,2	18,16	16,7	-0,2	89,0	N	N
5-A	343,8	17,19	18,6	-0,19	89,2	N	N
5-B	343,8	17,19	19,9	0,3	87,1	Y	N
5-C	343,8	17,19	17,6	-0,04	88,6	N	N
6-A	343,2	17,16	20,5	0,25	87,8	Y	N
6-B	343,2	17,16	17,4	0,18	85,8	Y	N
6-C	343,2	17,16	17,4	-0,22	89,1	N	N
7-A	353,2	17,66	20,1	0,06	88,6	Y	N
7-B	353,2	17,66	17,3	-0,13	87,6	N	N
7-C	353,2	17,66	19,9	0	89,6	N	N

>>>

RESULTS

Summary of measured energy and subjective evaluation:

Test	After flame (s)	Ablation	Melting	Dripping	Charring	Embrittlement
1-A	0	N	N	N	Y	Y
1-B	0	N	N	N	Y	Y
1-C	0	N	N	N	Y	Y
2-A	0	N	N	N	Y	Y
2-B	0	N	N	N	Y	Y
2-C	0	N	N	N	Y	Y
3-A	0	Y	N	N	Y	Y
3-B	0	Y	N	N	Y	Y
3-C	0	N	N	N	Y	Y
4-A	0	N	N	N	Y	Y
4-B	0	N	N	N	Y	Y
4-C	0	N	N	N	Y	Y
5-A	0	N	N	N	Y	Y
5-B	0	N	N	N	Y	Y
5-C	0	N	N	N	Y	Y
6-A	0	N	N	N	Y	Y
6-B	0	N	N	N	Y	Y
6-C	0	N	N	N	Y	Y
7-A	0	N	N	N	Y	Y
7-B	0	N	N	N	Y	Y
7-C	0	N	N	N	Y	Y

Y Yes N No


>>>

RESULTS

Electrical current and response sensor response:


Calibration shot

INITIAL CALIBRATION



Ei Panel A	7,0 cal/cm ²	Ei Panel B	6,8 cal/cm ²	Ei Panel C	7,1 cal/cm ²
------------	-------------------------	------------	-------------------------	------------	-------------------------

FINAL CALIBRATION



Ei Panel A	8,7 cal/cm ²	Ei Panel B	9,1 cal/cm ²	Ei Panel C	7,5 cal/cm ²
------------	-------------------------	------------	-------------------------	------------	-------------------------


>>>

RESULTS

Electrical current and response sensor response:

Shot 1


Current Plot




Voltage Plot



Average panel sensors response Vs. Stoll plot



Average monitor sensors plot




>>>

RESULTS


Electrical current and response sensor response:

Shot 1

Average panel sensors response Vs. Stoll plot



Monitor sensors plot



Current Total RMS (kA)	8,0	Current Peak (kA)	17,8	Arc Voltage (V)	1476,0
Duration (cycles n°)	8,2	Duration (ms)	163,6	Arc Energy (kJ)	533,6
Arc Voltage (kJ)	457,9				

sensor response	PANEL A	PANEL B	PANEL C
Ei	9,38 cal/cm ²	8,37 cal/cm ²	9,39 cal/cm ²
SCD	-0,39 cal/cm ²	-0,47 cal/cm ²	-0,56 cal/cm ²
HAF	83,27 %	82,27 %	86,73 %


>>>

RESULTS


Electrical current and response sensor response:

Shot 2


Current Plot




Voltage Plot



Average panel sensors response Vs. Stoll plot



Average monitor sensors plot




>>>

RESULTS


Electrical current and response sensor response:

Shot 2

Average panel sensors response Vs. Stoll plot



Average monitor sensors plot



Current Total RMS (kA)	8,0	Current Peak (kA)	18,3	Arc Voltage (V)	1428,0
Duration (cycles n°)	20,2	Duration (ms)	403,6	Arc Energy (kJ)	1313,4
Arc Voltage (kJ)	448,8				

sensor response	PANEL A	PANEL B	PANEL C
Ei	23,26 cal/cm ²	20,83 cal/cm ²	21,00 cal/cm ²
SCD	0,30 cal/cm ²	0,57 cal/cm ²	-0,05 cal/cm ²
HAF	88,69 %	86,24 %	90,08 %


>>>

RESULTS


Electrical current and response sensor response:

Shot 3


Current Plot




Voltage Plot



Panel sensors vs. Stoll plot



Average monitor sensors plot




>>>

RESULTS


Electrical current and response sensor response:

Shot 3

Average panel sensors response Vs. Stoll plot



Monitor sensors plot



Current Total RMS (kA)	8,0	Current Peak (kA)	18,3	Arc Voltage (V)	1470,0
Duration (cycles n°)	25,2	Duration (ms)	503,7	Arc Energy (kJ)	1591,8
Arc Voltage (kJ)	438,8				

sensor response	PANEL A	PANEL B	PANEL C
Ei	29,82 cal/cm ²	25,98 cal/cm ²	22,42 cal/cm ²
SCD	0,78 cal/cm ²	0,60 cal/cm ²	0,03 cal/cm ²
HAF	91,67 %	89,22 %	89,56 %


>>>

RESULTS

Electrical current and response sensor response:

Shot 4


Current Plot




Voltage Plot



Panel sensors vs. Stoll plot



Average monitor sensors plot




>>>

RESULTS


Electrical current and response sensor response:

Shot 4

Average panel sensors response Vs. Stoll plot



Monitor sensors plot



Current Total RMS (kA)	8,0	Current Peak (kA)	18,2	Arc Voltage (V)	1452,0
Duration (cycles n°)	18,2	Duration (ms)	363,2	Arc Energy (kJ)	1170,3
Arc Voltage (kJ)	444,6				

sensor response	PANEL A	PANEL B	PANEL C
Ei	23,18 cal/cm ²	18,84 cal/cm ²	16,74 cal/cm ²
SCD	0,56 cal/cm ²	0,17 cal/cm ²	-0,20 cal/cm ²
HAF	88,00 %	87,09 %	89,01 %


>>>

RESULTS

Electrical current and response sensor response:

Shot 5


Current Plot




Voltage Plot



Panel sensors vs. Stoll plot



Average monitor sensors plot




>>>

RESULTS


Electrical current and response sensor response:

Shot 5

Average panel sensors response Vs. Stoll plot



Monitor sensors plot



Current Total RMS (kA)	8,1	Current Peak (kA)	18,2	Arc Voltage (V)	1431,0
Duration (cycles n°)	17,2	Duration (ms)	343,8	Arc Energy (kJ)	1110,2
Arc Voltage (kJ)	445,6				

sensor response	PANEL A	PANEL B	PANEL C
Ei	18,64 cal/cm ²	19,91 cal/cm ²	17,65 cal/cm ²
SCD	-0,19 cal/cm ²	0,30 cal/cm ²	-0,04 cal/cm ²
HAF	89,18 %	87,09 %	88,65 %


>>>

RESULTS

Electrical current and response sensor response:

Shot 6


Current Plot




Voltage Plot



Panel sensors vs. Stoll plot



Average monitor sensors plot




>>>

RESULTS


Electrical current and response sensor response:

Shot 6

Average panel sensors response Vs. Stoll plot



Monitor sensors plot



Current Total RMS (kA)	8,0	Current Peak (kA)	18,3	Arc Voltage (V)	1476,0
Duration (cycles n°)	17,2	Duration (ms)	343,3	Arc Energy (kJ)	1125,3
Arc Voltage (kJ)	452,4				

Sensor response	PANEL A	PANEL B	PANEL C
Ei	20,46 cal/cm ²	17,44 cal/cm ²	17,39 cal/cm ²
SCD	0,25 cal/cm ²	0,18 cal/cm ²	-0,22 cal/cm ²
HAF	87,76 %	85,83 %	89,12 %


>>>

RESULTS


Electrical current and response sensor response:

Shot 7


Current Plot




Voltage Plot



Panel sensors vs. Stoll plot



Average monitor sensors plot




>>>

RESULTS


Electrical current and response sensor response:

Shot 7

Average panel sensors response Vs. Stoll plot



Monitor sensors plot



Current Total RMS (kA)	8,0	Current Peak (kA)	17,9	Arc Voltage (V)	1503,0
Duration (cycles n°)	17,7	Duration (ms)	353,3	Arc Energy (kJ)	1212,2
Arc Voltage (kJ)	478,9				

sensor response	PANEL A	PANEL B	PANEL C
Ei	20,14 cal/cm ²	17,34 cal/cm ²	19,89 cal/cm ²
SCD	0,06 cal/cm ²	-0,13 cal/cm ²	0,00 cal/cm ²
HAF	88,55 %	87,61 %	89,62 %

>>>

RESULTS

Tested material pictures:

Original



Shot 1




Shot 2



Shot 3



Shot 4



Shot 5



Shot 6



Shot 7



>>>

RESULTS

Summary of results:

ATPV	19,1 cal/cm ²
HAF	87,9 %

FABRIC TESTED ACCORDING TO THE STANDARD ASTM F1959/F1959M-14

ARC RATING

19,0 cal/cm²

>>>

*According to ASTM F1506-15 y ASTM F1959/F1959M-14, arc rating values below 10 cal/cm² shall be reported to the nearest 0.1 cal/cm², and arc rating values above 10 cal/cm² shall be reported to the nearest 1 cal/cm².

Arc Flash PPE category according to standard NFPA70E Edition 2015 Table 130.7 (C) (16) - Personal Protective Equipment (PPE)

PPE Category	Minimum Arc Rating (cal/cm ²)
1	4
2	8
3	25
4	40

///

Lucia Martinez
Head of PPE and Ballistics department

LIABILITY CLAUSES

- 1.- AITEX is liable only for the results of the methods of analysis used, as expressed in the report and referring exclusively to the materials or samples indicated in the same which are in its possession, the professional and legal liability of the Centre being limited to these. Unless otherwise stated, the samples were freely chosen and sent by the applicant.
- 2.- AITEX shall not be liable in any case of misuse of the test materials nor for undue interpretation or use of this document
- 3.- The original test report is kept in AITEX. An electronic copy of it is delivered to the costumer which keeps the value from the original one as far as the security properties of the document are not violated. A hard copy of this report with the AITEX logotype sealed in all the pages, keeps the original value.
- 4.- The results are considered to be the property of the applicant, and AITEX will not communicate them to third parties without prior permission. After one month, AITEX may use the results for statistical or scientific purposes.
- 5.- None of the indications made in this report may be considered as being a guarantee for the trade marks mentioned herein.
- 6.- In the eventuality of discrepancies between reports, a check to settle the same will be carried out in the head offices of AITEX. Also, the applicants undertake to notify AITEX of any complaint received by them as a result of the report, exempting this Centre from all liability if such is not
- 7.- AITEX may include in its reports, analyses, results, etc., any other evaluation which it considers necessary, even when it has not been specifically requested.
- 8.- The uncertainties of the tests, which are made explicit in the Results Report, have been estimated for a $k = 2$ (probability of coverage of 95%). If not informed, they are available to the client in AITEX.
9. - The original materials and rests of samples, not subject to test, will be retained in AITEX during the twelve months following the issuance of the report, so that any check or claim which, in his case, wanted to make the applicant, should be exercised within the period indicated.
- 10.- This report may only be sent or delivered by hand to the applicant or to a person duly authorised by the same.
- 11.- The results of the tests and the statement of compliance with the specification in this report refer only to the test sample as it has been analyzed / tested and not the sample / item which has taken the test sample.
- 12.- The client must attend at all times, the dates for conducting the

Laboratories:

ASOCIACION DE INVESTIGACION DE LA INDUSTRIA TEXTIL, AITEX
Plaza Emilio Sala, 1 y C/Sant Jordi, 13
E-03801 ALCOY (Alicante) SPAIN
Tel. +34 965542200
Fax. +34 965543494
CIF G03182870

www.aitex.es
info@aitex.es

Trade centers:

México DF (México)
Bogotá (Colombia)
Dhaka (Bangladesh)
Kaunas (Lituania)
Karachi y Faisalabad (Pakistán)
New Delhi (India)
São Paulo (Brasil)
Shanghai (China)