

CLIENT INFORMATION**Client:** *******Requested On:** Jun 23, 2025**Phone:** *******Email:** *****

Kitting, Logistics, and Support provided by: SimpleLab, Inc.

Questions? For fastest assistance:

hello@gosimplelab.com

Do not contact facility technicians directly.

TESTING PERFORMED**Testing Requested:** PFAS Water Test**Matrix:** Drinking Water**Testing / Report ID:** VXTKQ6**Testing Facility:** Pace Analytical**Facility Location:** 2231 W. Altorfer Dr.
Peoria, Illinois 61615**SAMPLE INFORMATION****Collection Date:** Aug 1, 2025**Collected By:** *******Received Date:** Aug 11, 2025**Reported On:** Aug 22, 2025**Sample Location:** Aquaria Hydropack PFAS Test - Austin, TX**Sample Address:** *******TESTING NOTES FROM SIMPLELAB**

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact hello@gosimplelab.com

TEST RESULTS

ANALYTE	UNIT	RESULT	MDL	RL	METHOD	EPA REG
N-ethyl perfluorooctanesulfonamidoacetic acid	µg/L	NOT DETECTED	0.0006	0.0022	EPA 537.1	
N-methyl perfluorooctanesulfonamidoacetic acid	µg/L	NOT DETECTED	0.0005	0.0022	EPA 537.1	
Perfluorobutanesulfonic acid	µg/L	NOT DETECTED	0.0006	0.0022	EPA 537.1	
Perfluorodecanoic acid	µg/L	NOT DETECTED	0.0006	0.0022	EPA 537.1	
Perfluorododecanoic acid	µg/L	NOT DETECTED	0.0007	0.0022	EPA 537.1	
Perfluoroheptanoic acid	µg/L	NOT DETECTED	0.0006	0.0022	EPA 537.1	
Perfluorohexanesulfonic acid	µg/L	NOT DETECTED	0.0005	0.0022	EPA 537.1	
Perfluorohexanoic acid	µg/L	NOT DETECTED	0.0005	0.0022	EPA 537.1	
Perfluorononanoic acid	µg/L	NOT DETECTED	0.0006	0.0022	EPA 537.1	
Perfluorooctanesulfonic acid	µg/L	NOT DETECTED	0.0006	0.0022	EPA 537.1	
Perfluorooctanoic acid	µg/L	NOT DETECTED	0.0005	0.0022	EPA 537.1	
Perfluorotetradecanoic acid	µg/L	NOT DETECTED	0.0007	0.0022	EPA 537.1	
Perfluorotridecanoic acid	µg/L	NOT DETECTED	0.0007	0.0022	EPA 537.1	
Perfluoroundecanoic acid	µg/L	NOT DETECTED	0.0006	0.0022	EPA 537.1	

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Federal Maximum Contaminant Level (MCL).

This is an enforceable primary drinking water standard set by the U.S. EPA. MCLs are the highest concentration of a contaminant permitted in drinking water from public water systems. MCLs are set as close as possible to health protective levels, while also taking into account the cost and availability of treatment technologies.

Use of this report can only be done in full, with no alterations or additions. SimpleLab maintains the right to enforce this and by accepting this report you agree to abide by this policy.

MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team is configured to measure.