

ALL DIMENSIONS IN MILLIMETERS - DO NOT SCALE

KEY:

NOTES:

THE FRONT OF THE UNIT MUST MAINTAIN A CLEARANCE OF AT LEAST 1000MM TO ENSURE THE EXHAUST FANS ARE NOT RESTRICTED WHICH WILL CAUSE OPERATIONAL ISSUES. SIDE CLEARANCES ARE REQUIRED FOR FUTURE MAINTENANCE.

01	TP	CLEARANCE ZONES ADDED	01.06.26	NP
00	TP	FIRST ISSUE	27.05.26	NP
REV	BY	DESCRIPTION	DATE	CHK.



PROJECT

ATHENA ASHP

TITLE

ATHENA 500
GENERAL ARRANGEMENT

DATE	27.05.26	DRAWN	VisCAD	CHECKED	NP
SCALE	1:20@A3	SHEET	1of1	REV.	01

DRG. NO.

ATHENA 500

