



# Certificate of Compliance

**Certificate:** 80221925 **Master Contract:** 305093  
**Project:** 80221925 **Date Issued:** 2024-10-24  
**Issued to:** KB Racking  
1050 King Street West  
Suite 03A104  
Toronto, Ontario M6K 0C7  
Canada

**Attention:** Michael Shea

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



**Issued by:** Joseph Garcia  
Joseph Garcia

## PRODUCTS

Class 5313 05 POWER SUPPLIES - PHOTOVOLTAICS - Photovoltaic Hazard Control

Class 5313 85 POWER SUPPLIES - PHOTOVOLTAICS - Photovoltaic Hazard Control - US

**Racking systems for bonding and grounding of photovoltaic modules. The systems listed are designed to provide hazard controls for PV arrays mounted on roofs. The modules are bonded to the racking system and wire management to reduce hazard due to fire fighter interactions during various fault conditions. All components in array shall be compliant with its given standards and rates shall meet requirements of installation and applicable standards per end use of system design of array.**

Model(s)

AeroGrid, EkonoRack 2.0

The grounding of the system is intended to comply with the latest edition of the National Electrical Code, including NEC 250 & 690 or in accordance with CSA C22.1, Safety Standard for Electrical Installations, Canadian Electrical Code, Part I. Local codes compliance is



**Certificate:** 80221925

**Master Contract:** 305093

**Project:** 80221925

**Date Issued:** 2024-10-24

---

required, in addition to national codes.

**APPLICABLE REQUIREMENTS**

ANSI/CAN/UL 3741 (First Edition) - UL Standard for Safety Photovoltaic Hazard Control



**Certificate:** 80221925

**Project:** 80221925

**Master Contract:** 305093

**Date Issued:** 2024-10-24

---

Notes:



## *Supplement to Certificate of Compliance*

**Certificate:** 80221925

**Master Contract:** 305093

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
80221925	2024-10-24	UL 3741 initial evaluation, analysis Section 12, risk assessment, and testing.