

IAPMO RESEARCH AND TESTING, INC.

4755 E. Philadelphia Street, Ontario, CA 91761-2816 • (909) 472-4100 • Fax (909) 472-4244 • www.iapmort.org



CERTIFICATE OF LISTING

IAPMO Research and Testing, Inc. is a product certification body in which its product certification system includes inspection and testing of samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and/or warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

Issued to:

ResinTech Inc

1801 FEDERAL STREET
CAMDEN, NJ 08105

Product:

Water Treatment Product - Health Effects

Products are in compliance with the following code(s):

Uniform Plumbing Code (UPC®)

Products are certified to the following standard(s):

NSF/ANSI 53-2023

File Number: W-17562

Effective Date: May 2025

Void After Date: May 2030*


Chairman, Product Certification Committee




Chief Technical Service Officer

* This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

This listing period is based upon the last date of the month indicated on the Effective Date and Void After Date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Certification Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Production of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc. Any alteration of this certificate could be grounds for revocation of the listing. This document shall be reproduced in its entirety.

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: ResinTech Inc

File Number: W-17562

Product: Water Treatment Product - Health Effects

Effective Date: May 2025

Void After: May 2030

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Identification:

Product shall bear: The certified company name. The model number or trade designation. The appropriate certification mark. Product markings may be permanently fixed on the system or may be included as part of product literature or packaging.


Characteristics:

The point-of-use and point-of-entry systems addressed by this Standard are designed to be used for the reduction of specific substances that may be present in drinking water (public or private) which are considered health hazards. Certification demonstrates that all materials safety and structural integrity (as applicable) requirements have been met. To be used in accordance with the manufacturer's instructions An elective claim per NSF/ANSI 53 is VOC. When a VOC reduction claim is listed, it means the system has the ability to reduce the concentration of all of the contaminants listed below: Alachlor endrin simazine Atrazine ethylbenzene styrene Benzene ethylene dibromide (EDB) 1,1,2,2-tetrachloroethane Carbofuran haloacetonitriles tetrachloroethylene carbon tetrachloride bromochloroacetonitrile toluene chlorobenzene dibromoacetonitrile 2,4,5-TP(silvex) chloropicrin dichloroacetonitrile tribromoacetic acid 2,4-D trichloroacetonitrile 1,2,4-trichlorobenzene dibromochloropropane (DBCP) haloketones 1,1,1-trichloroethane o-dichlorobenzene 1,1-dichloro-2-propanone 1,1,2-trichloroethane p-dichlorobenzene 1,1,1-trichloro-2-propanone trichloroethylene 1,2-dichloroethane heptachlor trihalomethanes (THM) 1,1-dichloroethylene heptachlor epoxide bromodichloromethane cis-1,2-dichloroethylene hexachlorobutadiene bromoform trans-1,2-dichloroethylene hexachlorocyclopentadiene chlorodibromomethane 1,2-dichloropropane lindane chloroform cis-1,3-dichloropropylene methoxychlor xylenes dinoseb pentachlorophenol

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: ResinTech Inc

File Number: W-17562

Product: Water Treatment Product - Health Effects

Effective Date: May 2025

Void After Date: May 2030

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Product Type Plumbed-in to separate tap without reservoir

Model Number	Replacement Component	Flow Rate (GPM)	Capacity (Gallons)	Reduction Claims
HYS-100-3612 ¹	AF-10-3612	0.62	1,750	Total PFAS
HYS-200-3612 ¹	AF-20-3612	1.02	3,500	Total PFAS
HYS-100-B-3612 ¹	AF-10-3612-BB	1.62	3,350	Total PFAS
HYS-200-B-3612 ¹	AF-20-3612-BB	3.00	7,125	Total PFAS

¹ The test mixture for total PFAS is made up of PFOA (500 ppt), PFOS (1,000 ppt), PFHxS (300 ppt), PFNA (50 ppt), PFHpA (40 ppt), PFBS (260 ppt), and PFDA (10 ppt). This system meets the 20 ppt requirement for Total PFAS.