

## **AAMA CERTIFICATION PROGRAM**

**An FGIA Product Certification Program** 



## **AUTHORIZATION FOR PRODUCT CERTIFICATION**

Elixir Door and Metals Co. 1215 Pope Dr. Douglas, GA 31533

Attn: Randall Yarberry

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

| SPECIFICATION   |                          |   |                              |                                     |
|---|--------------------------|---|------------------------------|-------------------------------------|
| AAMA ALTERNATE DOOR CERTIFICATION PROGRAM ASTM E330-14 DP = ±50 psf STP = ±75 psf | RECORD OF PRODUCT TESTED |   |                              |                                     |
| COMPANY AND CODE  | CPD NO.                  | SERIES MODEL & PRODUCT DESCRIPTION                  | MAXIMUM SIZE TESTED          |                                     |
| Elixir Door and Metals Co.<br>Code: EXR   | 19345                    | 407 VINYL LAMINATED<br>OUTSWING DOOR<br>(AL)(ST)(X) | <u>FRAME</u><br>3'2" x 6'10" | <u>LEAF</u><br>3'0" x 6'8" x 1-1/2" |

This Certification will expire **August 19, 2025** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: Construction Consulting Laboratory

Report No.: CCL-20-167

Date of Report: September 28, 2020

Evaluated for Certification: January 28, 2021

Authorized for Certification: January 28, 2021

Fenestration and Glazing Industry Alliance

A·L·I

(Validator / Operations Administrator)

ACP-04 (Rev. 2/20)