



**AAMA CERTIFICATION PROGRAM**  
An FGIA Product Certification Program



**AUTHORIZATION FOR PRODUCT CERTIFICATION**

**Elixir Door and Metals Co.**  
**1215 Pope Dr.**  
**Douglas, GA 31533**

**Attn: Randall Yarberry**

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED			
ASTM E330-14 DP = $\pm 65$ psf STP = $\pm 97.5$ psf				
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
Elixir Door and Metals Co. Code: EXR	21212	BVI63S STEEL SKINNED INSWING DOOR W/STORM (WD)(VC)(ST)(X) (INS TEMP GL)	<u>FRAME</u> 40" x 83"	<u>LEAF</u> 36" x 79" x 1-3/4" <u>FIXED INSERT</u> 22" x 36"


This Certification will expire **March 24, 2028** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: **Construction Consulting Laboratory**

Report No.: **CCL 23-091**

Date of Report: **July 31, 2023**

Evaluated for Certification: **August 14, 2023**

  
Associated Laboratories, Inc.

Authorized for Certification: **August 14, 2023**

  
Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)

ACP-04 (Rev. 2/20)