



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

Elixir Door and Metals Co.
1215 Pope Dr.
Douglas, GA 31533

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED			
AAMA ALTERNATE DOOR CERTIFICATION PROGRAM ASTM E330-14 DP = ±50 psf STP = ±75 psf				
COMPANY & CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
Elixir Door and Metals Co. Code: EXR	19355	BVIF7S VINYL LAMINATED INSWING DOOR W/STORM (WD)(ST)(X) (FIXED INSERT W/INS TEMP GL) (OS FULL LITE EXT STORM)	FRAME 38" x 82"	LEAF 36" x 79" x 1-1/2" FIXED INSERT 22" x 64"

This Certification will expire **July 29, 2030 (extended from July 29, 2025 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.


Product Tested and Reported by: **Construction Consulting Laboratory**

Report No.: **CCL-20-171**

Date of Report: **October 16, 2020**

Date Test Completed: **July 29, 2020**

Evaluated for Certification: **June 20, 2024**


Associated Laboratories, Inc.

Authorized for Certification: **June 20, 2024**


Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173



(Validator / Operations Administrator)