



Product Service

CERTIFICATE

No. B 004759 0006 Rev. 00

Holder of Certificate: **PACIFIC ELECTRIC
WIRE & CABLE CO., LTD.**
No.858, Sec.5, Kuaisu Rd.
Yangmei District
32661 Taoyuan City
TAIWAN

Certification Mark:



Product: **Electric Cables**
**Electric cables for photovoltaic systems
with a voltage rating of 1,5 kV DC**

Model(s): **62930 IEC 131**
**1×1.5mm², 1×2.5mm², 1×4mm², 1×6mm², 1×10mm², 1×16mm²,
1×25mm², 1×35mm², 1×50mm², 1×70mm², 1×95mm²,
1×120mm², 1×150mm², 1×185mm², 1×240mm²**

Parameters:

Rated Voltage:	DC 1.5 kV
	AC U ₀ /U: 1.0/1.0 kV
Class (IEC 61140):	II
Ambient Temperature:	-40°C ~+90°C
Max. Temperature at conductor:	120°C

Tested according to: IEC 62930:2017

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704072012301-01
Valid until: 2030-06-02

Date, 2025-06-03

(Yaqun Alex Liu)