

# PORTABLE APPLIANCE TEST LOG

<b>CLIENT</b>	FRED HOLDEN	<b>CONTRACTOR</b>	TALEK SEMMENS	<b>DATE</b>	23/03/2026	<b>CERTIFICATE NO.</b>	00006
<b>CLIENT ADDRESS</b>	527 AIRPOINT, SKYPARK ROAD, BRISTOL BS3 3NL	<b>CONTRACTOR ADDRESS</b>	4 LYNCOMBE WALK, FISHPONDS, BRISTOL BS16 4DF	<b>VALID UNTIL</b>	22/03/2027		
				<b>TESTING APPARATUS</b>	SEAWARD PRIMETEST 220		

APPLIANCE ID	APPLIANCE DESCRIPTION	TEST TYPE	EARTH CONTINUITY		INSULATION RESISTANCE	VISUAL INSPECTION		INSULATION TEST	FUNCTIONAL TEST	PASS/FAIL
FH0007	IEC C13-C14 EXTENSION	CL I – IEC	0.22	✓	>200M	✓	✓	✓	✓	PASS
FH0008	IEC C13-C14 EXTENSION	CL I – IEC	0.19	✓	>200M	✓	✓	✓	✓	PASS
FH0009	IEC C13-C14 EXTENSION	CL I – IEC	0.08	✓	>200M	✓	✓	✓	✓	PASS
FH0010	IEC C13-C14 EXTENSION	CL I – IEC	0.20	✓	>200M	✓	✓	✓	✓	PASS
FH0012	IEC C13-C14 EXTENSION	CL I – IEC	0.18	✓	>200M	✓	✓	✓	✓	PASS
FH0013	IEC C13-C14 EXTENSION	CL I – IEC	0.16	✓	>200M	✓	✓	✓	✓	PASS
FH0014	IEC C13-C14 EXTENSION	CL I – IEC	0.11	✓	>200M	✓	✓	✓	✓	PASS
FH0015	IEC C13-C14 EXTENSION	CL I – IEC	0.14	✓	>200M	✓	✓	✓	✓	PASS
FH0018	IEC C13-C14 EXTENSION	CL I – IEC	0.25	✓	>200M	✓	✓	✓	✓	PASS
FH0019	IEC C13-C14 EXTENSION	CL I – IEC	0.19	✓	>200M	✓	✓	✓	✓	PASS
FH0020	IEC C13-C14 EXTENSION	CL I – IEC	0.11	✓	>200M	✓	✓	✓	✓	PASS
FH0021	IEC C13-C14 EXTENSION	CL I – IEC	0.18	✓	>200M	✓	✓	✓	✓	PASS
FH0023	IEC C13-C14 EXTENSION	CL I – IEC	0.11	✓	>200M	✓	✓	✓	✓	PASS
FH0024	IEC C13-C14 EXTENSION	CL I – IEC	0.29	✓	>200M	✓	✓	✓	✓	PASS
FH0025	IEC C13-C14 EXTENSION	CL I – IEC	0.35	✓	>200M	✓	✓	✓	✓	PASS
FH0026	IEC C13-C14 6-WAY SPLIT (SURGE PROTECTED)	CL I – IEC	0.10	✓	>200M	✓	✓	✓	✓	PASS
FH0027	IEC C13-C14 6-WAY SPLIT (SURGE PROTECTED)	CL I – IEC	0.09	✓	>200M	✓	✓	✓	✓	PASS

FH0029	GEAR4MUSIC GALAXY19 LED BAR	CL I	0.09	✓	>200M	✓	✓	✓	✓	PASS
FH0030	GEAR4MUSIC GALAXY19 LED BAR	CL I	0.08	✓	>200M	✓	✓	✓	✓	PASS
FH0031	THE BOX MA8/2CL ACTIVE LOUDSPEAKER	CL I	0.14	✓	>200M	✓	✓	✓	✓	PASS
FH0032	BEHRINGER XAIR XR16 AUDIO MIXER	CL I	0.14	✓	>200M	✓	✓	✓	✓	PASS
FH0034	YAMAHA DXR12 ACTIVE LOUDSPEAKER	CL I	0.09	✓	>200M	✓	✓	✓	✓	PASS
FH0035	YAMAHA DXR12 ACTIVE LOUDSPEAKER	CL I	0.19	✓	>200M	✓	✓	✓	✓	PASS
FH0100	BS1363 – IEC-C13 (13A-IEC)	CL I – IEC	0.07	✓	>200M	✓	✓	✓	✓	PASS
FH0101	BS1363 – IEC-C13 (13A-IEC)	CL I – IEC	0.06	✓	>200M	✓	✓	✓	✓	PASS
FH0102	BS1363 – IEC-C13 (13A-IEC)	CL I – IEC	0.03	✓	>200M	✓	✓	✓	✓	PASS
FH0103	IEC-C14 – BS1362 4-WAY SPLIT (IEC-13A)	CL I – IEC	0.15	✓	>200M	✓	✓	✓	✓	PASS
FH0104	IEC-C5 – USB-C ADAPTER (MACBOOK CHARGER)	CL II	–		>200M	✓	–	✓	✓	PASS

**APPLIANCES INSPECTED:**

**ADDITIONAL NOTES:**

- The following items present on the previous inspection were absent/not inspected:
  - FH0001
  - FH0002
  - FH0003
  - FH0004
  - FH0005
  - FH0011
  - FH0016
  - FH0017
  - FH0022
  - FH0028

**DECLARATION**

The undersigned declares that all portable appliances detailed above were tested comprehensively and are physically and electrically safe for use.

**SIGNED:**

A handwritten signature in black ink, reading "Talek Demmens". The signature is written in a cursive style with a large initial 'T' and a long, sweeping underline.