

**EU Declaration of Conformity / UKCA  
ZPK 8066 Ni / SW**

 **EU Declaration of Conformity**

**Meter test terminal block**



<b>Order No.</b>	ZPK 8066 Ni / SW
<b>Manufacturer</b>	Schützinger GmbH   Eichwiesenring 6   70567 Stuttgart   Germany
<b>The sole responsibility for issuing this declaration carries the manufacturer.</b>	
<b>Rated voltage</b>	600 V CAT II
<b>Rated current</b>	1 A
<b>Description of the product</b>	for quick test connection to electric meter; spring clip for Ø 3 mm; socket Ø 4 mm; Connection must be dead when installed. Safety regulations for life working must be heeded
<b>European directives and European regulations</b>	<p>The object of the declaration described above is in conformity with the relevant harmonization legislation of the Union:</p> <ul style="list-style-type: none"><li>• <i>Low Voltage Directive 2014/35/EU</i> <i>published on 29 March 2014 at the EU Official Journal L 96/357-374 Number</i></li><li>• <i>RoHS II-Directive 2011/65/EC</i> <i>published on 01 July 2011 at the EU Official Journal L 174/88 Number</i> Applied exemption, Annex III, 6c: copper alloy containing up to 4 % lead by weight</li><li>• <i>Commission delegated Directive 2015/863/EC</i> <i>published on 06 June 2015 at the EU Official Journal L 137/10 Number</i></li><li>• <i>REACH-Regulation No. 1907/2006</i> <i>published on 30 December 2006 at the EU Official Journal L 396/1 Number</i> <i>CAS-Number: 7439-92-1</i> <i>Description: lead, up to 3 %, contained in metal parts</i></li></ul>
<b>Applied harmonized standards and technical specifications</b>	<ul style="list-style-type: none"><li>• <i>IEC/EN 61010-031:2016-07</i> <i>Safety requirements for electrical equipment for measurement, control and laboratory use - Part 031: Safety requirements for hand-held probe assemblies for electrical measurement and test (IEC 61010-031:2015)</i></li></ul>

**EU Declaration of Conformity / UKCA  
ZPK 8066 Ni / SW**

Stuttgart, 29.10.2024

  
.....  
Bernhard Schützing, CEO

EU Declaration of Conformity / UKCA  
ZPK 8066 Ni / SW



**Meter test terminal block**

<b>Order No.</b>	ZPK 8066 Ni / SW
<b>Manufacturer</b>	Schützinger GmbH   Eichwiesenring 6   70567 Stuttgart   Germany
<b>The sole responsibility for issuing this declaration carries the manufacturer.</b>	
<b>Rated voltage</b>	600 V CAT II
<b>Rated current</b>	1 A
<b>Description of the product</b>	for quick test connection to electric meter; spring clip for Ø 3 mm; socket Ø 4 mm; Connection must be dead when installed. Safety regulations for life working must be heeded
<b>UK Statutory requirements</b>	The product is in conformity with the relevant UK Statutory Instruments (and their amendments): <ul style="list-style-type: none"><li>• <i>The Electrical Equipment (Safety) Regulations 2016</i></li><li>• <i>The Restriction of the Use of certain hazardous substances in Electrical and Electronic Equipment Regulations 2012</i></li></ul>

Stuttgart, 29.10.2024

  
.....  
Bernhard Schützinger, CEO