

EN 3 APPROVAL CERTIFICATE

Approval number: SP 88/11

This is to certify that the "VICTORY" EN 3 fire extinguisher with 2 kg carbon dioxide has been type approved with the above mentioned approval number.

Approval specifications: EN 3-7 : 2004 + A1 : 2007 in conjunction with the requirements of EN 3-10 : 2009

Test report no.: 20140944/ZX 92 *) in conjunction with the approval certificate no. SP 88/11 dated July 6th, 2011

Holder of the certificate: Ningbo Zhengxin Fire-Fighting Equipment Co., Ltd.
Rm 15B2, No. 1199 Hua Shan Road, WeiGaoQiao, Pudong, Shanghai 200137, China

Manufacturer: Ningbo Zhengxin Fire-Fighting Equipment Co., Ltd., No. 1199 Hua Shan Road, Shanghai
Factory: Wuchenyan, Huangjiabu Town, Yuyao City 315466, Zhejiang, China

Model name:	CO2A, alternat. model CO2A 250	Trade mark:	VICTORY
Assembly drawing no.:	ZX-CO2A-01 alternat. model ZX-CO2-2-10	List of parts no.	ZX-051-012 altern. model ZX-CO2-2-10
Fire extinguishing medium:	2 kg carbon dioxide (CO ₂) Reference no. –	Operation device:	Valve with handle and lever
Propellant:	–	Special detail:	Horn (1) acc. to drawing No. ZX-059-004 Horn (2) acc. to drawing No. ZX-059-005
Test fire rating:	34 B according to EN 3-7	Range of operating temperature:	- 30 °C to 60 °C

Notes: *) Supplementation: Alternative model as per dwg. no. ZX-CO2-2-10, PS 174 bar, PT 250 bar


The fire extinguisher is tested in accordance with the standard EN 3-7. Conformity to EN 3-7 is attested.

The manufacture of the fire extinguisher is subject of the factory production control within the scope of a quality management system according to EN 3-10 and is subject of surveillance by MPA Dresden GmbH.

The holder of the certificate is authorized to affix the above stated approval number on the marking label of the approved corresponding fire extinguisher as long as the results of our regular inspections, proceeded according to clause 10 of EN 3-10, are satisfactory.

This approval certificate is valid solely for fire extinguishers which correspond with the submitted test samples and with the confirmed documents.

September 15th, 2014



Grad. Eng. Bernd Ruhle
Manager of the certification office

MPA Dresden GmbH
Fuchsmühlenweg 6F
09599 Freiberg
www.mpa-dresden.de

Geschäftsführer: Thomas Hübler
Tel. +49(0)3731-20393-0
Fax +49(0)3731-20393110
E-Mail info@mpa-dresden.de

Amtsgericht Chemnitz HRB 28268
Steuernummer: 220/114/03364
USt-IdNr. DE291271296

Sparkasse Mittelsachsen
Poststraße 1a
09599 Freiberg
IBAN DE68 870520003115024672
BIC WELADED1FGX

