

2. SUPPLEMENT TO EN 3 APPROVAL CERTIFICATE

Approval number: SP 220/14

Issue date of the approval certificate: 09 January 2015

Identification of the fire extinguisher: „Victory“ EN 3 fire extinguisher
with 6 kg ABC power

Requested by: NingBo ZhengXin Fire-Fighting Equipment Co., Ltd.
No. 1199 Hua Shan Road, 200137 Shanghai, P.R. China

Manufacturer: NingBo ZhengXin Fire-Fighting Equipment Co., Ltd., No. 1199 Hua Shan
Road, Shanghai,
Factory: WuChenYan, HuangJiaBu Town, YuYao City, 315466, ZheJiang,
P.R. China

Model name: PD6E-E

Modification / Supplementation: Fire rating : 34 A and 233 B according to EN 3-7
Basis is the supplementary test report no. 20170444/ZX 119

The fire extinguisher with the aforementioned approval number is tested in accordance with the standard EN 3-7 also with the indicated modifications.

Conformity of the modified fire extinguisher to the standard EN 3-7 is attested.

Other regulations of the EN 3 approval certificate are not affected by this supplement.

26 July 2017



Grad. Eng. Bernd Rühle
Manager of the certification office

