



**District Level Water Quality Testing and Monitoring Laboratory  
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun**

**TEST REPORT**

Name and Address of Organization/ Customer	Trinity High School, Dhoolkot, P.O. Selaqui, Dehradun, Uttarakhand.		
Test Report ID	49/UJS/DLWQTML/2026-27	Reporting Date	15/05/2026
Date and Time of Sample Received:	13/05/26 & 1:46 PM	Sample Location	Dhoolkot, P.O. Selaqui, Dehradun
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2026-27/49	Duration of Analysis	13/05/2026 to 14/05/2026


S.N.	Parameters	Test Method	Result	Requirement (Acceptable Limit) As per (IS 10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
<b>(A) Organoleptic and Physical Parameters</b>					
1.	pH at 25°C	IS 3025 (Part 11)	7.13	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C, mg/L	IS 3025 (Part 16)	140	500 Max	2000 Max
3.	Turbidity, NTU	IS 3025 (Part 10)	0.42	1 Max	5 Max
4.	Colour, CU	IS 3025 (Part 4)	Less than 01	5 Max	15 Max
5.	Odour	IS 3025 (Part 5)	Agreeable	Agreeable	Agreeable
<b>(B) General Parameters Concerning Substances</b>					
6.	Total Alkalinity (as CaCO <sub>3</sub> ), mg/L	IS 3025 (Part 23)	60	200 Max	600 Max
7.	Total Hardness (as CaCO <sub>3</sub> ), mg/L	IS 3025 (Part 21)	110	200 Max	600 Max
8.	Calcium as Ca, mg/l	IS 3025 (Part 40)	18.4	75 Max	200 Max
9.	Chloride as Cl, mg/l	IS 3025 (Part 32)	12	250 Max	1000 Max
10.	Magnesium as Mg, mg/l	IS 3025 (Part 46)	15.55	70 Max	100 Max
<b>(C) Microbiological Parameters</b>					
	Parameters	Test method	Results	Requirements as per IS 10500:2012	
11.	Total Coliform (in 100ml)	IS 15185:2016	Absent	Shall not be detectable in any 100 ml sample	
12.	<i>E. coli</i> (in 100ml)	IS 15185:2016	Absent	Shall not be detectable in any 100 ml sample	

Note -

1. The results listed refer only to tested sample and applicable parameters. 2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory. 3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer. 4. The results apply to the sample as received. 5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer.

\*\*\* End of Report\*\*\*

Review and Authorized By

  
 Dr. Vishu Khandari  
 Technical Manager

Testing Laboratory  
 DLWQML  
 Uttarakhand Jal Sansthan  
 Dehradun



District Level Water Quality Testing and Monitoring Laboratory  
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun

**TEST REPORT**

Name and Address of Organization/ Customer	Trinity High School, Dhoolkot, P.O. Selaqui, Dehradun, Uttarakhand.		
Test Report ID	49A/UJS/DLWQTML/2026-27	Reporting Date	15/05/2026
Date and Time of Sample Received:	13/05/26 & 1:46 PM	Sample Location	Dhoolkot, P.O. Selaqui, Dehradun
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2026-27/49	Duration of Analysis	13/05/2026 to 14/05/2026


SN	Parameters	Test Method	Results	Requirement (Acceptable Limit) As per (IS 10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
<b>(D) General Parameters Concerning Substances</b>					
1.	Fluoride, mg/l	IS 3025 (Part60/Sec 1)	Less than 0.2	1.0 M <sub>ax</sub>	1.5 M <sub>ax</sub>
2.	Nitrate, mg/l	IS 3025 (Part34/Sec 1)	Less than 01	45 M <sub>ax</sub>	No Relaxation
3.	Iron, mg/l	IS 3025 (Part53)	0.05	1.0	No relaxation
4.	Sulfate, mg/l	IS 3025 (Part24/Sec 1)	Less than 05	200 M <sub>ax</sub>	400 M <sub>ax</sub>

**Note -**

1. The results listed refer only to tested sample and applicable parameters. 2. This certificate is not to be reproduced wholly or in parts, grammatically, publicly or legal purpose without permission of authority of testing laboratory. 3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer. 4. The results apply to the sample as received. 5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer.

\*\*\*\* End of Report\*\*\*\*

Review and Authorized By

  
(Dr. Vikash Khandari)  
Technical Manager, Lab

Technical Officer  
DLWQTML  
Uttarakhand Jal Sansthan  
Dehradun

## DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 49/UJS/DLWQTM/2026-27

Dated: 15/05/2026

It is certified that an inspection team headed by Dr. Vikash Kandari, Technical Manager (Name of Officers with designation) from District Level Water Quality Testing and Monitoring Laboratory, UJS, Dehradun inspected the school Trinity High School, Dhoolkot, P.O. Selaqui, Dehradun, on 12.05.2026, and on the basis of Water Test Report (Attached) bearing 49/UJS/DLWQTM/2026-27 dated 15/05/2026 of District Level Water Quality Testing and Monitoring Laboratory, Uttarakhand Jai Sansthan, certified that the school Trinity High School, Dhoolkot, Dehradun, Uttarakhand has safe drinking water facilities for the students and members of staff of the institution. School also maintains hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This Certificate is valid till for 06 Month

Signature with Seal:

Name:



Designation: Technical Manager

Name & Address of the Office / Department:

To,

Trinity High School,  
Dhoolkot, P.O. Selaqui, Dehradun, Uttarakhand.

Technical Manager  
DLWQTM  
Uttarakhand Jai Sansthan  
Dehradun