

Government of Andhra Pradesh
A.P. State Disaster Response and Fire Services Department

Periodical Renewal Fire Certificate

From:
 Regional Fire Officer
 Zone-2, Rajahmundry
 Andhra Pradesh.

To:
 The District Educational Officer, East
 Godavari District.,

File No: 34597/EGV/RFO/2026, Date:10/09/2026
Occupancy NOC RC Number: 2527/EG/RFO/2018

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of Sri Rajasree Educational Society (Laurel High EM School), represented by S Ravi, R.S.No.361, 362 & 363, Gadala Village, Korukonda Mandal, East Godavari District. - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.01-09-2025.
 3. This Office NOC for Occupancy Rc No. 2527/EG/RFO/2018, Dt.30/04/2018
 4. Renewal NOC For Occupancy 2527/EG/RFO/2018, Dt.28/03/2025
 5. Online Application for Renewal NOC of S Ravi, R.S.No.361, 362 & 363, Gadala Village, Korukonda Mandal, East Godavari District. - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 01-01-1900.

-- x --

The Management of Sri Rajasree Educational Society (Laurel High EM School), represented by S Ravi, R.S.No.361, 362 & 363, Gadala Village, Korukonda Mandal, East Godavari District. has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.297913/- vide challan No. 11193393422026, Dated 05/09/2026 at ONLINE, ONLINE.

Sri Rajasree Educational Society (Laurel High EM School)

2. The builder has constructed a Non Multi Storeyed Building with 4 Upper Floors with a height of 14.95 Mtrs for Educational Occupancy (Category - B1) in a total plot area of 18162.34 sq. meters.
3. Open Spaces:

NOTE: It is the responsibility of the local Municipal authorities i.e., Municipal Corporations, Panchayats, IALA, SEZ, APIIC etc., to ensure the setbacks as per local building rules are in force vide G.O.Ms.No.44 Home (Prisons & Fire) Department Dated:12-03-2024.

4. The builder has provided the following means of escape:

Sl	Details of Staircases	Provided Nos / Meters
1	Internal Staircases	5 Nos. - 1.76 Meters Each
	Total	8.80 Meters

5. Occupant Load :

Sl	Floor	Built up area (Sq Mtrs)	Occupancy Type
1	GROUND	3173.1	Educational
2	FIRST	2907.6	Educational
3	SECOND	2936.77	Educational
4	THIRD	2899.08	Educational
	Total	11916.55	

6. The minimum Fire Fighting Installations required and provided as per Table 7 of Part 4 of National Building Code of India 2016 are:

Sl	Fire Fighting Equipment	Provided
1	Fire Extinguishers	Provided
2	Hose Reel Systems	Provided
3	Terrace Tank	Provided
4	Booster Pump	Provided

7. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023

8. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate vide reference 4th cited to the existing Non Multi Storeyed Building.

9. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate S Ravi R.S.No.361, 362 & 363, Gadala Village, Korukonda Mandal, East Godavari District., subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

10. The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

11. This Periodical Renewal Fire Certificate is valid from 10/09/2026 to 09/09/2031.

12. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire Services Act 1999 and Rules, 2006.

13. Challan Info:

Challan Number	Challan Date	Challan Amount
11193393422026	2026-09-05	297913

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended by the management.

Recommended : Respected Sir, I, District Disaster Response and Fire Officer, East Godavari District, along with the Assistant District Fire Officer, Rajamahendravaram Fire Station, inspected the above said premises and found that the existing building consists of Ground + 03 Upper Floors. The management obtained Occupancy NOC vide File No. 2527/EG/RFO/2018, dated 30.04.2018, of the Regional Fire Officer, Andhra Pradesh, Vijayawada, and the last renewal was obtained vide File No. 25609/EGV/MSB/2025, dated 28.03.2025, of the Director General, State Disaster Response and Fire Services, Andhra Pradesh, Vijayawada. Now the management has applied for periodical renewal of NOC and remitted fire precautionary fee of Rs. 2,97,913/- vide Challan No. 11193393422026, dated 05.09.2026, towards renewal of NOC for a period of 05 years. The existing firefighting equipment is in good working condition. Hence, issuance of Renewal of NOC is recommended.

Note: This Fire No Objection Certificate shall remain valid only subject to continuous compliance with all the conditions stipulated herein and maintenance of all Fire Prevention, Fire Protection and Life Safety Measures, systems and equipment in proper and fully operational condition at all times. If, during any inspection or random verification, any such measure, system or equipment is found non-functional, defective or not maintained as prescribed, or if the Management fails to comply with any condition within the period stipulated in the affidavit/undertaking furnished by it, this Fire No Objection Certificate shall be liable to cancellation by the Issuing Authority, notwithstanding the validity period specified herein, without prejudice to any other action permissible under the applicable Act and Rules.

"Safe School, Safe Hospital & Fire Safety Society-Together for Fire Prevention"

"सुरक्षित विद्यालय, सुरक्षित अस्पताल एवं अग्नि सुरक्षा के प्रति जागरूक समाज आग की रोकथाम के लिए एक साथ"

"సురక్షిత పాఠశాలలు, సురక్షిత మైన ఆసుపత్రులు మరియు అగ్నిమాపక భద్రతపై సమైక్య ఉన్న సమాజం మంటలను నివారించడానికి కలిసి పనిచేస్తాయి."



Your Sincerely,

[Signature]
Regional Fire Officer
Zone-2, Rajahmundry
Andhra Pradesh.

In case of emergency, please call 101 or 08813-231101 or 9963726417

Copy to S Ravi, Sri Rajasree Educational Society (Laurel High EM School), Sunkara Lakshmi Satyanarayana & Sons, At R.S.No.361, 362 & 363, Gadala Village, Korukonda Mandal, East Godavari District.

Copy to Chief Office for Record Purpose

Copy to District Fire Officer Concerned

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned